FILE NO. 146

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION (Alterations: Extensions)
TYPE OF LICENSE OR PERMIT

November 4, 1970
THIS LICENSE OR PERMIT EXPIRES

Scott Schleicher
LICENSEE OR PERMITTEE

Rt. 1, Lincoln (West Burnham)
ADDRESS

NAME OF ESTABLISHMENT, IF ANY

T 9N; R 6E; Sect. 4; Lot W 1/2 6; Stockwell Addition (Legal Description)
ADDRESS

West Burnham Street

REMARKS: Non-Transferable

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
143-1535	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-31(67) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 146

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 5-1-70

The undersigned hereby applies for a permit to ALTER [X], EXTEND [X], or REPAIR [ ] an existing Individual Sewage Disposal System, in conformance with Lincoln City Ordinance No. 9150, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 9N; Range 6E; Section 4; STOCKWELL
Block [illegible]; Lot [illegible] Addition ~~SHELDON HEIGHTS~~
Street Address West Bourham

2. Property Use: Residential [X]; Commercial [ ]
No. Bedrooms 3 Describe

Other Use [ ]
Describe

3. Type of existing Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Description of proposed alteration, extension or repair: Put in seepage line to creek on lateral line

5. Work to be done by: Owner [ ]; or Contractor [X], Giebelhaus Plumbing
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$	over 200.00

test by D. Smith
Smith Pumping Co.
3400 No 33rd

Scott Schleicher
Signature of Applicant (owner or lessee)

RT 1 - West Bourham
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd:
Filing Fee: $ 30.00

2. Date Site Clearance:

3. Site Visits:
Date: 5/8/70 by: L.C.H. + DD & L.W.
Date: 5/11/70 by: L.W.
Date: by:

4. Date: Approved [X]; Disapproved [ ]
by: Jerrald C. Hood

5. BUREAU OF LICENSES & PERMITS
Date Notified:
Date Issued: Serial

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 5/11/70 by: L.C.H.

FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 146

PROPERTY WHERE SOIL TESTED:
Location: Township _____
Section & ¼ Sect. _____
Property Dimensions: ____ft. x ____ ft.
Area: _____acres. (Attach sketch of property showing hole location).

Owner: Scott Schleicher
Address Rt 1 - West Burnham

Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☒; Clay Loam ☐; Sandy Clay ☐

Dates of Tests: 4/29/70 to 5/1/70. Weather: Precip. No Temp. 50 F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
Hole No.	Hole Depth (in.)	Pre-Saturation Period Start Date (Mo. Day)	Start Time (Hr. Min.)	End Date (Mo. Day)	End Time (Hr. Min.)	Percolation Readings Start Date (Mo. Day)	Start Time (Hr. Min.)	Start Water Level (in.)	End Time (Hr. Min.)	End Water Level (in.)	Results Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	28	4/29	1 P	4/29	5 P	5/1	12:59	6	1:29	3/4	30	5¼	60 - 10½
2	26	4/29	1 P	4/29	5 P	5/1	12:59	6	1:29	6	30	0	60 - 0
3	20	4/29	1 P	4/29	5 P	5/1	12:59	6	1:29	4	30	2	60 - 4
4	23	4/29	1 P	4/29	5 P	5/1	12:59	6	1:29	3½	30	2½	60 - 5
5	21	4/29	1 P	4/29	5 P	5/1	12:59	6	1:29	4½	30	1½	60 - 3
6	23	4/29	1 P	4/29	5 P	5/1	12:59	6	1:29	5¾	30	¼	60 - 1½

Sum of Percolation Rates
Average of Rates: 60 - 24
Mean of Rates: 15 - 4

Signature of Person Conducting Test

Address 3800 No. 27
Phone: 434-9393

(Do not write below this line)


REVIEWING ACTION

REMARKS: _____


Approved Percolation Rate(s)
A. 15 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: May 1, 1970

Gerrold C. Hood
Signature of Reviewing Official



CREEK



CROSS SECTION
UNDER DRAIN SYSTEM