Lincoln-Lancaster County Health Department
Environmental Public Health Division
3140 N Street • Lincoln NE 68510-1514
Phone: 402-441-8643

D Exhibit 4

Permit Number:

Onsite Wastewater Treatment System
As-Built Description and Drawing

Type of Onsite Wastewater System: ☐ Lagoon (Skip to Back Page) ☒ Subsurface Septic ☐ Mound

Onsite Wastewater System Location

Address or Legal Description or Parcel Identification Number (PID) _____

Owner: Danielle Urban Address 2601 w Claire Ave Lincoln

A. Wastewater Piping

1. Material: PVC Diameter: 4 in.
2. Distance between dwelling and septic tank: ____ ft.

B. Septic Tank

1. Material Snyder Poly
2. Capacity: 2000
3. Depth to top of tank, below unfinished grade: 16 in.
4. Distance to:
   Well Over 100 ft.
   Pressure line " ft
   Property Line " ft.
   Foundation " ft.

C Distribution Box or Drop Box

Distance and Direction from septic tank: 14 ft. N

D. Drainfield/Absorption Field

☒ Trench ☐ Bed

1. Type: ☐ Perforated Pipe ☐ Chamberless ☐ Other
   Material brand and inside width of Chamberless: Infiltrator Quick 4 Plus 29"
2. Number of Laterals: 4
3. Length of each lateral (linear): ft. 148 ft. 148 ft. 148 ft. 44
4. Drainfield size: 1769 sq. ft.
5. Distance to:
   Well Over 100 ft.
   Pressure line " ft.
   Property line " ft.
   Depth of Groundwater Over 12

Was the Onsite Wastewater System covered prior to LLCHD inspection? ☐ Yes ☒ No

If Yes, the Certified Professional must sign below for final approval:

I swear and affirm that the system complies with Lincoln Municipal Code (LMC) 24.38 and/or County Resolution R-13-0062 requirements and that the information and documentation submitted are true and accurate.

Certified Professional Signature: _____ Date: Nov 17 2016

Complete As-Built drawing on the back of this form.

488' Intimater
Quick 4 Plus

N

148'
148'
148'
148'

14'
14'
14'
14'

2-1000 gal
Snyder Poly
Tanks w/16"
Risers

51'-6"

26'

39'

4'

008

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 11-23-93

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 6E; SECTION 9; BLOCK ___

LOT 14; ADDITION ___; Street Address 2001 W Clare Ave, Lincoln

Directions to Property ___

Location of Well ___ Tap Location: Inside ☐ Outside ☒

Location of Sewage System ___ Year Installed 1987

	NAME	ADDRESS	PHONE
Present Owner:	Melvin & Kathleen Goddard	2001 W Clare, Lincoln	421-1230 (H)
~~Tenant/Buyer:~~		Kathy	471-2781 (W)
Return to:	Security Federal Savings	P.O. Box 81849, Lincoln 68501	474-4444

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Christy Walker Address Security Federal

==========

HEALTH DEPARTMENT USE ONLY

Date Received 11/29/93 Received $150.00 Check ☒ Cash ☐

CK# 49533 CW

PRELIMINARY STATUS--DATE DECEMBER 6, 1993

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☒	☐	Approved:	☒	Date 12/1/93 by J.C.H.
Bacteria 0	☒	☐	Provisional:	☐	Date ___ by ___
Nitrate 4.2 RP.M.	☒	☐	Disapproved:	☐	Date ___ by ___

Comments: IF THE SEPTIC TANK HAS NOT BEEN PUMPED RECENTLY IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED.

___ See Attached Letter ☐

FINAL STATUS

	WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
	Approved: ☒	Approved: ☒	Provisional Approval: ☐

APPROVED BY Gerrold C. Hood R.E.H.S. DATE DECEMBER 3, 1993

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

093

NO3 RECHECK

P11685-21

Lincoln-Lancaster County Health Department

000323005 1of

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

FOR PROPERTY IN **LANCASTER COUNTY** ONLY

COLI 3/21/00

This form must be completed and returned with payment to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: "Lincoln-Lancaster County Health Department" or "LLCHD"

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

LCR 910

Legal Description of Property: Street Address 2601 W. Claire Ave

Twp 9N Range 6E Section 9 1/4 ___ 1/4 ___ Block ___ Lot 141 Addition ___

Directions to Property ___

Location of Well SE of house aprx 45' Tap Location: Inside ☒ Outside ☐

Location of Sewage System West side of House a little North Year Installed 1986

	NAME	ADDRESS	PHONE
Present Owner:	Mel & Kathleen Goddard	2601 W Claire Ave Lincoln NE 68523	421-1230
Tenant/Buyer:	Don & Jodi Urban	2001 SW 47th Lincoln, Ne, 68522	438-3678
Return to:	Don & Jodi Urban	2001 SW 47th Lincoln, Ne, 68522	438-3678

STATE TITLE 434-5040 ATTN: CHERYL OLDHAM

Signature of Applicant Don J. Urban Address 2001 SW 47th LINCOLN NE Date 1/24/00

HEALTH DEPARTMENT USE ONLY

RECEIVED

Date 01/31/00
Initials ___
Amount 150.00
Check No. 3647

DATA ENTRY

Date ___/___/___
Case No. ___
Initials ___

PRELIMINARY STATUS--By Jerrold C. Hood **DATE:** 2/1/00

CORRECTED 3/21/00 J.C.H.

WATER SYSTEM:	Approved	Disapproved
Construction	☐	☒
Bacteria	☒ 0 /ml	☐ ___ /ml
Nitrate	☒ 8.1 ppm	☐ ___ ppm

SEWAGE SYSTEM	
Approved	☒
Provisional	☐
Disapproved	☐

Additional Site Visits

Date 2/2/00 by J.C.H.
Date ___/___/___ by ___
Date ___/___/___ by ___

Comments: ELECTRICAL CONDUIT IS BROKEN AND SEPARATED ON WELL HEAD. IF THE SEPTIC TANK HAS NOT BEEN PUMPED RECENTLY IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED. A WATCH ON THE NITRATE LEVEL OF THE WELL WATER SHOULD BE DONE AS IT IS NEARING THE 10 P.P.M THRESHOLD. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved ☒ **SEWAGE DISPOSAL SYSTEM:** Approved ☒ Provisional Approval ☐

Approved by Jerrold C. Hood R.E.H.S. Date 3/23/00

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

White - Applicant after approval Yellow - Environmental Health Pink - Business Office

Revised/Reprint: 10-95