CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

FILE NO. 1221

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — MAY 10, 1978

TYPE OF LICENSE OR PERMIT — THIS LICENSE OR PERMIT EXPIRES

Randy Wobig — 1520 Pioneer Blvd, Lincoln, NE

LICENSEE OR PERMITTEE — ADDRESS

T9N, R6E, Section SW¼ of 9 —

NAME OF ESTABLISHMENT, IF ANY — ADDRESS

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
110.15	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT
624-1535		

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

HEALTH

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒

County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 121

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 10-26-77

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

SEE ATTACHED

1. Legal description of property: Twp. 9N ; Range 6E ; Section SW¼ 9
   Block _____; Lot _____; Addition _____
   Street Address _____

2. Property Use: Residential _____ ☒ ; Commercial _____ ☐
   No. of Bedrooms 3 . Describe: _____
   Other Use _____ ☐
   Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: N/A ft.

Rudy Uehrig
Signature of Applicant (Owner or Lessee)

1520 PIONEER BLVD.
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 11/10/77. Date Frwd. 11/10/77. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 11-10-77 Date Frwd. 11-10-77. ACTION: Approved ☒ Disapproved ☐ Signature: [illegible]

3. City ~~or County~~ Engineer: Date Rec'd. 11-10-77. Date Frwd. 11-10-77. ACTION: Approved ☒ Disapproved ☐ Signature: [illegible]

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1321

DATE: 10-26 1977

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto. SEE ATTACHED

1. Legal description of property: Twp. 9N ; Range 6E ; Section SW¼ 9 ; Block ; Lot ; Addition .
   Street Address .

2. Property Use: Residential X [ ]; Commercial [ ]
   No. of Bedrooms 3
   Describe:
   Other Use
   Describe:

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Randy Wobig
Signature of Applicant (owner or lessee)

1520 Pioneer Lincoln, Ne.
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd;
   Filing Fee: $ 30.00

2. Site Visits:
   Date: 11-18-77 by: jw
   Date: by:
   Date: by:

3. Date: Approved [X]; Disapproved [ ] 11/10/77
   by: Jerrold C. Hoob

4. INSTALLATION FINAL WRITTEN APPROVAL
   Date: 11-18-77 by: James Weverka

FORM HD- 43(73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 475-6221)

FILE NO. 1221

PROPERTY WHERE SOIL TESTED:
Location: Township 9N ; Range 6E
Section & ¼ Sect. ____
Property Dimensions: 391 ft. x 556 ft.
Area: 5 acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☐; Sandy Clay ☐

Owner: Randy Wobig
Address SW¼ 9

Dates of Tests: 10-20 to 10-21. Weather: Precip. dry Temp. 65°

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	30	10-20	2:00PM	10-21	8:00AM	10-21	12:00	8¾	12:30	8	30	¾	
2	30						12:00	9½	12:30	8⅞	30	⅝	
3	32						12:10	6	12:40	5¼	30	¾	
4	30						12:10	8	12:40	7⅜	30	⅝	
5	32						12:15	9⅝	12:45	7½	30	1	
6	30						12:15	8	12:45	7½	30	½	

Sum of Percolation Rates 4.25
Average of Rates: .7083
Mean of Rates: ____

Signature of Person Conducting Test

Address ____
Phone: ____

(Do not write below this line)

REVIEWING ACTION

REMARKS: U.C.S.: Wymore Silty Clay Loam.

Approved Percolation Rate(s)
A. 44 min./inch
B. ____ min./inch
C. ____ min./inch

DATE: November 10, 1977

Signature of Reviewing Official

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1221

SPECIFICATIONS

DATE: NOV. 1, 1977


A. BUILDING SEWER:
1. Material Cast iron; Diameter 4 in.
2. Distance above basement floor ___ in.; or below basement floor 18 in.
3. Distance between dwelling and septic tank 140 ft.
4. Number of clean-outs 1.
5. Distances To:
Well or Suction Line 80 ft.;
Stream — ft.; Pressure Line ___ ft.;
Property Line ___ ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material fiberglass; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth ___ in.
3. Factory Built: Yes [X] (Company Calvary)
No ☐
4. Manholes: Over Inlet; diam. ___ in.
Over Outlet; diam. 24 in.
Below Grade ___ in.
5. Inlet: Baffle ☐; or Tee [X]
6. Outlet: Baffle ☐; or Tee [X]
Depth of outlet below inlet 4 in.
7. Depth of top of tank below finished grade 36 in.
8. Distances To:
Well or Suction Line 140 ft.;
Stream — ft.; Pressure Line 100 ft.;
Property Line 80 ft.

C. DISTRIBUTION BOX
1. Material fiberglass; No. available outlets ___.
2. Factory Built: Yes [X], (Company Calvary) No ☐
3. Dimension: Length ___ in.; Width ___ in. Depth ___ in.
4. Distance from Septic Tank 10 ft.
5. Serial Distribution: Yes ☐, No [X] (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: lateral
2. Lateral Lines: Depth below grade 24 in. Number 3; Length of each line ___ ft Total length of Laterals 298 ft.; Slope ___ in/100 ft. Diameter of pipe ___ in.; Shape ___
Material: concrete ☐; fiber asbestos ☐; clay [X]; other PVC
Distance between lateral lines 6 ft.
3. Trench Dimensions: Depth 36 in.; Width 36" in.
4. Filter Material: gravel.
Depth of material from trench bottom 8 in.
5. Distances To:
Well or Suction Line 140 ft.;
Stream ___ ft.; Pressure Line 100 ft.
Property Line 40 ft.
6. Percolation Rate: 44 minutes/inch

TYPICAL SKETCHES



Randy Webig
Signature of Applicant

Randy Wobig

Installer

11-18-77

