009

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

REAL ESTATE TRANSFER /

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 3-31-93

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 6E; SECTION 10; BLOCK ____

LOT 19I.T; ADDITION _____; Street Address 1121 W Pioneers Blvd.

Directions to Property Take west By Pass from the south on Old Cheny to W. Pioneers - Turn

Location of Well NORTH OF HOUSE Tap Location: Inside ☐ Outside ☐

Location of Sewage System SOUTH WEST OF HOUSE Year Installed _____

	NAME	ADDRESS	PHONE
Present Owner:	Janet Scott Swim	1121 W. Pioneers Blvd	421-1559
Tenant/Buyer:	Kent Sandell	5121 Hartley	
Return to:	FIRST COMMERCE SAVING JERRY PESEK	40TH & SOUTH ST	

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Kent Sandell Address 5121 Hartley, NE 68504

==========

HEALTH DEPARTMENT USE ONLY

Date Received APRIL 1, 1993 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE APRIL 2, 1993

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☒	☐	Approved:	☐	Date 4/2/93 by LCH
Bacteria	☒	☐	Provisional:	☒	Date _____ by ____
Nitrate 0.9 ppm	☒	☐	Disapproved:	☐	Date _____ by ____

Comments: WELL COMES CLOSE TO HAVING A DEPRESSION AROUND IT ALTHOUGH MAYBE NOT QUITE. COULD FILL IN A LITTLE DIRT AROUND WELL. PORTIONS OF THE SEPTIC SYSTEM PREDATE REGULATIONS HENCE APPROVAL IS PROVISIONAL. NO EVIDENCE OF MALFUNCTION. IF SEPTIC TANK HAS NOT BEEN PUMPED RECENTLY THEN IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☒	Approved: ☐	Provisional Approval: ☒

APPROVED BY Jerold C. Hood R.E.H.S. DATE APRIL 8, 1993

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

061