007

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-8000 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☑ Evaluation of the Individual Water System Date: 5/18/92

☑ Evaluation of the Sewage Disposal System ☑ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 6E; SECTION 14; BLOCK 1

LOT 10; ADDITION Lazy Acres; Street Address 935 Mockingbird Lane North

Directions to Property On So. 14th take 1st right onto Mockingbird Lane after passing Thunderbird Estates. Last House on road before private drive.

Location of Well northwest corner Tap Location: #10 on mailbox Inside ☐ Outside ☑

Location of Sewage System ~~north of garage~~ back yard Year Installed ~~1992~~

	NAME	ADDRESS	PHONE
Present Owner:	Estate of Ella Reusche)	935 Mockingbird Lane No.	N/A
Tenant/Buyer:	Liz Thanel / Bob Jarrett	1941 Northville Circle	477-5301 438-5060
Return to:	Gary Griffith, Columbus Federal Suite 325, 770 N. Cotner Blvd.		464-4444

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Liz Thanel Address 1941 Northville Circle

==========

HEALTH DEPARTMENT USE ONLY

Date Received MAY 20, 1991 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE 5-21-92

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☒	☐	Approved:	☐	Date 5-21-92 by P.D
Bacteria	☒	☐	Provisional:	☒	Date _____ by ____
Nitrate	☒ 0.6 ppm	☐	Disapproved:	☐	Date _____ by ____

Comments: Sewage System given provisional status because Health Department has no records regarding construction or alterations made at this property. Permits may not have been taken out prior to construction. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☒	Approved: ☐	Provisional Approval: ☒

APPROVED BY PAUL DROTZMANN DATE 5-27-92

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

078

009

Lincoln-Lancaster County Health Department

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

oln, Nebraska 68502 Phone: 441-8022

SFER/LOAN APPROVAL FORM

Outside faucets turned off. Can come into house to get water. Barking dogs are locked up.

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☒ Evaluation of the Individual Water System ☒ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 935 Mockingbird Lane North
Twp 9 Range 6 Section 14 1/4 ___ 1/4 ___ Block ___ Lot ___ Addition ___
Directions to Property 9/10 mile south of Old Cheney on 14th St, turn west - 1st house
Location of Well Northwest of garage Tap Location: Inside ☒ Outside ☒
Location of Sewage System ___ Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	Bob Jarrett + Liz Thane	Same	421-1414
Tenant/Buyer:			
Return to:	~~Same~~ Call Liz at 441-7530 when done - will pick up		

Signature of Applicant Bob Jarrett Liz Thane Address Same Date 10/27/93

HEALTH DEPARTMENT USE ONLY

Date Received 10/27/93 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By Paul Dyhrman **DATE:** 10/27/93

WATER SYSTEM:	Approved	Disapproved	**SEWAGE SYSTEM**	**Additional Site Visits**
Construction	☒	☐	Approved ☐	Date ___/___/___ by ___
Bacteria	☒ 0 /ml	☐ ___ /ml	Provisional ☒	Date ___/___/___ by ___
Nitrate	☒ 0.3 ppm	☐ ___ ppm	Disapproved ☐	Date ___/___/___ by ___

Comments: Sewage System given provisional status because Health Dept. is unable to determine if the system had been inspected during construction. Permits may not have been taken out prior to construction. See Attached Letter ☐

FINAL STATUS
WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☐ Provisional Approval: ☒

Approved by Paul Dyhrman Date 11/2/93

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

077