009

Lincoln-Lancaster County Health Department

2200 St. Mary's Avenue, Lincoln, Nebraska 68502 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

This form must be completed and returned to requ

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☐ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 2251 Pleasant Hill Rd.

Twp 9N Range 6E Section 16 1/4 ___ 1/4 ___ Block ___ Lot ___ Addition ___

Directions to Property ½ mile west of Coddington ½ mile north of Denton Rd.

Location of Well SW of house 100' Tap Location: Inside ☐ Outside ☒

Location of Sewage System west of house 100' Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	Tom Sundeland	2251 Pleasant Hill Rd	
	Sundling	Lincoln Ne 8523	
Tenant/Buyer:			
Return to:	Roger Krull	3510 "L" Street	476-8403

Signature of Applicant Roger D. Krull Address 3510 "L" Street Lincoln, Ne Date 5/17/93

HEALTH DEPARTMENT USE ONLY

Date Received 5/17/93 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By Jerrold Hood **DATE:** 5/17/93

WATER SYSTEM:	Approved	Disapproved
Construction	☐	☒
Bacteria	☒ ____/ml	☐ ____/ml
Nitrate	☒ 10 ppm	☐ ____ppm

SEWAGE SYSTEM
Approved ☐
Provisional ☒
Disapproved ☐

Additional Site Visits
Date 5/25/93 by L.C.H.
Date ___/___/___ by ___
Date ___/___/___ by ___ 5/27/93 J.C.R.

Comments: ELECTRICAL PLATE BROKEN ON WELL HEAD. PORTIONS OF THE SEPTIC SYSTEM PREDATE REGULATIONS HENCE APPROVAL IS PROVISIONAL. NO EVIDENCE OF MALFUNCTION. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☐ Provisional Approval: ☒

Approved by Jerrold C. Hood R.E.H.S. Date 5/27/93

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

071