FILE NO. 1954

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

June 28 1983 — THIS LICENSE OR PERMIT EXPIRES

Mrs. Geo. Cook — LICENSEE OR PERMITTEE

711 So. 42nd Lincoln, NE 68510 — ADDRESS

NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NONTRANSFERABLE T9N, R6E, Sec 16 Middle of N½

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
018754	XXXXXX	148.14	6-2

SERIAL NO.	DATE	AMOUNT
628	2	30.00

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

HEALTH APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

REC'D DEC 27 1982

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒

County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. _____

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 12/23

The undersigned hereby applies for a permit to ALTER ☐, EXTEND ☒, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 9N ; Range 6E ; Section 16 MIDDLE OF N ½ ;
Block _____ ; Lot _____ ; Addition _____
Street Address 5801 SW 12th

2. Property Use: Residential _____ ☒; Commercial _____ ☐
No. Bedrooms 3
Describe _____
Other Use ☐
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: ADDITION OF 100' OF ½ ROUND LATERAL W/ DIST. BOX

5. Work to be done by: Owner ☐ ; or Contractor ☒ , Southwick Sewer & Pavin
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$	1069.00

Brad Southwick
MRS. GEO. COOK
Signature of Applicant (owner or lessee)

711 S. 42nd Lincoln, 68510
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Site Visits:
Date: _____ by: J.C.H.
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 12/28/82 by: J. C. Hood

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

D

DATE: 12/23

FILE NO. _____


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material _____; Diameter _____ in.
2. Distance above basement floor _____ in., or below basement floor _____ in.
3. Distance between dwelling and septic tank _____ ft.
4. Number of clean-outs _____.
5. Distances to:
Well or Suction Line _____ ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

B. SEPTIC TANK:
1. Material CONCRETE No. of compartments _____.
2. Capacity 1,000 gals.;
3. Factory Built: Yes ☒ No ☐
(Company PRE CAST)
4. Manholes: Over Inlet; diam. 6 in.
Over Outlet; diam. 8 in.
Riser Above ☐ Below ☐ Grade ___ in.
5. Inlet: Baffle ☐ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☒
7. Depth of top of tank below finished grade 13 in.
8. Distances to:
Well or Suction Line 65 ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

C. DISTRIBUTION BOX:
1. Material PLASTIC; Number - available outlets 7.
2. Factory Built: Yes ☒ No ☐
(Company _____)
3. Distance from Septic Tank 15 ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☒ Perforated Pipe ☐
Diameter of Half Round 12" or
Perforated Pipe _____.
Material: fiberglass ☒ ; plastic ☐ ; concrete ☒ ; other _____.
2. Lateral Lines:
Number 2 ; Length of each line 50, 100, _____, _____, _____ ft.;
Total length of laterals 150' ft.;
Distance between lateral lines 10 ft.
3. Trench dimensions: Width 3½' ft.;
Slope 3½ in/100 ft.; Average Depth 36" in.
4. Filter Material: ROAD GRAVEL
Depth of Material 18 in.
5. Distances to:
Well or Suction Line 100 ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line 200 ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

AS BUILT DRAWING OF SYSTEM

DATE 12/23 INSTALLER Brad Southwick

