FILE NO. 1180

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF LICENSE OR PERMIT

March 30, 1978
THIS LICENSE OR PERMIT EXPIRES

Claude Oie — 4621 Pioneers Blvd. Lincoln, NE
LICENSEE OR PERMITTEE — ADDRESS

T9N, R6E, Section 17, Bl 2, Lot 3, Addtion Hitching Post Hills 1st
NAME OF ESTABLISHMENT, IF ANY — ADDRESS

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE	
624-1535	110.16	148.14	6-2	

SERIAL NO. — DATE — AMOUNT

47034 SE 3 77 30.00 -

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

Heater APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1180

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 9-30-77

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. T9N ; Range R6E ; Section 17
Block 2 ; Lot 3 ; Addition Hitching Post Hills 1st Addition
Street Address _____

2. Property Use: Residential _____ ☒ ; Commercial _____ ☐
No. of Bedrooms 3 . Describe: _____
Other Use _____ ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft.

Claude Oie
Signature of Applicant (Owner or Lessee)

4621 Pioneer Blvd.
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 9/30/77. Date Frwd. 9/30/77. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Rood

2. Supt. Bldg. Insp.: Date Rec'd. _____. Date Frwd. 9-30-77. ACTION: Approved ☒ Disapproved ☐ Signature: Tom Baasch

3. City or County Engineer: Date Rec'd. 9/30/77. Date Frwd. 9/30/77. ACTION: Approved ☐ Disapproved ☒ Signature: Joe Rolfe

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1180

DATE: 9-30-77

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. T9N ; Range R6E ; Section 17 ; Block 2 ; Lot 3 ; Addition Hitching Post Hills 1st Add.
Street Address _____.

2. Property Use: Residential _____ [X]; Commercial _____ [ ]
No. of Bedrooms 3
Describe: _____
Other Use _____
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Claude Qie
Signature of Applicant (owner or lessee)

4621 Pioneer Blvd.
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd; _____
Filing Fee: $ 30.00

2. Site Visits:
Date: 11-30-77 by: sm
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved [X]; Disapproved [ ] 9/30/77
by: Jerrold E. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 11-30-77 by: Ron Bryant

FORM HD-43 (73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 474-1541)

FILE NO. 1180

PROPERTY WHERE SOIL TESTED:
Location: Township T9N : Range R6E
Section & ¼ Sect. 17 E NE¼
Property Dimensions: 215 ft. x 616 ft.
Area: _____ acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ✓ ; Silty Clay Loam ; Sandy Loam
Silty Loam ; Clay Loam ; Sandy Clay

Owner: Claude OIE
Address: 4621 Pioneer Blvd.

Dates of Tests: 9-22-77 to 9-29-77. Weather: Precip. ¼ Temp. 70

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	36"	9-22	9:30	9-23	9:30	9-23	9:30	6½	10:00	5¾	30	¾	40
2	36"	9-22	10:00	9-23	10:00	9-23	10:00	6½	10:00	5½	30	1	30
3	36"	9-25	6:30	9-26	5:30	9-26	5:30	6¼	6:00	5	30	1¼	24
4	36"	9-25	7:00	9-26	6:00	9-26	6:00	6⅜	6:30	5¼	30	1⅛	27
5	36"	9-26	6:30	9-27	3:00	9-27	3:00	6	3:30	5⅛	30	⅞	34
6	36	9-26	7:00	9-27	3:00	9-27	3:00	6⅛	3:00	5¼	30	⅞	34

Sum of Percolation Rates: 5.875
Average of Rates: 0.9792
Mean of Rates:

Claude Oie
Signature of Person Conducting Test

Address 4621 Pioneer Blvd.
Phone 489-6061

Sum of Percolation Rates: 5.875
Average of Rates: 0.9792
Mean of Rates:

(Do not write below this line)

REVIEWING ACTION

REMARKS: Wymore silty Clay Loam. C.L.C.L.

DATE: September 30, 1977

Approved Percolation Rate (a)
A. 32 min./inch
B. _____ min./inch
C. _____ min./inch

Gerrold C. Hoab
Signature of Reviewing Official

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM

(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. _____

SPECIFICATIONS

DATE: 9-30-77


A. BUILDING SEWER:
1. Material PVC; Diameter 4 in.
2. Distance above basement floor ___in.; or below basement floor 8 in.
3. Distance between dwelling and septic tank 100 ft.
4. Number of clean-outs 2.
5. Distances To:
Well or Suction Line 150 ft.;
Stream — ft.; Pressure Line — ft.;
Property Line 50 ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Conc.; No. of compartments _____.
2. Capacity 1000 gals.; Liquid depth ___in.
3. Factory Built: Yes ☒ (Company _____)
No ☐
4. Manholes: Over Inlet; diam. ___in.
Over Outlet; diam. ___in.
Below Grade _____in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☐
Depth of outlet below inlet ___in.
7. Depth of top of tank below finished grade ___in.
8. Distances To:
Well or Suction Line 150 ft.;
Stream ___ft.; Pressure Line ___ft.;
Property Line 75 ft.


C. DISTRIBUTION BOX
1. Material Conc; No. available outlets 7.
2. Factory Built: Yes ☒, (Company _____) No ☐
3. Dimension: Length ___in.; Width ___in. Depth ___in.
4. Distance from Septic Tank 25 ft.
5. Serial Distribution: Yes ☐, No ☒
(If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: _____
2. Lateral Lines: Depth below grade 36 in.
Number 3; Length of each line ___ft
Total length of Laterals 258 ft.;
Slope ___in/100 ft. Diameter of pipe 4 in.; Shape Round
Material: concrete ☐; fiber asbestos ☐; clay ☐; other Plastic
Distance between lateral lines ___ft.
3. Trench Dimensions. Depth 36 in.;
Width 36 in.
4. Filter Material: gravel.
Depth of material from trench bottom 16 in.
5. Distances To:
Well or Suction Line 150 ft.;
Stream — ft.; Pressure Line — ft.
Property Line 50 ft.
6. Percolation Rate: 31.5 minutes/inch

TYPICAL SKETCHES



Claude Orr
Signature of Applicant



58 ft No of Hunt

38 ft east of Hunt

Orville Hunt