FILE # 2795

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

6 MONTHS — THIS LICENSE OR PERMIT EXPIRES

TERRY M. LINDSTROM 5321 SO. 51ST LINCOLN, NE 68516 — LICENSEE OR PERMITTEE / ADDRESS

T9N; R6E; Sec. 17; Blk 2; Lot 1; Hitching Post 3rd Addition — NAME OF ESTABLISHMENT, IF ANY / ADDRESS

REMARKS: NON TRANSFERABLE

NEW CONSTRUCTION

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 60.00	018754	$ 60.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. | Date and Amount

APPLICATION

HEALTH

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

A

FILING FEE: $ 60.00

FILE NO. 2795

DATE: 1-24-89

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N; Range 6E; Section 17;
   Block 2 : Lot 1 : Addition HITCHING POST THIRD ADD.
   Street Address 5901 SADDLE CREEK TRAIL

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3. Describe 2 story home
   LVL1 - 1166 ☐ LVL1 - 900 ☐

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: N/A. ft.

Terry Lindstrom T.M. Williams
Signature of Applicant (Owner or Lessee)

5321 So 51st Lincoln (16)
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 1/24/89. Date Frwd. 1/25/89. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Noel

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 1/25/89. Date Frwd. 1/25/89. ACTION: Approved ☐ Disapproved ☐ Signature:

3. City or County Engineer: Date Rec'd. 1-25-89. Date Frwd. 1-25-89. ACTION: Approved ☒ Disapproved ☐ Signature: Dennis Bartels

REMARKS OR REASONS FOR DISAPPROVAL

Site Visits:
Date: 4-6-89 by:
Date: by:
Date: by:

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

INSTALLATION FINAL WRITTEN APPROVAL
Date: 4-6-89 By: Ron Mogensen

FORM 23-43

RECEIVED APR 0 3 1989

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

B

FILE NO. _____

PROPERTY WHERE SOIL TESTED: Permit #

Location: Township _____; Range _____; Section & ¼ Section _____.
Property Dimensions: _____ ft. x _____ ft. Area: _____ acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 3-28 to 3-29-89. Weather: Precip. — Temp. 70.

5901 Saddle Creek Rd.
Terry Lynstrum

OWNER: T.M. Williams
5-321 50,51 2+
Address: ~~5901 S~~

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Water Level (in.)	Time (Hr./Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	32"	3-28	6:00pm	3-29	8:30	3-29	11:30	14 3/4	12:00	15 1/2	30	3/4"	
2	"							7 3/4		7 7/8		1/8"	
3	"							21 1/4		22 1/4		1"	
4	"							11 1/2		12 1/2		1"	
5	"							22		23 1/8		1 1/8"	
6	"							10 1/2		10 7/8		3/4"	

Larry Schwarck Trenching
Signature of Person Conducting Test

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

Address 8200 old Cheney Phone 489-7294

(Do not write below this line)

REVIEWING ACTION

Remarks: _____
Soil Type (SCS): Wymore Silty Clay Loam
Date: April 3, 1989

Approved Percolation Rate (a)
A. 40 min./inch
B. _____ min./inch
C. _____ min./inch

Jerrold C. Hood
Signature of Reviewing Official

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

D

DATE: _____

FILE NO. _____


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material SCH 160 ; Diameter 4 in.
2. Distance above basement floor _____ in., or below basement floor 14 in.
3. Distance between dwelling and septic tank 111' ft.
4. Number of clean-outs 1 .
5. Distances to:
Well or Suction Line - ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

B. SEPTIC TANK:
1. Material Pre Cast ; No. of compartments _____.
2. Capacity 1000 gals.;
3. Factory Built: Yes ☒ No ☐
(Company _____)
4. Manholes: Over Inlet; diam. _____ in.
Over Outlet; diam. _____ in.
Riser Above ☐ Below ☐ Grade ___ in.
5. Inlet: Baffle ☐ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☐
7. Depth of top of tank below finished grade 18" in.
8. Distances to:
Well or Suction Line _____ ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

C. DISTRIBUTION BOX:
1. Material Pre Cast ; Number - available outlets _____.
2. Factory Built: Yes ☒ No ☐
(Company _____)
3. Distance from Septic Tank 5' ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☐ Perforated Pipe ☒
Diameter of Half Round _____ or
Perforated Pipe 4" .
Material: fiberglass ☐ ; plastic ☒ ; concrete ☐ ; other _____.
2. Lateral Lines:
Number 3 ; Length of each line 80 , 100 , 100 , _____ , _____ ft.;
Total length of laterals 280 ft.;
Distance between lateral lines ___ ft.
3. Trench dimensions: Width 3 ft.;
Slope 4 in/100 ft.; Average Depth 28" in.
4. Filter Material: Road Gravel
Depth of Material 20" in.
5. Distances to:
Well or Suction Line - ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

AS BUILT DRAWING OF SYSTEM

DATE 4-6-89 INSTALLER L Schwenk

