LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 1001-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — [illegible]5, 1977

TYPE OF PERMIT — THIS PERMIT EXPIRES

Phillip G. Splichal — 3111 North 64 St., Lincoln, NE 68507

ISSUED TO — ADDRESS

T9N; R6E; Sec. 19, Bl. 3, Lot 2, Yankee Hill Lake Subdivision

LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ ~~$0~~.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

FRANK GOLDEN, Lancaster County Treasurer

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

Health

ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1001-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: Feb 7, 1977

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 6E ; Section 19
Block 3 ; Lot 2 ; Addition Yankee Hill Lake Subdivision
Street Address 4801 Deer Crest Dr

2. Property Use: Residential ☒ ; Commercial ☐
No. of Bedrooms 3. Describe:
Other Use ☐
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft.

2/15/77 no easement needed

Phillip G Splichal
Signature of Applicant (Owner or Lessee)

3111 N 64 St
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 2/15/77. Date Frwd. 2/15/77. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold E. Hood

2. Supt. Bldg. Insp.: Date Rec'd. _____. Date Frwd. _____. ACTION: Approved ☐ Disapproved ☐ Signature:

3. City or County Engineer: Date Rec'd. 2/15/77. Date Frwd. 2/15/77. ACTION: Approved ☒ Disapproved ☐ Signature: Henry Graff

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1001-C

DATE: Feb 8, 1977

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 9N ; Range 6E ; Section 19 ; Block 3 ; Lot 2 ; Addition Yankee Hill Subdivision
Street Address _____.

2. Property Use: Residential _____ ☒ Commercial _____ ☐
No. of Bedrooms 3 Describe: _____
Other Use _____
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ Other ☐

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Phillip G Sokol
Signature of Applicant (owner or lessee)

311 N 64 st
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd; _____
Filing Fee: $ 30.00

2. Site Visits:
Date: 6-17-77 by: jw
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒ ; Disapproved ☐ 2/15/77
by: Jerrold C. Hood 4/7/77

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 6-17-77 by: James Weverka

FORM HD-43 (73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 474-1541)

FILE NO. 1001-C

PROPERTY WHERE SOIL TESTED:
Location: Township 9N : Range 6E
Section & ¼ Sect. 19
Property Dimensions: 260 ft. x 508 ft. X 390 X 345
Area: 3½ acres. (Attach sketch of property showing hole location).
Owner: Phil Splechal
Address: 3111 N 64
Soil Type: Silty Clay ; Silty Clay Loam X ; Sandy Loam
Silty Loam ; Clay Loam X ; Sandy Clay
Dates of Tests: Feb 6 to Feb 7. Weather: Precip. 0 Temp. 32°

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	36"	2/6	12:00	2/7	12:00 pm	2/7	12:00	36"	4:00 pm	1	30 mm	1 1/8"	
2										3		1/2"	
3										1 1/2		1 1/2	
4										2 1/2		3/4	
5										4 1/2		1/4	
6										2		3/4	

Signature of Person Conducting Test: Phillip G Splechal
Address: 3111 N 64
Phone: 464-0920

Sum of Percolation Rates:
Average of Rates:
Mean of Rates:

(Do not write below this line)

REVIEWING ACTION

REMARKS:

DATE: February 14, 1977

Approved Percolation Rate (a)
A. 37 min./inch
B. _____ min./inch
C. _____ min./inch

Signature of Reviewing Official: Jerrold C. Hood

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1001-C

SPECIFICATIONS

DATE: Feb 7, 1977


A. BUILDING SEWER:
1. Material Soil Pipe; Diameter 4 in.
2. Distance above basement floor ___ in.; or below basement floor 40 in.
3. Distance between dwelling and septic tank 50 ft.
4. Number of clean-outs None.
5. Distances To:
Well or Suction Line 100 ft.;
Stream None ft.; Pressure Line None ft.;
Property Line 130 ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Fibre; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth ___ in.
3. Factory Built: Yes ☒ (Company ___) No ☐
4. Manholes: Over Inlet; diam. ___ in.
Over Outlet; diam. ___ in.
Below Grade 48 in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☐
Depth of outlet below inlet 8 in.
7. Depth of top of tank below finished grade 48 in.
8. Distances To:
Well or Suction Line 150 ft.;
Stream None ft.; Pressure Line ___ ft.;
Property Line 130 ft.

C. DISTRICTION BOX
1. Material Concrete; No. available outlets 5.
2. Factory Built: Yes ☒, (Company Pre Cast) No ☐
3. Dimension: Length ___ in.; Width ___ in. Depth ___ in.
4. Distance from Septic Tank 10 ft.
5. Serial Distribution: Yes ☒, No ☐ (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: Trench & Laterals
2. Lateral Lines: Depth below grade 20 in. Number 3; Length of each line 100 ft Total length of Laterals 300 ft.; Slope 24 in/100 ft. Diameter of pipe ___ in.; Shape ½ moon Material: concrete ☐; fiber asbestos ☐; clay ☐; other ___ Distance between lateral lines 10 ft.
3. Trench Dimensions: Depth 72 in.; Width 36 in.
4. Filter Material: Gravel. Depth of material from trench bottom 24 in.
5. Distances To:
Well or Suction Line 170 ft.;
Stream None ft.; Pressure Line ___ ft.
Property Line 130+ ft.
6. Percolation Rate: ___ minutes/inch

TYPICAL SKETCHES



Signature of Applicant

Oscilla Hurst
June 17, 77

