FILE NO. 1867

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

OCTOBER 22, 1982 — THIS LICENSE OR PERMIT EXPIRES

AMERICAN CHARTER BOX 2521 LINCOLN NE 68502 — LICENSEE OR PERMITTEE / ADDRESS

T9N, R6E, SECTION 21, BLOCK 5, LOT 1, ADDITION: RIDGE WOOD ADDITION — NAME OF ESTABLISHMENT, IF ANY / ADDRESS

REMARKS: NONTRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 60.00	$	$	$	$ 60.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
018754	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT
60329	10-22-82	60.00

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

HEALTH APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $ 60.00

FILE NO. 1867

DATE: 4-20-82

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 6E ; Section 21 ;
   Block 5 : Lot 1 : Addition RIDGE WOOD ADDITION
   Street Address # 2001 FOOTHILLS DRIVE

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 4 . Describe

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: N/A ft.

American Construction by Donald R Cantico
Signature of Applicant (Owner or Lessee)

P.O. Box 2521 LINCOLN, NE.
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 4/22/82. Date Frwd. 4/22/82. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold E. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 4-22-82. Date Frwd. 4-22-82. ACTION: Approved ☒ Disapproved ☐ Signature: Paul Bowne

3. City ~~or County~~ Engineer : Date Rec'd. 4-22-82 Date Frwd. 4-22-82 ACTION: Approved ☒ Disapproved ☐ Signature: [illegible]

REMARKS OR REASONS FOR DISAPPROVAL

Site Visits:
Date: 6-25-82 by: JMN
Date: by:
Date: by:

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

INSTALLATION FINAL WRITTEN APPROVAL
Date: 9-23-82 By: John Olson

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

B

FILE NO. _____

PROPERTY WHERE SOIL TESTED: #2001 FOOTHILLS DRIVE

Location: Township _____; Range _____; Section & ¼ Section _____.
Property Dimensions: _____ ft. x _____ ft. Area: _____ acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 4-14-82 to 4-15-82. Weather: Precip. dry Temp. 70°.

OWNER: American Charter c/o Pottyco Inc
Address: P.O. Box 2521 LINCOLN NE 68502

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	36"	4-14	11:00	4-15	9:00	4-15	2:15	27	2:45	27½	30	½	
2	36"						2:15	24	2:45	24⅝	30	⅝	
3	34"						2:18	23¼	2:48	23⅞	30	⅝	
4	35"						2:20	21½	2:50	22¼	30	¾	
5	35"						2:22	26⅜	2:52	27⅛	30	¾	
6	36"						2:25	26	2:55	26⅞	30	⅞	

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

Pottyco Inc. by Donald Rientjes
Signature of Person Conducting Test
Address P.O. Box 2521 LINCOLN NE 68502 Phone 423-0121
(Do not write below this line)

REVIEWING ACTION

Remarks: _____
Soil Type (SCS): Sharpsburg Silty Clay Loam
Date: April 22, 1982

Approved Percolation Rate (a)
A. 44 min./inch
B. _____ min./inch
C. _____ min./inch

Jerrold C. Wood
Signature of Reviewing Official

FORM 20102-0477
PRELIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐


LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

C

Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.

FILE NO. _____

Indicate on sketch if residence and well are exisiting or proposed.



REVIEWING ACTION

Remarks: _____

Date: april 22, 1982

Minimum Design Requirement
1. Capacity of Septic Tank 1250 gals.
2. Total Length of Laterals 397 ft.
3. With a Trench Width of 48 in.
4. Total Area of Lateral needed 1191 sq.ft.

Jerrold C. Hood
Signature of Reviewing Official

Larry Schwarck
For Pattyco Plbg.

sewer line & Tank had been previously installed

Larry will cut 8" hole and eftend a riser over it. will scarf off some top soil so that riser will be within 8" of surface.

mak. depth of trench (anyone) 4'

