FILE #2641

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

SEPTEMBER 22, 1988 — THIS LICENSE OR PERMIT EXPIRES

TERRY STENTZ BY ERNEST PUMP CO. 1629 HARWOOD LINCOLN, NE 68502

LICENSEE OR PERMITTEE — ADDRESS

T9N; R6E; Sec SW¼ 21; Blk 7; Lot 5; Ridgewood Addition

NAME OF ESTABLISHMENT, IF ANY — ADDRESS

REMARKS: NON TRANSFERABLE NEW CONSTRUCTION

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 60.00	018754	$ 60.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. Date and Amount

APPLICATION

HEALTH

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

A

FILING FEE: $60.00

FILE NO. 2641

DATE: _____

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 6E ; Section SW¼ 21; Block 7 : Lot 5 : Addition Ridgewood Add
   Street Address _____

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft. 2 miles

1629 Harwood
Lincoln (02)
for Terry 474-1826
Stentz 470-2468

Glenn B Earnest
Signature of Applicant (Owner or Lessee)

400 2nd St, Box H
Address
Milford, NE 68405
☎ 761-2281

(Do not write below this double line)

1. Health Department: Date Rec'd. 3/21/88. Date Frwd. 3/21/88. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 3-21-88. Date Frwd. 3-21-88. ACTION: Approved ☒ Disapproved ☐ Signature: Paul Boeme

3. City or County Engineer: Date Rec'd. 3-21-88. Date Frwd. 3-21-88. ACTION: Approved ☒ Disapproved ☐ Signature: Dennis Bartels

REMARKS OR REASONS FOR DISAPPROVAL WELL PERMIT RECIEVED.

Site Visits:
Date: _____ by: J.C.H.
Date: June 88 by: [illegible]
Date: _____ by: _____

INSTALLATION FINAL WRITTEN APPROVAL *
Date: 7/5/88 By: J.C. Hood

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

* PROVISIONAL APPROVAL
EXPERIMENTAL SYSTEM

FORM 23-43

AM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: ~~471-7800~~ 471-8000

B

FILE NO. 2641

Ridgewood Estates

PROPERTY WHERE SOIL TESTED:

Location: Township 9N ; Range 6E ; Section & ¼ Section 21 SW/4
Property Dimensions: _____ ft. x _____ ft. Area: _____ acres. (Attach Sheet C with sketch of property).
SHC or WT03
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 2-29- to 3-1-88 . Weather: Precip. 0 Temp. 30's .

OWNER: Terry Stentz

Address: 1629 Harwood 68502

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Water Level (in.)	Time (Hr./Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	36	2/29	8:00	3/1	8:00	3/1	11:50	24	12:20	24 3/8	30	3/8	
2			AM		AM			20 3/4		21 1/8		3/8	
3								20 1/8		20 7/8		3/4	
4								23 1/8		23 5/8		1/2	
5								19 3/8		19 1/2		1/8	
6								17 1/2		18		1/2	
7								16 5/8		17 1/4		5/8	
												3.25	

Sum of Percolation Rates: 3.25
Average of Rates: .46
Mean of Rates: _____

Brad Southwick
Signature of Person Conducting Test

Address 701 E 4 Hickman Phone 792-2462

65 min/in

(Do not write below this line)

REVIEWING ACTION

Approved Percolation Rate (a)
A. _____ min./inch
B. _____ min./inch
C. _____ min./inch

Remarks: TOO SLOW FOR CONVENTIONAL SEPTIC SYSTEM

Soil Type (SCS): _____

Date: MARCH 21, 1988

Jerrold C. Hood
Signature of Reviewing Official

2000 As Built
W. Dunraven Lane - Terry Stentz

West
N

