002

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 F

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

REAL ESTATE TRANSFER/LOAN API

This form must be completed and returned to request a [illegible] transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☐ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 8201 S. 14 Rt. 1

Twp 9 Range 6 Section 23 1/4 1/4 Block Lot Addition ACACIA E

Directions to Property LOT 37 I.T. EXC NO 150' SEC 23-9-6

Location of Well North of Metal Building Tap Location: Inside ☒ Outside ☐

Location of Sewage System tank North of house / Leach field South Year Installed Updated '92 Southwick Sewer Hickman, NE

	NAME	ADDRESS	PHONE
Present Owner:	Wally Schroeder	3310 Scottsdale Lincoln, NE 68516	421-1338
Tenant/Buyer:	Alan Schroeder	4022 C Lincoln, NE 68510	4835646
Return to:			

Signature of Applicant Alan Schroeder Address 4022 C Lincoln, NE 68510 Date 11/10/95

HEALTH DEPARTMENT USE ONLY

Date Received 11/13/95 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By John Chess **DATE:** 11/13/95

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM	Additional Site Visits
Construction	☒	☐	Approved ☐	Date 11/14 by JC
Bacteria	☒ 0 /ml	☐ /ml	Provisional ☒	Date / / by
Nitrate	☒ .3 ppm	☐ ppm	Disapproved ☐	Date / / by

Comments: To best protect the integrity of the well, No Animals (Livestock) within 100ft. No evidence of surface discharge; inspected area with current owner. It is not recommended that animals (livestock) horses be corraled over lateral system. If the tank has not been pumped in the last several years, it should be checked to see if it is needed. No current information found on existing system, therefore provisional approval. ☐ See Attached Letter.

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☐ Provisional Approval: ☒

Approved by John J Chess REHS Date 11/15/95

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.