FILE NO. 1318

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

November 16, 1978 — THIS LICENSE OR PERMIT EXPIRES

Keith Wunderlich — LICENSEE OR PERMITTEE

Route 7, Lincoln, NE 68502 — ADDRESS

T9N, R6E, Section 23 — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
110.15	110.16	148.14	6-2

624-1535

SERIAL NO.	DATE	AMOUNT

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION
HEALTH

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1318

DATE: 13 Aug 77

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 9 N ; Range 6 E ; Section 23 ; Block ; Lot ; Addition .
Street Address Rt 1 Lincoln Ne .

2. Property Use: Residential [X]; Commercial [ ]
No. of Bedrooms 3
Other Use
Describe:

Describe:

3. Type of Individual Sewage Disposal System: Septic Tank [ ]; Other [X]

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Keith Schneider
Signature of Applicant (owner or lessee)

Rt 7 Lincoln Ne
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd;
Filing Fee: $ 30.00

2. Site Visits:
Date: by:
Date: by:
Date: 9/1/78 by: J.C.H

3. Date: Approved [X]; Disapproved [ ]
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 2/18/98 by: Jerrold C. Hood

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1318

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 13 Aug 77

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein: SEE ATTACHED

1. Legal description of property: Twp. 9N ; Range 6E ; Section 23
Block ____; Lot ____; Addition ____
Street Address RT 1 Lincoln Ne

2. Property Use: Residential ____ ☒ ; Commercial ____ ☐
No. of Bedrooms 3 . Describe: ____
Other Use ____ ☐
Describe: ____

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒

4. Distance to public sewer: None ft.

Keith Wunderlich
Signature of Applicant (Owner or Lessee)

Rt 7 Lincoln Ne
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 5/16/78 . Date Frwd. 5/16/78 . ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hoof

2. Supt. Bldg. Insp.: Date Rec'd. 5/16/78 . Date Frwd. 5/16/78 . ACTION: Approved ☒ Disapproved ☐ Signature: Gary N. Henwood

3. City or County Engineer : Date Rec'd. 5/16/78 . Date Frwd. 5/16/78 . ACTION: Approved ☒ Disapproved ☐ Signature: Dennis Bartels

REMARKS OR REASONS FOR DISAPPROVAL Need Drawing

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-43 (73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 474-1541)

FILE NO. 1318

PROPERTY WHERE SOIL TESTED:
Location: Township 9N : Range 6E
Section & ¼ Sect. 23
Property Dimensions: 384 ft. x 340.5 ft.
Area: 3 acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ; Silty Clay Loam ; Sandy Loam
Silty Loam ; Clay Loam ; Sandy Clay

Owner: Keith Wunderlich
Address: Rt 7 Lincoln Ne

Dates of Tests: 12 Aug 77 to 13 Aug 77. Weather: Precip. None Temp. 80°

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Dat (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	36	8-12	10:50	8-13	10:15	8-13	10:25	6"	10:57	6"	32	0	
2	36	8-12	10:54	8-13	10:15	8-13	10:27	6"	10:54	5 3/4"	31	1/4"	
3	36	8-12	10:58	8-13	10:15	8-13	10:29	6"	10:59	5 5/8"	30	3/8"	
4	36	8-12	11:01	8-13	10:15	8-13	10:30	6"	11:01	5 3/4"	30	1/4"	
5	36	8-12	11:04	8-13	10:15	8-13	10:33	6"	11:02	5 5/8"	29	5/8"	
6	36	8-12	11:10	8-13	10:15	8-13	10:35	6"	11:04	5 3/4"	29	1/4	

Sum of Percolation Rates: 1.75
Average of Rates: 0.29167
Mean of Rates:

Keith Wunderlich
Signature of Person Conducting Test

Address Rt 7 Lincoln, Ne
Phone 474-0482

(Do not write below this line)

REVIEWING ACTION

REMARKS: Wt C - Wymore silty clay loam


DATE: 3-17-78

Approved Percolation Rate (a)
A. 96 min./inch
B. _____ min./inch
C. _____ min./inch

James Wunderlich
Signature of Reviewing Official

Scale $\frac{1}{8}$" = 5' Keith Wunderlich
Rt 7 Lincoln Vt


Approx. 340.5'



Keith Wunderlich
Rt 1 Lincoln Ne 68512

FEB 1 7 1998

Sewage Permit #1318



N