LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 1011-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

September 15, 1977 — THIS PERMIT EXPIRES

Richard Egger, Sprague, Nebraska 68356 — ISSUED TO / ADDRESS

T9N, R [illegible] of 6 P.M., Section 8.6[illegible]6 ft. of [illegible]28[illegible] of SW¼ of Sec. 30 — LEGAL DESCRIPTION

CLOSED

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

Health — ISSUING OFFICER

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

2832

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. _____

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1011-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 3-11-77

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9 N ; Range 6 East of 6 P.M.; Section S. 656 ft of W 383 of S.W. 1/4 of Sec. 30
Block ____; Lot ____; Addition ____
Street Address ____

2. Property Use: Residential ____ ☒ ; Commercial ____ ☐
No. of Bedrooms 3.
Describe: ____
Other Use ____ ☐
Describe: ____

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒ Lagone

4. Distance to public sewer: None ft.

Easement signed Rec'd 3/14/77 Akerman

Richard Egger
Signature of Applicant (Owner or Lessee)

Sprague Nebr.
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 3/15/77. Date Frwd. 3/15/77. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. ____. Date Frwd. ____. ACTION: Approved ☐ Disapproved ☐ Signature: ____

3. City or County Engineer: Date Rec'd. 3/15/77. Date Frwd. 3/15/77. ACTION: Approved ☐ Disapproved ☒ Signature: Henry Graff
Rec'd 3/15/77 Kubes

REMARKS OR REASONS FOR DISAPPROVAL ____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐

County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1011-C

DATE: 3-11-77

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 9 N ; Range N.6 E of 6 P.M. ; Section 5, 656 ft. of W383 of SW 1/4 of Sec 30 ; Block ; Lot ; Addition ; Street Address .

2. Property Use: Residential ☒ Commercial ☐
   No. of Bedrooms 3 Describe:
   Other Use
   Describe:

3. Type of Individual Sewage Disposal System: Septic Tank ☐; Other ☒ Lagone

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Richard Eggen
Signature of Applicant (owner or lessee)

Sprague Nebr.
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd;
   Filing Fee: $ 30.00

2. Site Visits:
   Date: 6-23-77 by: jw
   Date: by:
   Date: by:

3. Date: Approved ☒; Disapproved ☐ 3/15/77
   by: Carroll E. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
   Date: 6-23-77 by: James Wiewiora

FORM HD-43 (73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 474-1541)

FILE NO. 1011-C

PROPERTY WHERE SOIL TESTED:
Owner: Richard Egger
Location: Township 9 : Range N.6 E. of 6 PM
Section & 1/4 Sect. S. 656 ft of W 383 ft of SW 1/4 of Sec. 30
Address: Sprague Nebr.
Property Dimensions: ____ ft. x ____ ft.
Area: ____ acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ; Silty Clay Loam ; Sandy Loam
Silty Loam ; Clay Loam ; Sandy Clay

Dates of Tests: 3-11-77 to 3-12-77. Weather: Precip. ____ Temp. ____

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	60	3-11	10:00	3-12	1:00	3-12	1:00	30	2:00	29 1/2	60	1/2	60/ 1/2
2	60	3-11	10:00	3-12	1:00	3-12	1:00	30	2:00	29	60	1	60/1

Terry Bouma
Signature of Person Conducting Test
Address Firth, Nebr.
Phone 791-5760 - 791-5730

Sum of Percolation Rates: 1 1/2 in
Average of Rates: 3/4 in
Mean of Rates: 60 min / 3/4 in

(Do not write below this line)

REVIEWING ACTION

REMARKS: Soils map indicates mostly Wymore silty clay loam with some Pawnee silty clay loam in area.

DATE: March 15, 1977


Approved Percolation Rate (a)
A. ____ min./inch
B. ____ min./inch
C. ____ min./inch

Jerrold C. Hood
Signature of Reviewing Official

5500 West
Rocaby Rd.

N

New Crestline 4"
sealed plastic line
(sewer)



Bouma trenching
Firth Nebr.
Terry Davison