Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

FOR PROPERTY IN **LANCASTER COUNTY** ONLY

This form must be completed and returned with payment to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: "Lincoln-Lancaster County Health Department" or "LLCHD"

☐ Enclosed is $200.00. Allow two weeks for processing. Incomplete information will delay processing.

Legal Description of Property: Street Address 10910 SW 27th St Lincoln NE 68523

Parcel ID ____-____-____-____-____ (i.e. 99-99-999-999-999)

Twp 9 Range 6 Section 33 1/4 ___ 1/4 ___ Block ___ Lot 20 Addition ___

Directions to Property ___

Location of Well Front Yard Tap Location: Inside ☐ Outside ☑

Location of Sewage System Septic Year Installed ___

Site Hazards (dogs, etc.) ___

	NAME	ADDRESS	PHONE
Present Owner:	Richard Cottrell	Same	440-0528
Tenant/Buyer:			
Return to:	Wells Fargo Attn: Kerri Gattie Grommet	1248 'O' 68508	434-4406 434-4818 (Fax)

Signature of Applicant ___ Address Same Date 10/17/05

HEALTH DEPARTMENT USE ONLY

RECEIVED Date 10/17/05 Amount 200.00 Check No. CASH Initials ___

DATA ENTRY Date ___/___/___ Case No. ___ Initials ___

PRELIMINARY STATUS--By Doug Smith **DATE:** 10/19/05

WATER SYSTEM:	Approved	Disapproved
Construction	☑	☐
Bacteria	☑ ___/ml	☐ ___/ml
Nitrate	☑ .07 ppm	☐ ___ppm

SEWAGE SYSTEM	
Approved	☑
Provisional	☐
Disapproved	☐

Additional Site Visits

Date ___/___/___ by ___

Date ___/___/___ by ___

Date ___/___/___ by ___

Comments: - No visible malfunctions noted
- Well appears to meet construction standards
- Water sample indicates supply meets standards for safe drinking water

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved ☑ **SEWAGE DISPOSAL SYSTEM:** Approved ☑ Provisional Approval ☐

Approved by Doug Smith Date 10/20/05

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

White - Applicant after approval Yellow - Environmental Health Pink - Business Office

Revised/Reprint: 9-00