RECEIVED APR 16 1991

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

LINCOLN-LANCASTER COUNTY HEAL ENT

2200 St Marys Avenue Phone (402) 471-7800 Linc.

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer insp.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 4-15-91

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is ~~$75.00~~ $150.00

Legal Description of Property: TWP. 9N; RANGE 7E; SECTION SE¼ of 9; BLOCK ___

LOT 127; ADDITION _____; Street Address 6700 Old Cheney Road

Directions to Property contact owner. Call Kathi at home (421-1497) or at work (483-7688)

Location of Well contact owner Tap Location: Inside ☐ Outside ☐

Location of Sewage System contact owner Year Installed ____

	NAME	ADDRESS	PHONE
Present Owner:	Scott & Kathi Krause	6700 Old Cheney Road	421-1497
Tenant/Buyer:			
Return to:	Security Federal Savings	PO Box 80609, Lincoln 68501	474-4444

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Rhonda Davis (consultant for SFS) Address _____

==========

HEALTH DEPARTMENT USE ONLY $150.00

Date Received APRIL 16, 1991 Received ~~$75.00~~ Check ☐ Cash ☐

PRELIMINARY STATUS--DATE APRIL 17, 1991

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☐	☒	Approved:	☐	Date 4/17/91 by J.C.H.
Bacteria	☒	☐	Provisional:	☒	Date 5/3/91 by J.C.H.
Nitrate	☒	☐	Disapproved:	☐	Date _____ by ___

Comments: DEPRESSION AROUND WELL. SEPTIC TANK MAY NEED PUMPING. SHOULD PUT SOME DIRT OVER SEPTIC LATERALS SO WATER WILL NOT STAND ON THEM. THEY ARE KIND OF SUNKEN IN SOME PLACES. See Attached Letter ☐

FINAL STATUS Well and laterals corrected 5/3/91 J.C.H. Septic system predates Regulations so approval is provisional. No evidence of malfunction

WATER SYSTEM:		SEWAGE DISPOSAL SYSTEM:		
Approved:	☒	Approved:	☐	Provisional Approval: ☒

APPROVED BY Jerrold C. Hood DATE MAY 9, 1991

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832