ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

Lincoln-Lancaster County He

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☒ Evaluation of the Individual Water System ☒ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 6600 PHEASANT RUN PLACE, LINCOLN, NE. 68516

Twp 9N Range 7E Section 9 1/4 SE 1/4 Block ____ Lot 134 Addition ____

Directions to Property 66TH & Old Cheney

Location of Well North East Side House Tap Location: Inside ☐ Outside ☐ 6/25/56

Location of Sewage System UNKNOWN Year Installed UNKNOWN

	NAME	ADDRESS	PHONE
Present Owner:	WALT ESTATE C/O MARY WALT WALKER, PR.	9279 HYLAND CREEK RD. BLOOMINGTON, MN. 55437	
Tenant/Buyer:	ROBERT & MERILYN LOCKWOOD	16 FIRETHORN CT. LINCOLN, NE. 68520	483-4514
Return to:	D. RESPESS NEBRASKA TITLE CO. FAX: 486-4949	BX 5635 O STREET #101 LINCOLN, NE. 68510	486-4900

Signature of Applicant [signature] Address 16 FIRETHORN CT. LINCOLN, NE. 68520 Date 11/16/94

HEALTH DEPARTMENT USE ONLY

Date Received 11/17/94 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By Jerrold C. Hood **DATE:** 11/21/94

WATER SYSTEM:	Approved	Disapproved	**SEWAGE SYSTEM**	**Additional Site Visits**
Construction	☒	☐	Approved ☐	Date ___/___/___ by ___
Bacteria	☒ ___/ml	☐ ___/ml	Provisional ☒	Date ___/___/___ by ___
Nitrate	☒ 1.0 ppm	☐ ___ppm	Disapproved ☐	Date ___/___/___ by ___

Comments: THE SEPTIC SYSTEM PREDATES REGULATIONS HENCE APPROVAL IS PROVISIONAL.

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☐ Provisional Approval: ☒

Approved by Jerrold C. Hood R.E.H.S. Date 11/28/94

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.