FILE NO. 200

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

December 28, 1971 — THIS LICENSE OR PERMIT EXPIRES

Harold Fritz — LICENSEE OR PERMITTEE

4420 Pagoda Lane — ADDRESS

T9N; Range 7E; Section 10; Block 1; Lot 9; Mar-Ma-Ra-Lo Heights (Extend) — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: Non-Transferable

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
110.15	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT
624 1535		

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-31(67) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 200

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 6-28-71

The undersigned hereby applies for a permit to ALTER ☐, EXTEND ☒, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with Lincoln City Ordinance No. 9150, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 9N; Range 7E; Section 10;
Block 1; Lot 9; Addition MAR-MA-RA-LO HEIGHTS
Street Address 4420 Pagoda Za

2. Property Use: Residential ✓ ☒3; Commercial ☐
No. Bedrooms 3 Describe
Other Use ☐
Describe

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: Box & 100' Lateral

5. Work to be done by: Owner ☐; or Contractor ☒, SINTEK SERVICE
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$ 285	00

Harold Pirtz
Signature of Applicant (owner or lessee)

4420 Pagoda Za.
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd:
Filing Fee: $ 30.00

2. Date Site Clearance:

3. Site Visits:
Date: by: J.C.H.
Date: by:
Date: by:

4. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Hood

5. BUREAU OF LICENSES & PERMITS
Date Notified:
Date Issued: Serial

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 6/28/71 by: J.C.H.

REC'D MAY 13 1971

FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. _____

PROPERTY WHERE SOIL TESTED:
Location: Township _____
Section & ¼ Sect. _____
Property Dimensions: ____ft. x ____ ft.
Area: _____acres. (Attach sketch of property showing hole location).

Owner: Harold W Pritz
Address 4420 Pagoda Ln

Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☒; Sandy Clay ☐

Dates of Tests: 5-10-71 to 5-11-71. Weather: Precip. NO Temp. 70 F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	32	5-10	6P	5-10	10P	5-11	3:45	6	4:15	5¼	30	¾	60 - 1½
2	32	5-10	6P	5-10	10P	5-11	3:45	6	4:15	5⅜	30	5/8	60 - 1⅛

Sum of Percolation Rates 2 7/8
Average of Rates: 66 - 1 3/4
Mean of Rates: 44 - 1

Santee Pumping Inc
Signature of Person Conducting Test

Address 3800 NO 27
Phone: 4349393

(Do not write below this line) 300-Per


REVIEWING ACTION


REMARKS: _____

DATE: _____

Approved Percolation Rate(s)
A. 44 min./inch
B. _____ min./inch
C. _____ min./inch

Gerrold C Hood
Signature of Reviewing Official


N
S
E
W


HOUSE
31'
6'
90'
EXISTING LINE
42'
21'
PROPERTY LINE
56'
20'
20'
PROPERTY LINE