CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

FILE # 1364

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

January 12, 1979 — THIS LICENSE OR PERMIT EXPIRES

Larry Felton — LICENSEE OR PERMITTEE

4500 Pagoda Lane, Lincoln, NE — ADDRESS

T9N; R7E; Sect. 10; Block 1; Lot 7; MAR-MA-RA-LO Heights — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NONTRANSFERABLE (Extend and REPAIR)

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 15.00	$	$	$	$ 15.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
110.15	110.16	148.14	6-2

624-1535

SERIAL NO.	DATE	AMOUNT

APPLICATION

Health

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1364

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: July 11 - 78

The undersigned hereby applies for a permit to ALTER [ ], EXTEND [✓], or REPAIR [✓] an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. ~~9~~ 7N; Range 7E; Section ~~2~~ 10;
Block 1; Lot 7; Addition MAR-MA-RA-LO HEIGHTS
Street Address 4500 Pagoda Lane.

2. Property Use: Residential [✓]; Commercial [ ]
No. Bedrooms 3 Describe
Other Use [ ]
Describe

3. Type of existing Individual Sewage Disposal System: Septic Tank [✓]; Other [ ]

4. Description of proposed alteration, extension or repair: Extend Drain Field.

5. Work to be done by: Owner [ ]; or Contractor [✓], Jay Felton
Contractor's Name

6. Estimated cost of project: over

a. Materials	$	200.00
b. Labor	$	
c. Other	$	
TOTAL	$	

A. E. Dultzbaugh
Signature of Applicant (owner or lessee)

4500 Pagoda Lane
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd:
Filing Fee: $ 15.00


2. Site Visits:
Date: 7-20-78 by: dm *
Date: by:
Date: by:

3. Date: Approved [X]; Disapproved [ ]
by: Jerrold E. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 7-21-78 by: [illegible] **

* 25-30' is too close to neighbors well.
** Installer agreed to remove last 25-30' of lateral.

neighbors
Lowell



008

Lincoln-Lancaster County Health Department

2200 St. Mary's Avenue, Lincoln, Nebraska 68502 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☑ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☑ Evaluation of the Individual Water System ☑ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 4500 Pagoda La

Twp 9N Range 7E Section 10 1/4 ____ 1/4 ____ Block 1 Lot 7 Addition Mar-Ma-Ra-lo Heights LLCN

Directions to Property _____

Location of Well Between House & Drive just west of front door under planter. Tap Location: Inside ☐ Outside ☑

Location of Sewage System East of House under flower pot Year Installed 1971

Lift station East of flower pot under concrete pad.

	NAME	ADDRESS	PHONE
Present Owner:	Alvae+Anna Sultzbaugh	4500 Pagoda La Lincoln NE.	488-1264
Tenant/Buyer:	Jeffrey+Anica Brown	8211 Prescott Ave Lincoln NE. 68506	489-9441
Return to:	Jeffrey Brown	8211 Prescott Ave Lincoln NE 68506	489-9441

Signature of Applicant Jeffrey L Brown Address 8211 Prescott Ave Lincoln NE. 68506 Date 5/16/94

HEALTH DEPARTMENT USE ONLY

Date Received 5/18/94 Received $150.00 Check ☑ Cash ☐

PRELIMINARY STATUS--By Jerold C. Hood **DATE:** 5/19/94

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM	Additional Site Visits
Construction	☒	☐	Approved ☒	Date 5/20/94 by J.C.H.
Bacteria	☒ 0 /ml	☐ ____ /ml	Provisional ☐	Date ___/___/___ by ____
Nitrate	☒ 5.9 ppm	☐ ____ ppm	Disapproved ☐	Date ___/___/___ by ____

Comments: CAN NOT LIFT PLANTER OFF OF WELL. J.C.H. 5/20/94
IF THE SEPTIC TANK HAS NOT BEEN PUMPED RECENTLY IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☒ Provisional Approval: ☐

Approved by Jerold C. Hood R.E.H.S. Date 5/23/94

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.