9807220015
JUL 6 1998

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☐ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

CR 3708

Legal Description of Property: Street Address 8501 Kathy Ln. Villa Del Rey

Twp 9N Range 7E Section 11 1/4 ___ 1/4 ___ Block 3 Lot 4 Addition

Directions to Property ___

Location of Well See enclosure Tap Location: Inside ☐ Outside ☐

Location of Sewage System ___ Year Installed ___

ACR 69573.

CR 30241

	NAME	ADDRESS	PHONE
Present Owner:	Mr. + Mrs Metz	8501 Kathy Ln. Lincoln 68526-1009	489-2929
Tenant/Buyer:			
Return to:	Darcie Prellwitz Woods Bros.	3201 Pioneer Lincoln NE	434-3600 430-3244

Signature of Applicant Darcie Prellwitz Address ↑ Date 7/2/98

HEALTH DEPARTMENT USE ONLY

Date Received 7/6/98 Received $150.00 Check ☒ Cash ☐ #5510

PRELIMINARY STATUS--By Paul Drotzmann **DATE:** 7/8/98

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM	Additional Site Visits
Construction	☐	☒	Approved ☐	Date 7/16/98 by PD
Bacteria	☒ 0 /ml	☐ ___ /ml	Provisional ☐	Date 7/17/98 by PD
Nitrate	☒ 0.4 ppm	☐ ___ ppm	Disapproved ☐	Date ___/___/___ by ___

Comments: Small depression around well, Electrical conduit needs to be sealed. Nitrate sample collected 7-16-98 Depression filled. Elc conduit not repaired 7-17-98 well repaired, sample collected

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☒ Community System

Provisional Approval: ☐

Approved by Paul Drotzmann Date 7/21/98

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.