95 062616

# Lincoln-Lancaster County H[illegible] Department

3140 "N" Street, Lincoln, Nebraska 68[illegible]

**REAL ESTATE TRANSFER/LOAN**

**ORIGINAL LOAN APPROVAL FILE**
**PREVIOUS HISTORY UNKNOWN**

This form must be completed and returned to request a real estate transfer inspection.

**MAKE CHECK PAYABLE TO:** Lincoln-Lancaster County Health Department or LLCHD

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☒ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 11600 Middle Fork Rd

Twp 9N Range 7E Section 13 1/4 ___ 1/4 ___ Block ___ Lot ___ Addition ___

Directions to Property Yankee Hill Rd to 115th. Go North and take Middle Fork branch to right. 2nd lane on left.

Location of Well in front of house by cedar tree Tap Location: Inside ☐ Outside ☒

Location of Sewage System ___ Year Installed ___

| | NAME | ADDRESS | PHONE |
|---|---|---|---|
| Present Owner: | Steven D Burns | 11600 Middle Fork Rd Lincoln NE 68526 | 474-1513 Day 488-7772 Home |
| Tenant/Buyer: | | | |
| Return to: | (Same) | | |

Signature of Applicant [signature] Address 11600 Middle Fork Lincoln NE 68526 Date 6 / 8 / 95

## HEALTH DEPARTMENT USE ONLY

Date Received 6 / 8 / 95 Received $150.00 Check ☒ Cash ☐

**PRELIMINARY STATUS--By** Jerrold C. Hood **DATE:** 6 / 8 / 95

| **WATER SYSTEM:** | Approved | Disapproved |
|---|---|---|
| Construction | ☐ | ☒ |
| Bacteria | ☒ 0 /ml | ☐ ___ /ml |
| Nitrate | ☒ 0.1 ppm | ☐ ___ ppm |

**SEWAGE SYSTEM**
Approved ☒
Provisional ☐
Disapproved ☐

**Additional Site Visits**
Date 6 / 15 / 95 by L.C.H.
Date ___ / ___ / ___ by ___
Date ___ / ___ / ___ by ___

**Comments:** DEPRESSIONS AROUND WELL. Corrected 6/16/95 L.C.H.

See Attached Letter ☐

**FINAL STATUS**

**WATER SYSTEM:** Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☒ Provisional Approval: ☐

Approved by Jerrold C. Hood R.E.H.S. Date 6 / 16 / 95

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.