CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

FILE NO. 1894

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

December 29, 1982 — THIS LICENSE OR PERMIT EXPIRES

John Sampson — LICENSEE OR PERMITTEE

5625 L Street, Lincoln, NE 68510 — ADDRESS

T9N; R7E; Section 15, Block 2; Lot 1; Stevens Ridge Estates — NAME OF ESTABLISHMENT, IF ANY

Legal Description — ADDRESS

REMARKS: NONTRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 60.00	$	$	$	$ 60.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
018754	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT
61519	12-29-82	60.00

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION HEALTH

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $ 60.00

FILE NO. 1894

DATE: 4/26/82

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section 15 ;
   Block 2 : Lot 1 : Addition Stevens Ridge Estates
   Street Address _____

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft.

John Sayer
Signature of Applicant (Owner or Lessee)

5625 L ST
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 6/29/82. Date Frwd. 6/29/82. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 6/29/82. Date Frwd. _____. ACTION: Approved ☒ Disapproved ☒ Signature: Gary L. Thurwood

3. City or County Engineer: Date Rec'd. 6-29-82. Date Frwd. 6-29-82. ACTION: Approved ☒ Disapproved ☐ Signature: Dennis Bartels

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 10/18/82 by: L.C.H.
Date: _____ by: _____
Date: _____ by: _____

INSTALLATION FINAL WRITTEN APPROVAL
Date: 10/18/82 By: Jerrold C. Hood

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

D

DATE: _____

FILE NO. _____


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material PVC ; Diameter 4 in.
2. Distance above basement floor _____ in., or below basement floor 30 in.
3. Distance between dwelling and septic tank 74 ft.
4. Number of clean-outs 1 .
5. Distances to:
Well or Suction Line 116 ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

B. SEPTIC TANK:
1. Material CON ; No. of compartments _____.
2. Capacity 1000 gals.;
3. Factory Built: Yes ☑ No ☐
(Company Pre Cast)
4. Manholes: Over Inlet; diam. _____ in.
Over Outlet; diam. _____ in.
Riser Above ☐ Below ☐ Grade ____ in.
5. Inlet: Baffle ☑ ; or Tee ☐
6. Outlet: Baffle ☑ ; or Tee ☐
7. Depth of top of tank below finished grade 12 in.
8. Distances to:
Well or Suction Line _____ ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

C. DISTRIBUTION BOX:
1. Material CON ; Number - available outlets 5 .
2. Factory Built: Yes ☑ No ☐
(Company Pre Cast)
3. Distance from Septic Tank 2½ ft.


D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☑ Perforated Pipe ☐
Diameter of Half Round 20 or
Perforated Pipe _____.
Material: fiberglass ☐ ; plastic ☐ ; concrete ☑ ; other _____.
2. Lateral Lines:
Number 3 ; Length of each line 100 , 100 , 32 , _____ , _____ ft.;
Total length of laterals _____ ft.;
Distance between lateral lines 22 ft.
3. Trench dimensions: Width 4 ft.;
Slope 0 in/100 ft.; Average Depth 36 in.
4. Filter Material: Gravel
Depth of Material 24 in.
5. Distances to:
Well or Suction Line _____ ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

AS BUILT DRAWING OF SYSTEM

DATE_____ INSTALLER_____



Capitol City Trenching
Harold & Casement
10-18-82