603

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☐ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 6700 SO. 59TH ST. CIRCLE

Twp 9N Range 7E Section 16 1/4 ___ 1/4 ___ Block ___ Lot ___ Addition LOT 2

Directions to Property 59TH CIR LAKE ROAD 2 BLOCKS NORTH

Location of Well ELKUNT YARD Tap Location: Inside ☒ Outside ☒

Location of Sewage System BEHIND AND NW Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	JOE & PATRICIA PARMELE	6700 SO. 59TH ST. CIRCLE 68516	
Tenant/Buyer:	MIKE & KIM SCHWANTZMAN	1636 BURR ST. LINCOLN, NE. 68502	435-4511
Return to:	MIKE & KIM SCHWANTZMAN	1636 BURR ST LINCOLN, NE. 68502	435-4511

Signature of Applicant [signature] Address 1636 BURR ST LINCOLN, NE. 68502 Date 11/1/95

HEALTH DEPARTMENT USE ONLY

Date Received 11/03/95 Received $150.00 Check ☒ H 3576 Cash ☐

PRELIMINARY STATUS--By J Chess **DATE:** 11/9/95

WATER SYSTEM:	Approved	Disapproved	**SEWAGE SYSTEM**	**Additional Site Visits**
Construction	☒ 11/9/95	☐	Approved ☐	Date ___/___/___ by ___
Bacteria	☒ 0 /ml	☐ ___ /ml	Provisional ☐	Date ___/___/___ by ___
Nitrate	☒ <0.2 ppm	☐ ___ ppm	Disapproved ☐	Date ___/___/___ by ___

Comments: IF THE TANK HAS NOT BEEN PUMPED RECENTLY, IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED. NOTICE OF SURFACE DISCHARGE NOTED. HOUSE IS VACANT

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☒ Provisional Approval: ☐

Approved by John J Chess Date ___/___/___

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.