Lincoln-Lancaster County Health Department

ENVIRONMENTAL HEALTH DIVISION
3140 N STREET · LINCOLN, NE 68510-1514 (402) 441-8000

Permit

SEWAGE SYSTEM REPAIR
SEWAGE REPAIR

Permit # 99390062801

Issued 08/10/99
Expires 02/10/00
Revenue Code 3157

Establishment

LARRY SCHWARCK
T9N R7E SEC 16
SHELDON HEIGHTS BLK 3 LOT 3&4
6101 FRONTIER ROAD

FEES: $50.00

Permitee

LARRY SCHWARCK
8200 OLD CHENEY RD
LINCOLN NE 68516-3827

TOTAL: $50.00

Leon F. Vinci, MPH, Health Director

• POST IN A PROMINENT PLACE • NOT TRANSFERABLE

010851

JUL 2 2 1999

Individual Sewage Disposal System
Application to Alter, Extend or Repair

☒ Municipal Code 24.38 ☐ County Resolution Number 2832

Date: 7-20-99	File No.: 993900628

The undersigned hereby applies for a permit to: ☐ **ALTER** ☒ **EXTEND** ☒ **REPAIR** an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. **Legal description of property:**
   Township 9N Range 7E Section 16 1/4 Section _____
   Block 3 Lot 3+4 Addition SHELDON HEIGHTS
   Street Address 6101 Frontier Rd

2. **Property use:** ☒ residential ☐ commercial ☐ other use
   Number of bedrooms 4 Describe _____

3. **Type of Present Individual Disposal System:** ☒ septic tank ☐ lagoon ☐ other

4. **Description of proposed alteration, extension or repair:** replace D box & Sewer from tank to D box — add 100' infiltration lateral

5. **Work to be done by:** ☐ owner ☒ contractor's name Larry Schwarck

6. **Estimated project:** a. Repair, replace or minor extension with a cost of less than $400.00 (no fee required).
   b. Total cost is greater than $400.00 (Return fee with this application).
   c. A "construction permit" is required if the use, operation, location, or type of the system is being changed.

Print Name Larry Schwarck Address 8200 old Cheney Rd Phone 489-7294
Applicant Signature (owner or lessee) Larry Schwarck

Please include the permit fee ($50.00) with this application

(Please do not write below this line)

Date rec'd 7/22/99 REVIEW: ☒ approved ☐ disapproved By: Jerrold C. Hood

Site visits:
Date _____ By _____
Date _____ By _____
Date _____ By _____


Installation final written approval
Date MARCH 22, 2000 By Jerrold C. Hood

Return to: Lincoln-Lancaster County Health Department - Environmental Health Division
3140 "N" Street, Lincoln, NE. 68510
441-8022


7/22/99
$ 50.00
ck 2121

White - EH Pink - Business Office Revised 1/98

#993900628



610 FRONTIER RD.



HOUSE

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

2200 St. Marys Ave Lincoln, NE 68502-3785 (402) 441-8000

NON TRANSFERABLE

PERMIT

Permit
WATER WELL

No. 94400044501

Issued 07/28/94
Expires 01/28/95
Revenue Code 19851

Establishment
GERALD BRYANT
T9N R7E SEC 16
SHELDON HEIGHTS BLK 3 LOT 3

FEES: $75.00

TOTAL $75.00

Permittee
GERALD BRYANT
6101 FRONTIER RD
LINCOLN NE 68516

Issued By M. Jane Ford
Health Director

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW
"POST IN A PROMINENT PLACE"

RECEIVED JUL 26 1994

FORM: 20222-0483
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL WATER WELL

LINCOLN LANCASTER COUNTY HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL HEALTH
2200 ST. MARYS AVENUE
LINCOLN, NEBRASKA 68502
PHONE: 471-7800

FILING FEE $ 75.00

FILE NO. _____

DATE: July 25, 1994

The undersigned hereby requests: Site Clearance and Permit to construct a new individual water well ☒ ; Permit existing well ☐ ; well repair or alteration involving opening of well ☐ ; in conformance with appropriate ordinance, as described herein:

1. Legal description of property: Twp. 9N : Range 7E : Section 16
   Block 3 : Lot 3 : Addition SHEDON HEIGHTS
2. Well use: Residential ☒ ; Commerical ☐ ; Other Use ☐
   Describe _____
3. Distance to Public Water Supply: ____ Ft.
4. Intended use of well Normal Residential Use

Gerald L Bryant
Signature of Applicant (owner or lessee)

6101 FRONTIER RD
Address

Sewage Permit Applied For Yes ☐ No ☐ Not Applicable ☒

1. Health Department: Date Rec'd 7/27/94. Date Frwd. 7/27/94. Action: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood
2. Supt. Bldg. Insp.: Date Rec'd 7-27-94. Date Frwd. 7-27-94. Action: Approved ☒ Disapproved ☐ Signature: [signature]
3. City or County Engineers: Date Rec'd 7/27/94. Date Frwd. _____. Action: Approved ☒ Disapproved ☐ Signature: [signature]

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 10/17/94 by J. C. Hood
Date: 11/1/94 by J. C. Hood ck 0.0
Date: _____ by _____

Nitrate Level 0.4 PPM
Bacteriological Analysis Satisfactory
Yes ☒ No ☐

INSTALLATION FINAL WRITTEN APPROVAL
Date: 11/7/94 By: J. C. Hood

Health Department copy: White
Engineers Copy: Light Green
Building Inspectors Copy: Light Blue

FORM 23-13

1994

FORM: 20223-0483
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL WATER WELL
CITY ORDINANCE NO. 13558
FILE NO. _____

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL HEALTH
2200 ST. MARYS AVENUE
LINCOLN NE 68502
Phone: ~~471-7830~~ 441-8022

DATA SHEET FOR WATER WELLS

Legal Description: Sec. 16 T. 9N R. 7E Block 2 Lot 3 Addition SHELDON HEIGHTS
Owner Gerald + JUDY BRYANT Address 6101 FRONTIER RD

LOG OF WELL	
	Description
Depth Ft. to	
0-2	Top soil
2-60	Brown clay
60-84	Blue clay
84-95	Red clay
95-115	Yellow & Gray clay
115-168	Sandstone
168-205	white clay & Shale
205-235	Sandstone

WELL COMPLETION RECORD

Drilling Method: Rotary
Depth (from ground level), Ft. 235
Date Completed 9/21/94

Casing: Length, Ft. 215 ; Dia.In. 4"
Wall Thickness, Inc. .214 ; type PVC Eagle

Screen: Length, Ft. 20 Dia.In. 4"
Type PVC monoFlex , slot Size .018 slot

Drop Pipe: Length, Ft. 200 Dia.In. 1¼"

Water Level, Surface to top of water.Ft.:
Static 132 , Pumping _____

Yield: 40 ggm, Measured ☐ , Est. ☑
Chlorination Completed Yes ☑ No ☐

The above information including "Log of Well" is a true record of the job performed by me.

Earnest Well Drilling, Inc.

Driller Marvin Roth
(Signed)

REMARKS NITRATE NITROGEN 0.4ppm.
BACTERIOLOGICAL O.K.


Address Box H Milford NE 68405

Date 9/22/94

DO NOT WRITE BELOW THIS DOUBLE LINE

Health Department forwarded copy of record to Nebraska Conservation and Survey Department for Scientific Record ☒

FORM 23-A


N
AREA OF
SEPTIC SYSTEM
DRIVE WAY
OLD WELL ABANDONED
WELL
47'2"
FIREPLACE
CHIMNEY
HOUSE