FILE NO. 204

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEPTIC SYSTEM CONSTRUCTION — January 15, 1971

TYPE OF LICENSE OR PERMIT — THIS LICENSE OR PERMIT EXPIRES

Grant Whitney, LANDMARK, LTD.

LICENSEE OR PERMITTEE — ADDRESS

T9N; Range 7E; Section 17; Lot 9; Colonial Acres 2nd.

NAME OF ESTABLISHMENT, IF ANY — ADDRESS

REMARKS: Non-Transferable

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
624 ~~110.15~~ 1536	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT
#22315	July 15, 1971	

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-32(67) APPLICATION FOR PERMIT
TO CONSTRUCT INDIVIDUAL SEWAGE
DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 204

DATE: _____

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 9N; Range 7E; Section 17;
Block —; Lot 9; Addition Colonial Acres, 2nd
Street Address _____.

2. Property Use: Residential _____ [X]; Commercial _____ [ ]
No. of Bed Rooms 3 Describe: _____

Other Use _____ [ ]
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-32a(67) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT, attached hereto.)

_____
Signature of Applicant (owner or lessee)

_____
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Date Site Clearance _____

3. Site Visits:
Date: 7/30/71 by: J.C.H.
Date: _____ by: _____
Date: _____ by: _____

4. Date: Approved [X]; Disapproved [ ]: 7/14/71
by: Jerrold C. Hood

5. BUREAU OF LICENSES & PERMITS
Date Notified: _____
Date Issued: _____ Serial _____

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 7/30/71 by: Jerrold C. Hood

FORM HD-30(67) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 304

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described herein:

1. Legal description of property: Twp. 9N; Range 7E; Section 17;
Block —; Lot 9; Addition Colonial Acres 2nd
Street Address _____.

2. Property Use: Residential _____ [X]; Commercial _____ [ ]
No. of Bedrooms 3. Describe: _____

Other Use _____ [ ]
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Distance to public sewer: _____ ft.

_____
Signature of Applicant (owner or lessee)

_____
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 7/14/71. ACTION: Approved [X] Disapproved [ ]
Date Frwd. 7/15/71. Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 7/15/71. ACTION: Approved [✓] Disapproved [ ]
Date Frwd. 7/15/71. Signature: Charles Seale By RG

3. City Engineer: Date Rec'd. _____. ACTION: Approved [✓] Disapproved [ ]
Date Frwd. 7-15-71. Signature: _____

REMARKS OR REASONS FOR DISAPPROVAL _____

FINAL ACTION ON SITE CLEARANCE: Approved [ ] Disapproved [ ]

Date Applicant Notified: _____ Signature _____

FORM HD-30(67) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 204

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described herein:

1. Legal description of property: Twp. 9N; Range 7E; Section 17;
Block —; Lot 9; Addition Colonial Acres 2nd
Street Address _____.

2. Property Use: Residential _____ [X]; Commercial _____ [ ]
No. of Bedrooms 3. Describe: _____
Other Use _____ [ ]
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Distance to public sewer: _____ ft.

Signature of Applicant (owner or lessee)

Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 7/14/71. ACTION: Approved [X] Disapproved [ ]
Date Frwd. 7/15/71. Signature: Jerrold C. Wood

2. Supt. Bldg. Insp.: Date Rec'd. 7/15/71. ACTION: Approved [✓] Disapproved [ ]
Date Frwd. 7/15/71. Signature: Charles Seale By RS

3. City Engineer: Date Rec'd. _____. ACTION: Approved [✓] Disapproved [ ]
Date Frwd. 7-15-71. Signature: _____

REMARKS OR REASONS FOR DISAPPROVAL _____

FINAL ACTION ON SITE CLEARANCE: Approved [ ] Disapproved [ ]

Date Applicant Notified: _____ Signature _____

FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 204

PROPERTY WHERE SOIL TESTED:
Location: Township _____
Section & ¼ Sect. _____
Property Dimensions: ____ft. x ____ ft.
Area: _____acres. (Attach sketch of property showing hole location).

Owner: Don Zornes
Address _____

Soil Type: Silty Clay ☐; Silty Clay Loam ☒; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☐; Sandy Clay ☐

Dates of Tests: 7-13-71 to 7-14-71. Weather: Precip. 0 Temp 85 F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
Hole No.	Hole Depth (in.)	Pre-Saturation Period Start Date (Mo. Day)	Pre-Saturation Period Start Time (Hr. Min.)	Pre-Saturation Period End Date (Mo. Day)	Pre-Saturation Period End Time (Hr. Min.)	Percolation Readings Start Date (Mo. Day)	Percolation Readings Start Time (Hr. Min.)	Percolation Readings Start Water Level (in.)	Percolation Readings End Time (Hr. Min.)	Percolation Readings End Water Level (in.)	Results Elapsed Time (Min.)	Results Water Level Drop (in.)	Results Percolation Rates (Min./inch)
1	32	7-13	8 AM	7-14	8 AM	7-14	8 AM		11 AM		3 Hr	23 3/4	
2	32	"	"	"	"	"	"		"		3 Hr	23 3/4	
3	32	"	"	"	"	"	"		"		2 Hr	21 1/2	
4	32	"	"	"	"	"	"		"		3 Hr	21 1/2	
5	32	"	"	"	"	"	"		"		3 Hr	19	
6	32	"	"	"	"	"	"		"		3 Hr	19	

James J Krafka
Signature of Person Conducting Test

Address RR #3 Lincoln
Phone: 434 2073

Sum of Percolation Rates _____
Average of Rates: _____
Mean of Rates: _____

(Do not write below this line)

REVIEWING ACTION

REMARKS: _____

Approved Percolation Rate(s)
A. 10 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: July 14, 1971

Jerrold C. Hood
Signature of Reviewing Official

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 204

SPECIFICATIONS

DATE: July 30, 1971


A. BUILDING SEWER:
1. Material Clay tile; Diameter 4 in.
2. Distance above basement floor — in.; or below basement floor 10 in.
3. Distance between dwelling and septic tank 56 ft.
4. Number of clean-outs 1.
5. Distances To:
Well or Suction Line 200 ft.;
Stream — ft.; Pressure Line — ft.;
Property Line 150 ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Conc.; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth — in.
3. Factory Built: Yes [X] (Company Precast)
No [ ]
4. Manholes: Over Inlet; diam. 6 in.
Over Outlet; diam. 6 in.
Below Grade — in.
5. Inlet: Baffle [ ]; or Tee [ ]
6. Outlet: Baffle [ ]; or Tee [ ]
Depth of outlet below inlet — in.
7. Depth of top of tank below finished grade 24" in.
8. Distances To:
Well or Suction Line 150 ft.;
Stream — ft.; Pressure Line — ft.;
Property Line 150 ft.


C. DISTRIBUTION BOX
1. Material Conc.; No. available outlets 3.
2. Factory Built: Yes [X], (Company Precast) No [ ]
3. Dimension: Length 24 in.; Width 24 in. Depth 12 in.
4. Distance from Septic Tank 15' ft.
5. Serial Distribution: Yes [ ], No [X] (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: ½ Moon Conc
2. Lateral Lines: Depth below grade 24" in. Number 2; Length of each line 62 ft Total length of Laterals 124 ft.; Slope 1 in/100 ft. Diameter of pipe 18" in.; Shape ⌒
Material: concrete [X]; fiber asbestos [ ]; clay [ ]; other —
Distance between lateral lines 20 ft.
3. Trench Dimensions: Depth 42 in.; Width 48" in.
4. Filter Material: Gravel.
Depth of material from trench bottom 26" in.
5. Distances To:
Well or Suction Line 250 ft.;
Stream — ft.; Pressure Line — ft.
Property Line 100 ft.
6. Percolation Rate: — minutes/inch

TYPICAL SKETCHES



Signature of Applicant


PROPERTY LINE
20'
36'
46'
60'
64'
1½'
56'
23'
HOUSE
N
W
E
S