FILE NO. 361

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

April 15, 1974 — THIS LICENSE OR PERMIT EXPIRES

Ken Peterson — LICENSEE OR PERMITTEE

4700 Kirkwood Drive — ADDRESS

T9N; R 7E; Sec. 20; Bl. 2; Lot 4; Country Acres — NAME OF ESTABLISHMENT, IF ANY

LEGAL DESCRIPTION — ADDRESS

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE	
624-1535 110.15	110.16	148.14	6-2	

SERIAL NO.	DATE	AMOUNT

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-30(67) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 361

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section ~~29~~ 20;
Block 2 ; Lot 4 ; Addition _____;
Street Address Country Acres.

2. Property Use: Residential 1 [X]; Commercial _____ [ ]
No. of Bedrooms 6. Describe: _____

Other Use _____ [ ]
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Distance to public sewer: _____ ft.

Ken Peterson by Roger Burling
Signature of Applicant (owner or lessee)

4700 Kirkwood Dr.
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 10/15/73. ACTION: Approved [X] Disapproved [ ]
Date Frwd. 10/15/73. Signature: Jerrold C. Hoad

2. Supt. Bldg. Insp.: Date Rec'd. 10-15-73. ACTION: Approved [X] Disapproved [ ]
Date Frwd. 10-15-73. Signature: Chas Seals By BL

3. City Engineer: Date Rec'd. 10-15-73. ACTION: Approved [ ] Disapproved [X]
Date Frwd. _____. Signature: Glen Smith

REMARKS OR REASONS FOR DISAPPROVAL _____

FINAL ACTION ON SITE CLEARANCE: Approved [ ] Disapproved [ ]

Date Applicant Notified: _____ Signature _____

FORM HD-32(67) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 361

DATE: _____

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 9N; Range 7E; Section 20; Block 2; Lot 4; Addition ____; Street Address Country Acres.

2. Property Use: Residential ____ [X]; Commercial ____ [ ]
No. of Bed Rooms 6 Describe: ____

Other Use ____ [ ]
Describe: ____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-32a(67) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT, attached hereto.)

Ken Petersen by Roger Burkey
Signature of Applicant (owner or lessee)

4700 Kirkwood Dr.
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd: ____
Filing Fee: $ 30.00

2. Date Site Clearance ____

3. Site Visits:
Date: 8/2/74 by: OSS
Date: ____ by: ____
Date: ____ by: ____

4. Date: Approved [X]; Disapproved [ ]; 10/15/73
by: Jerrold C. Hood R.S.

5. BUREAU OF LICENSES & PERMITS
Date Notified: ____
Date Issued: ____ Serial ____

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: Nov. 25, 1974 by: Jerrold C. Hood

4

FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 361

PROPERTY WHERE SOIL TESTED:
Location: Township T9N R7E
Section & ¼ Sect. 29
Property Dimensions: ____ft. x ____ ft. Block 2 Lot 4
Area: _____acres. (Attach sketch of property showing hole location).

Owner: Ken Peterson
Address 4700 Kirkwood Dr.

Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☒; Sandy Clay ☐

Dates of Tests: Oct. 12, 73 to Oct. 13, 73. Weather: Precip. Wet Temp. 70 F

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	38	9/12/73	9:00	9/13/73	9:00	9/13/73	4:00	10	12:00		3 hrs	4	
2												4	
3												4	
4												5	
5												5	
6												3	

Sum of Percolation Rates
Average of Rates:
Mean of Rates: 4 8/25

Signature of Person Conducting Test

Address
Phone:

(Do not write below this line)

REVIEWING ACTION

REMARKS:

Approved Percolation Rate(s)
A. 4 4 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: October 15, 1973

Gerrold C. Wood
Signature of Reviewing Official

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 361

SPECIFICATIONS

DATE: Oct 15 1973


A. BUILDING SEWER:
1. Material _____; Diameter ____ in.
2. Distance above basement floor ____in.; or below basement floor ____in.
3. Distance between dwelling and septic tank ____ft.
4. Number of clean-outs _____.
5. Distances To:
Well or Suction Line ____ft.;
Stream ____ft.; Pressure Line ____ft.;
Property Line ____ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material _____; No. of compartments 1.
2. Capacity 2000 gals.; Liquid depth 48 in.
3. Factory Built: Yes ☒ (Company _____)
No ☐
4. Manholes: Over Inlet; diam. ____in.
Over Outlet; diam. ___in.
Below Grade 24 in.
5. Inlet: Baffle ☐; or Tee ☒
6. Outlet: Baffle ☐; or Tee ☒
Depth of outlet below inlet ___in.
7. Depth of top of tank below finished grade ____in.
8. Distances To:
Well or Suction Line ____ft.;
Stream ____ft.; Pressure Line ____ft.;
Property Line ____ft.


C. DISTRIBUTION BOX
1. Material _____; No. available outlets _____.
2. Factory Built: Yes ☐, (Company _____) No ☐
3. Dimension: Length ____in.; Width ___in. Depth ____in.
4. Distance from Septic Tank ____ft.
5. Serial Distribution: Yes ☐, No ☐ (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: Half Round
2. Lateral Lines: Depth below grade ___in.
Number 5; Length of each line 100 ft
Total length of Laterals 450 ft.; +50
Slope 4 in/100 ft. Diameter of pipe ____ in.; Shape ∩
Material: concrete ☐; fiber asbestos ☐; clay ☐; other _____
Distance between lateral lines ____ft.
3. Trench Dimensions: Depth ___in.; Width 48 in.
4. Filter Material: Gravel.
Depth of material from trench bottom _____in.
5. Distances To:
Well or Suction Line ____ft.;
Stream _____ft.; Pressure Line ____ft.
Property Line ____ft.
6. Percolation Rate: _____minutes/inch

TYPICAL SKETCHES



Signature of Applicant


N
98½'
21'
7½"
100'
100'
100'
100'
37'
50'