FILE #2584

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

APRIL 26, 1988 — THIS LICENSE OR PERMIT EXPIRES

ANITA KIDWILER — LICENSEE OR PERMITTEE

7505 SO. 75 STREET, ROUTE #9 LINCOLN, NE 68516 — ADDRESS

T9N; R7E; Sec 22; Bk 2; Lot 10; Clarendon Hills 1st Add; — NAME OF ESTABLISHMENT, IF ANY

7505 So. 75 Street — ADDRESS

REMARKS: NON TRANSFERABLE ALTER, EXTEND OR REPAIR

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 30.00	018754	$ 30.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. Date and Amount

APPLICATION

HEALTH

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO. 2584

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 10/23/87

The undersigned hereby applies for a permit to ALTER ☒, EXTEND ☐, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 9N ; Range 7E ; Section 22 ;
Block 2 ; Lot 10 ; Addition CLARENDON HILLS 1st ADDITION
Street Address 7505 South 75

2. Property Use: Residential ☑; Commercial ☐
No. Bedrooms 3
Describe
Other Use ☐
Describe

3. Type of existing Individual Sewage Disposal System: Septic Tank ☑; Other ☐

4. Description of proposed alteration, extension or repair: REDISIGN SEWAGE SYSTEM

5. Work to be done by: Owner ☐ ; or Contractor ☒ , Duane Friesen
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$	2300.00

Signature of Applicant (owner or lessee)

7505 So 75
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd:
Filing Fee: $ 30.00

2. Site Visits:
Date: 10/26/87 by: J. C. Hood
Date: by:
Date: by:

3. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 2/22/88 by: J. C. Hood

16th Lincoln Gen. N.

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

B

FILE NO. 2584

PROPERTY WHERE SOIL TESTED:

Location: Township_____; Range_____; Section & ¼ Section_____.
Property Dimensions: _____ft. x _____ft. Area:_____acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 10/22/87 to 10/23/87. Weather: Precip._____Temp._____.

OWNER: Merlin Kidwiler

Address: 7505 So 75

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	30	10/22	3	10/22	7	10/23	10:30	[illegible]	2:00	6	30	1 7/8	
2	30	10/22	3	10/22	7	10/23	10:30	[illegible]	2:00	10	30	1/8	
3	30	10/22	3	10/22	7	10/23	10:30	[illegible]	2:00	13 1/8	30	1 5/8	
4	30	10/22	3	10/22	7	10/23	10:30	[illegible]	2:00	16 3/8	30	3/4	
5	30	10/22	3	10/22	7	10/23	10:30	[illegible]	2:00	15 5/8	30	1	
6	30	10/22	3	10/22	7	10/23	10:30	[illegible]	2:00	17 1/2	30	1/2	

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

[signature]
Signature of Person Conducting Test

Address 7505 South 75 Phone 423-2401


(Do not write below this line)

REVIEWING ACTION

Remarks: _____
Soil Type (SCS): Wymore Silty Clay Loam
Date: OCTOBER 23, 1987

Approved Percolation Rate (a)
A. 30 min./inch
B. _____ min./inch
C. _____ min./inch

Jerrold C. Hood
Signature of Reviewing Official


House
5561
Kidweiler
N
60'
Tanks
125'
Distribution Box
50'
100'
100'

003

Lincoln-Lancaster County Health Department

2200 St. Mary's Avenue, Lincoln, Nebraska 68502 Phone: 471-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☐ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 7505 So 75th Lincoln

Twp 9N Range 7E Section 22 1/4 ___ 1/4 ___ Block 2 Lot 10 Addition Clarendon Hills 1ST ADDITION

Directions to Property HW 2 East to Pine Lake Rd. (1990)

Location of Well South of house Tap Location: Inside ☐ Outside ☒ *

Location of Sewage System West of house Year Installed 1987- New Laterals

* TRIPLE FAUCET ON South side of house comes off well head (SW CORNER)

	NAME	ADDRESS	PHONE
Present Owner:	John & Marilyn Herman	7505 So 75th	423-9644
~~Tenant~~/Buyer:	Mary Robinson	3105 Cedar Ave	423-0742
Return to:	Applicant below		

Signature of Applicant Dede Hellert Address 3201 Pioneers Date 7/6/93

Realtor Woods Bros. Lincoln Ne 68502

HEALTH DEPARTMENT USE ONLY

Date Received 07/07/93 Received $150.00 ✓ Check ☒ # 2772 Cash ☐

PRELIMINARY STATUS--By Jerrold C. Hood **DATE:** 7/9/93

WATER SYSTEM:	Approved	Disapproved	**SEWAGE SYSTEM**	**Additional Site Visits**
Construction	☒	☐	Approved ☒	Date ___/___/___ by ___
Bacteria	☒ 0 /ml	☐ ___ /ml	Provisional ☐	Date ___/___/___ by ___
Nitrate	☒ 5.0 ppm	☐ ___ ppm	Disapproved ☐	Date ___/___/___ by ___

Comments: IF THE SEPTIC TANK HAS NOT BEEN DUMPED RECENTLY IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED.

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☒ Provisional Approval: ☐

Approved by Jerrold C. Hood R.E.H.S. Date 7/14/93

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

116