FILE W-7

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL WATER WELL CONSTRUCTION — TYPE OF LICENSE OR PERMIT

December 8, 1993 — THIS LICENSE OR PERMIT EXPIRES

RICHARD BORISON — LICENSEE OR PERMITTEE

2821 FOX HOLLOW ROAD, LINCOLN, NE 68506 — ADDRESS

NAME OF ESTABLISHMENT, IF ANY — ADDRESS

REMARKS: NON TRANSFERABLE T9N; R7E; Section NE¼ S 28; Add, Yankee Ridge

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 45.00	019851	$ 45.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. — Date and Amount

APPLICATION

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

135369

FORM: 20222-0483
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL WATER WELL

LINCOLN LANCASTER COUNTY HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL HEALTH
2200 ST. MARYS AVENUE
LINCOLN, NEBRASKA 68502
PHONE: 471-7800

FILING FEE $ 45.00

FILE NO. W-7

DATE: 6/8/83

The undersigned hereby requests: Site Clearance and Permit to construct a new individual water well ☒ ; Permit existing well ☐ ; well repair or alteration involving opening of well ☐ ; in conformance with appropriate ordinance, as described herein:

1. Legal description of property: Twp. 9N : Range 7E : Section NE¼S28
   Block _____ : Lot _____ : Addition Yankee Ridge Estates
2. Well use: Residential ☒ ; Commerical ☐ ; Other Use ☐
   Describe _____
3. Distance to Public Water Supply: _____ Ft.
4. Intended use of well domestic water supply

Signature of Applicant (owner or lessee)

2821 Fox Hollow Road
Address

Sewage Permit Applied For Yes ☒ No ☐ Not Applicable ☐

1. Health Department: Date Rec'd 6/9/83. Date Frwd. 6/9/83. Action: Approved ☒ Disapproved ☐ Signature: Jerrold C. Neef
2. Supt. Bldg. Insp.: Date Rec'd 6/9/83. Date Frwd. 6/9/83. Action: Approved ☒ Disapproved ☐ Signature: R. Harris
3. City or County Engineers: Date Rec'd 6/9/83. Date Frwd. 6/9/83. Action: Approved ☒ Disapproved ☐ Signature: Jerome D. Obrist

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 1/16/84 by L.C.H. Well under snow bank.
Date: 2/13/84 by L.C.H. Settlement around well.
Date: 4/5/84 by L.C.H.

Nitrate Level <0.1 PPM
Bacteriological Analysis Satisfactory
Yes ☒ No ☐

INSTALLATION FINAL WRITTEN APPROVAL
Date: 4/6/84 By: L.C. Hood

Health Department copy: White
Engineers Copy: Light Green
Building Inspectors Copy: Light Blue

FORM 23-13

W-7

FORM: 20223-0483
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL WATER WELL
CITY ORDINANCE NO. 13558
FILE NO. W-7

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL HEALTH
2200 ST. MARYS AVENUE
LINCOLN NE 68502
Phone: 471-7800

REC'D JAN 19 1984

DATA SHEET FOR WATER WELLS

Legal Description: Sec. 28 T. 9N R. 7E Block 8 Lot 1 Addition YANKEE RIDGE ESTATE
Owner Bruce Briney Address Yankee Ridge Estates
Dick Robisson - Contractor

LOG OF WELL	
	Description
Depth Ft. to	
0-40	yellow c.
40-95	blue c.
95-140	red + white shale
(100-101)	hard layer of limestone
140-170	yellow shale
170-210	s.s. w/ layers of shale
210-242	good coarse yellow s.s.

WELL COMPLETION RECORD

Drilling Method: Rotary Circulation
Depth (from ground level), Ft. 240'
Date Completed 7-6-83

Casing: Length, Ft. 230'; Dia. In. 4"
Wall Thickness, Inc. .200"; type SDR 21 PVC

Screen: Length, Ft. 10 Dia. In. 4"
Type slotted, slot Size .025

Drop Pipe: Length, Ft. 180' Dia. In. 1 1/4"

Water Level, Surface to top of water, Ft.:
Static 150', Pumping 20 gpm

Yield: ~~200~~ 100 ggm, Measured ☒, Est. ☐

Chlorination Completed Yes ☒ No ☐

The above information including "Log of Well" is a true record of the job performed by me.

Driller Bill Moser
(Signed)

REMARKS NITRATE NITROGEN < 0.1 ppm Address 703 E 4th

Date 1-17-84

DO NOT WRITE BELOW THIS DOUBLE LINE

Health Department forwarded copy of record to Nebraska Conservation and Survey Department for Scientific Record ☒

FORM 23-4

AS BUILT DRAWING OF INSTALLATION IN RELATION TO BUILDINGS, PROPERTY LINES, OTHER WELLS, AND SOURCES OF CONTAMINATION. INDICATE NORTH.

