CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

FILE NO. 1268

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF LICENSE OR PERMIT

August 27, 1978
THIS LICENSE OR PERMIT EXPIRES

Fred P. Wagner 1924 Park Ave., Lincoln, NE 68502
LICENSEE OR PERMITTEE ADDRESS

T9N, R7E, Section 28
NAME OF ESTABLISHMENT, IF ANY ADDRESS

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE	
110.15 624-1535	110.16	148.14	6-2	
SERIAL NO.	DATE	AMOUNT		

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION
HEALTH

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1268

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 6-24-75

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section 28 SEE ATTACHED
   Block _____; Lot _____; Addition _____
   Street Address 6200 Rokeby Rd

2. Property Use: Residential _____ ☒ ; Commercial _____ ☐
   No. of Bedrooms 3. Describe: _____
   Other Use _____ ☐
   Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐ CONTINGENT ON NEW SOIL TEST TO BE WITNESSED

4. Distance to public sewer: 20,000 ft. ft.

Fred P. Wagner
Signature of Applicant (Owner or Lessee)

1924 PARK AV., LINCOLN, NE
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 2/27/78. ACTION: Approved ☒ Disapproved ☐
   Date Frwd. 2/27/78. Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 2-27-78. ACTION: Approved ☒ Disapproved ☐
   Date Frwd. 2-27-78. Signature: Gaylon N. Sherwood

3. City ~~or County~~ Engineer: Date Rec'd. 2-27-78. ACTION: Approved ☒ Disapproved ☐
   Date Frwd. 2-27-78. Signature: Al Imig

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

½ of SW¼

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

y Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1268

DATE: 2-24-78

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto. SEE ATTACHED

1. Legal description of property: Twp. 9 N ; Range 7 E ; Section 28 ; Block ; Lot ; Addition .
Street Address 6200 Rokeby Road. SW 1/2 of SW 1/4

2. Property Use: Residential [X]; Commercial [ ]
No. of Bedrooms 3
Describe:

Other Use
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Fred P. Wagner
Signature of Applicant (owner or lessee)

Address

(Do not write below double line)

REVIEWING ACTION


1. Date Rec'd;
Filing Fee: $ 30.00

Site Visits:
Date: 12-21-78 by: [illegible] X
Date: 5-7-79 by: gw
Date: by:

3. Date: Approved [X]; Disapproved [ ] 2/27/78
by: Jerrold C. Hood


4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 6-27-80 by: Ron Marquart

mark fence drawing must have Recieved



6200 Robeby Road Twp. 9; Range 7; Section 28 of SW1/2 of SW 1/4
Fred P. Wagner Phone # 477 2679

PERCULATION READINGS



July 18, 1975

	①	②	③	④	⑤	⑥
5:30	3 1/4	6	6	4 5/8	3 1/4	3 1/2
6:00	3 1/4	6	6	3 1/4	3 1/4	3 1/2
6:30	3 1/4	6	6	5	3 1/4	3 1/4
7:00	3	6	6	5	3	2 1/2
7:30	3	6	6	4 1/4	3	2 1/2
8:00	3	5 1/8	6	3 3/4	3	2 1/2
8:30	2 1/8	5 1/8	5 3/4	3 1/2	2 3/4	2 1/2
9:00	2 3/4	5 3/4	5 3/4	3 1/2	2 3/4	2 1/4
9:30	2 3/4	5 5/8	5 3/4	3 3/8	2 3/4	2 1/4

3.75 / 30 minutes
of 8 minute/inch

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1208

SPECIFICATIONS

DATE: 2-24-78


A. BUILDING SEWER:
1. Material ~~Plastic~~ CI; Diameter 4 in.
2. Distance above basement floor ___ in.; or below basement floor 14 in.
3. Distance between dwelling and septic tank 55 ft.
4. Number of clean-outs 1.
5. Distances To:
Well or Suction Line excess of 100 ft ft.;
Stream excess of 100 ft.; Pressure Line same ft.;
Property Line 30 ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Concrete; No. of compartments 1
2. Capacity ~~1250~~ 1000 gals.; Liquid depth 50 in.
3. Factory Built: Yes ☒ (Company precast)
No ☐
4. Manholes: Over Inlet; diam. 6 in.
Over Outlet; diam. 6 in.
Below Grade 12 in.
5. Inlet: Baffle ☒; or Tee ☐
6. Outlet: Baffle ☒; or Tee ☐
Depth of outlet below inlet 1 in.
7. Depth of top of tank below finished grade 12 in.
8. Distances To:
Well or Suction Line excess 100 ft ft.;
Stream same ft.; Pressure Line same ft.;
Property Line 80 ft.

C. DISTRIBUTION BOX
1. Material Concrete; No. available outlets 5.
2. Factory Built: Yes ☒, (Company precast)
No ☐
3. Dimension: Length ___ in.; Width ___ in.
Depth ___ in.
4. Distance from Septic Tank 10 ft.
5. Serial Distribution: Yes ☐, No ☐
(If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: PreCast half moon
2. Lateral Lines: Depth below grade 12 in.
Number 2; Length of each line ___ ft
Total length of Laterals 152 ft.; 52+100
Slope ___ in/100 ft. Diameter of pipe ___ in.; Shape half moon
Material: concrete ☒; fiber asbestos ☐; clay ☐; other ___
Distance between lateral lines ___ ft.
3. Trench Dimensions: Depth 36 in.; Width 48 in.
4. Filter Material: gravel.
Depth of material from trench bottom 20 in.
5. Distances To:
Well or Suction Line excess of 100 ft ft.;
Stream same ft.; Pressure Line same ft.
Property Line 30 ft.
6. Percolation Rate: 8 minutes/inch
3.75 in / 30 min

TYPICAL SKETCHES




SEPTIC TANK

DISTRIBUTION BOX

TRENCH & LATERAL

Signature of Applicant



6200 Rokeby Rd Twp 9; RANGE 7 Section 28 of SW ½ of SW ¼ Fred P. WAGNER 423 2316