FILE NO. 1884

# CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

JUNE 8, 1982 — THIS LICENSE OR PERMIT EXPIRES

DARCY CONSTRUCTION, INC. — LICENSEE OR PERMITTEE

5432 LOCUST LINCOLN NE 68516 — ADDRESS

T9N, R7E, SECTION 28, BLOCK 1, LOT 5, ADDITION YANKEE RIDGE ESTATES — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NONTRANSFERABLE NEW

| PERMIT | INSPECTION FEE | OCCUPATION TAX | LICENSE | TOTAL |
|---|---|---|---|---|
| $ 60.00 | $ | $ | $ | $ 60.00 |

| ACCOUNTING NO. | ACCOUNTING NO. | ACCOUNTING NO. | CODE |
|---|---|---|---|
| 018754 | 110116 | 148114 | 6-2 |

| SERIAL NO. | DATE | AMOUNT |
|---|---|---|
| 81247 | | 60.00 |

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

HEALTH

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $ 60.00

FILE NO. 1884

DATE: June 8, 1982

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9 N.; Range 7 E.; Section 28;
   Block 1: Lot 5: Addition Yankee Ridge Estates
   Street Address _____

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3. Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: N.A. ft.

Dakey Const Inc
Signature of Applicant (Owner or Lessee)

5432 Locust
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 6/8/82. Date Frwd. 6/9/82. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold E. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 6-9-82. Date Frwd. 6-9-82. ACTION: Approved ☒ Disapproved ☐ Signature: Paul Bauma

3. City or County Engineer: Date Rec'd. 6-9-82. Date Frwd. 6-9-82. ACTION: Approved ☒ Disapproved ☐ Signature: Dennis Bartels

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 8/17/82 by: L.C.H.
Date: _____ by: _____
Date: _____ by: _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

INSTALLATION FINAL WRITTEN APPROVAL
Date: 8/17/82 By: Jerrold E. Hood

6200 ~~Pine~~ Lake Rd
Rebel Drive

Block I, Lot 5, Yankee Ridge Estates

June 6, 1982

| Hole NO | I | II | III | IV | V | VI |
|---|---|---|---|---|---|---|
| 7:30 start | 0 | 0 | 0 | 0 | 0 | 0 |
| 8:00 | 4 1/2" | 7 1/2" | 1/2" | 8" | 1 1/2" | 1/2" |
| 8:30 | 3 1/2" | 4" | 1/2" | 4" | 1 1/2" | 1/2" |
| 9:00 | 2 1/4" | 3 1/2" | 1/2" | 4" | 1" | 0 |
| 9:30 | 2 1/4" | 3 1/2" | 0" | 3 1/2" | 1" | 0 |
| 10:30 | 2" | 3 1/2" | 0" | 3 1/2" | 1" | 1/2" |
| 10:30 | 1 3/4" | 3 1/4" | 1/2" | 3" | 1" | 0" |
| 11:00 | 1 3/4" | 3 1/4" | 0 | 2 3/4" | 1" | 0" |
| 11:30 | 1 5/8" | 3 1/8" | 0 | 2 3/4" | 1" | 0 |

June 8

24hrs — Empty Empty 1 1/2" ~~Empty~~ Empty 2"

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

**D**

DATE: _____

FILE NO. _____


## SPECIFICATIONS AS BUILT

A. BUILDING SEWER: 3034
1. Material PVC; Diameter 4 in.
2. Distance above basement floor _____ in., or below basement floor 38 in.
3. Distance between dwelling and septic tank 65' ft.
4. Number of clean-outs 1.
5. Distances to:
Well or Suction Line 100'+ ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

B. SEPTIC TANK:
1. Material Concrete; No. of compartments _____.
2. Capacity 1000 gals.;
3. Factory Built: Yes ☒ No ☐
(Company Pre Cast Steps)
4. Manholes: Over Inlet; diam. _____ in.
Over Outlet; diam. _____ in.
Riser Above ☐ Below ☐ Grade _____ in.
5. Inlet: Baffle ☐ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☐
7. Depth of top of tank below finished grade 8" in.
8. Distances to:
Well or Suction Line 100'+ ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

C. DISTRIBUTION BOX:
1. Material Concrete; Number - available outlets 5.
2. Factory Built: Yes ☒ No ☐
(Company Pre Cast)
3. Distance from Septic Tank 10' ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☐ Perforated Pipe ☒
Diameter of Half Round _____ or Perforated Pipe 4" .
Material: fiberglass ☐ ; plastic ☑ ; concrete ☐ ; other _____.
2. Lateral Lines:
Number 3 ; Length of each line 70, 80, 100, _____, _____ ft.;
Total length of laterals 250 ft.;
Distance between lateral lines 12' ft.
3. Trench dimensions: Width 3' ft.;
Slope 3" in/100 ft.; Average Depth 36" in.
4. Filter Material: Road Gravel
Depth of Material 20" in.
5. Distances to:
Well or Suction Line 100'+ ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.




TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

# LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St. Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: JUNE 28, 1989

☐ Evaluation of the Sewage Disposal System ☒ Enclosed is $75.00

Legal Description of Property: TWP. 9N ; RANGE 7E ; SECTION 28 ; BLOCK 1

LOT 5 ; ADDITION YANKEE RIDGE ; Street Address 6200 REBEL DRIVE

Directions to Property 3½ MILES SOUTH OF OLD CHENEY ON 56TH, EAST 6 BLOCKS ON REBEL DRIVE. ON NORTH SIDE OF ROAD

Location of Well EAST OF HOUSE Tap Location: Inside ☐ Outside ☐

Location of Sewage System NORTH OF HOUSE Year Installed _____

| | NAME | ADDRESS | PHONE |
|---|---|---|---|
| Present Owner: | GARY & EVA WADE | 6200 REBEL | 423-5474 |
| Tenant/Buyer: | DAN & MARGARET SCOTT | 2329 TIMBERLAND, AMES IA | 292-7205 |
| Return to: | ROGER HARRE/WOODS BROS | 3201 PIONEERS BLVD, 68502 | 483-4151 |

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

**Signature of Applicant** Roger A. Harre Address 3811 PRESCOTT AVE LINCOLN, NE. 68506

==========

*HEALTH DEPARTMENT USE ONLY*

Date Received JULY 14, 1989 Received $75.00 Check ☒ Cash ☐

---

PRELIMINARY STATUS--DATE JUNE 29, 1989

| WATER SYSTEM: | Approved | Disapproved | SEWAGE SYSTEM: | | SITE VISIT: |
|---|---|---|---|---|---|
| Construction | ☒ | ☐ | Approved: | ☒ | Date 6/29/89 by L.C.H. |
| Bacteria | ☒ | ☐ | Provisional: | ☐ | Date _____ by ____ |
| Nitrate | ☒ | ☐ | Disapproved: | ☐ | Date _____ by ____ |

Comments: IF THE SEPTIC TANK HAS NOT BEEN PUMPED RECENTLY IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED. SYSTEM IS NEARLY SEVEN YEARS OLD. See Attached Letter ☐

---

FINAL STATUS

| WATER SYSTEM: | SEWAGE DISPOSAL SYSTEM: | |
|---|---|---|
| Approved: ☒ | Approved: ☒ | Provisional Approval: ☐ |

APPROVED BY Wolfe C. Nood M.S. DATE JULY 14, 1989

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

9909070001

# Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

## REAL ESTATE TRANSFER/LOAN APPROVAL FORM

FOR PROPERTY IN **LANCASTER COUNTY** ONLY

This form must be completed and returned with payment to request a real estate transfer inspection.

**MAKE CHECK PAYABLE TO:** "Lincoln-Lancaster County Health Department" or "LLCHD"

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

LCR 4458

Legal Description of Property: Street Address 6200 Rebel Drive, Lincoln NE 68516

Twp 9 Range 7 Section 28 1/4 N½ 1/4 ___ Block 1 Lot 5 Addition Yankee Ridge

Directions to Property 56th Street or 70th Street south to Rebel Drive (2nd road south of Yankee Hill Road. Turn west on Rebel Drive

Location of Well From SE corner of house East to behind 2nd apple trees (30-40') Tap Location: Inside ☐ Outside ☒

Location of Sewage System From the deck N.W. to closest pine trees (about 30' or 50') Lateral Rolls there Year Installed 1982

| | NAME | ADDRESS | PHONE |
|---|---|---|---|
| Present Owner: | Margaret E Scaffy | PO Box 246 Imperial NE 69033 | 308-882-5270 |
| Tenant/Buyer: | Bradley & Peggy Williams | 5506 Moore Drive Lincoln NE | 402-421-1607 |
| Return to: | Cynthia Carlton | Woods Bros Realty 7141 A Street Lincoln, NE 68510 | 402-430-7683 |

Signature of Applicant Margaret E Scaffy Address PO Box 246 Imperial NE 69033 Date 7/6/99

If access needed call Cynthia Carlton 430-7683

### HEALTH DEPARTMENT USE ONLY

**RECEIVED**

Date 07/14/99
Initials ___
Amount 150.00
Check No. 4001

**DATA ENTRY**

Date ___/___/___
Case No. ___
Initials ___

**PRELIMINARY STATUS--By** Chen **DATE:** 7/15/99 7-16 called to get on auto dialer

| WATER SYSTEM: | Approved | Disapproved |
|---|---|---|
| Construction | ☑ | ☐ |
| Bacteria | ☑ 0 /ml | ☐ ___ /ml |
| Nitrate | ☑ .4 ppm | ☐ ___ ppm |

| SEWAGE SYSTEM | |
|---|---|
| Approved | ☐ |
| Provisional | ☐ |
| Disapproved | ☐ |

**Additional Site Visits**

Date 7/19/99 by JR
Date ___/___/___ by ___
Date ___/___/___ by ___

**Comments:** IF the septic tank has not been pumped recently it should be checked to see if it is necessary. House is VACANT, NOV. 5th to SIGN OFF SEWAGE. AS THE TREES get larger root structure deeper may infest ~~sewage~~ may clog system

See Attached Letter ☐

**FINAL STATUS**

**WATER SYSTEM:** Approved ☑ **SEWAGE DISPOSAL SYSTEM:** Approved ☑ Provisional Approval ☐

Approved by John J Chen Date 8/20/99

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

Revised/Reprint: 10-95

P8525-99 8-299 7/27 P8525-96 7/22 P6759-28 7/27 3 P8340-13

Pos. Coli. Form Neg E. Coli Neg Neg Pos. Coli Form Neg E. Coli

6500 Rebal Rd.

AS BUILT DRAWING OF SYSTEM

DATE Aug. 17, 82 INSTALLER Larry Schwarck

