1831

# CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

MARCH 24, 1982 — THIS LICENSE OR PERMIT EXPIRES

POTTYCO PLUMBING COMPANY — LICENSEE OR PERMITTEE

4820 RENTWORTH LINCOLN NE 68516 — ADDRESS

T9N, R7E, SECTION 28, BLOCK 3, LOT 3, ADDITION YANKEE RIDGE — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NONTRANSFERABLE

| PERMIT | INSPECTION FEE | OCCUPATION TAX | LICENSE | TOTAL |
|---|---|---|---|---|
| $ 60.00 | $ | $ | $ | $ 60.00 |
| ACCOUNTING NO. | ACCOUNTING NO. | ACCOUNTING NO. | CODE | |
| 018754 | 110.16 | 148.14 | 6-2 | |

| SERIAL NO. | DATE | AMOUNT |
|---|---|---|
| 58947 | 3-24 | 60.00 |

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

HEALTH

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $60.00

FILE NO. 1831

DATE: Sept. 23 1981

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section 28 ;
   Block 3 : Lot 3 : Addition Yankee Ridge
   Street Address 6101 Rebel Dr.

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft. TYPE DEPENDENT UPON PERC. TEST.

Lotsco P.O.
By Ron Leuloo
Signature of Applicant (Owner or Lessee)

4820 Kentworth
Address 68516

(Do not write below this double line)

1. Health Department: Date Rec'd. 9/24/81. Date Frwd. 9/24/81. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 9-24-81. Date Frwd. _____. ACTION: Approved ☐ Disapproved ☐ Signature: Ernest Dunne

3. City ~~or County~~ Engineer : Date Rec'd. 9-24-81. Date Frwd. 9-24-81. ACTION: Approved ☒ Disapproved ☐ Signature: M Smog

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 11-13-81 by: DMR & JF
Date: _____ by: _____
Date: _____ by: _____

INSTALLATION FINAL WRITTEN APPROVAL
Date: 11-16-81 By: Ron Margnart

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

5-0477
ORPTION TEST DATA REPORT
to Application)
rence: City Ordinance No. 9150 and
County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

**B**

FILE NO. _____

PROPERTY WHERE SOIL TESTED: 6101 Rebel

Location: Township 9N ; Range 7E ; Section & ¼ Section 28 .
Property Dimensions: _____ ft. x _____ ft. Area: _____ acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☑ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 10-21-81 to 10-22-81 . Weather: Precip. _____ Temp. _____ .

OWNER: Brian Darcy c/o Pettyco Inc.
Address: P.O. Box 2521 Lincoln Ne.

PERCOLATION TEST DATA TABLE

| a. | b. | c. | d. | e. | f. | g. | h. | i. | j. | k. | l. | m. | n. |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | Pre-Saturation Period | | | | Percolation Readings | | | | | | Results | |
| | | Start | | End | | Start | | | End | | | | |
| Hold No. | Hole Depth (in.) | Date (Mo./ Day) | Time (Hr./ Min.) | Date (Mo./ Day) | Time (Hr./ Min.) | Date (Mo./ Day) | Time (Hr./ Min.) | Water Level (in.) | Time (Hr./ Day) | Water Level (in.) | Elapsed Time (Min.) | Water Level Drop (in.) | Percolation Rates (Min./in.) |
| 1 | 32" | 10/21 | 9:00 | 10/22 | 8:00 | 10/22 | 1:20 | 4¼" | 1:50 | 3⅜" | 30 | ⅞" | |
| 2 | 34" | | | | | | 1:20 | 5" | 1:50 | 4¼" | 30 | ¾" | |
| 3 | 34" | | | | | | 1:25 | 5½" | 1:55 | 4⅜" | 30 | ⅝" | |
| 4 | 32" | | | | | | 1:25 | 6" | 1:55 | 5⅛ | 30 | ⅞" | |
| 5 | 35" | | | | | | 1:30 | 3½ | 2:00 | 2½ | 30 | 1" | |
| 6 | 34" | | | | | | 1:30 | 4¾ | 2:00 | 3¼" | 30 | 1½" | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Don Darcy & Pettyco Plbg.
Signature of Person Conducting Test

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

Address P.O Box 2521 Lincoln Ne. Phone 423-0121

(Do not write below this line)

REVIEWING ACTION

Remarks: _____
Soil Type (SCS): _____
Date: _____

Approved Percolation Rate (a)
A. 32 min./inch
B. _____ min./inch
C. _____ min./inch

_____
Signature of Reviewing Official

0102-0477
LIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☑
County Resolution No. 2832 ☐


LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

**C**

Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.

FILE NO._____

Indicate on sketch if residence and well are exisiting or proposed.




REVIEWING ACTION

Remarks :_____


_____

Date:_____

Minimum Design Requirement
1. Capacity of Septic Tank_____gals.
2. Total Length of Laterals_____ft.
3. With a Trench Width of_____in.
4. Total Area of Lateral needed____sq.ft.

_____
Signature of Reviewing Official

6101 Rebel Rd - Darcy Constr.
1000gal Tank - 300' Perf. Lateral




Corraglass Tank -
4" PVC Bldg. Sewer
4" PVC Perf. Plastic