FILE NO. 1975

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

OCTOBER 20, 1983 — THIS LICENSE OR PERMIT EXPIRES

BIGGERSTAFF PLUMBING — LICENSEE OR PERMITTEE

3605 NORTH 40TH STREET LINCOLN NE 68504 — ADDRESS

T9N, R7E, SECTION 28, BLOCK 3, LOT 5 YANKEE HILL ADDITION — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NONTRANSFERABLE NEW

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 60.00	$	$	$	$ 60.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
018754	XXXXX	XXXXX	XXXXX

SERIAL NO.	DATE	AMOUNT
	10.16	148.14

6-2

HEALTH
APPLICATION

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $ 60.00

FILE NO. 1975

DATE: _____

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section 28 ;
   Block 3 : Lot 5 : Addition YANKEE RIDGE
   Street Address _____

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft.

Doug Burnhill
Signature of Applicant (Owner or Lessee)

3605 N. 40 68504
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 4/20/83. Date Frwd. 4/20/83. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Wood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 4/20/83. Date Frwd. _____. ACTION: Approved ☒ Disapproved ☐ Signature: Gary M. Shewder

3. City or County Engineer: Date Rec'd. 4/20/83. Date Frwd. 4/20/83. ACTION: Approved ☒ Disapproved ☐ Signature: Dennis D. Bartels

REMARKS OR REASONS FOR DISAPPROVAL _____


Site Visits:
Date: 6/9/83 by: J. C. H.
Date: _____ by: _____
Date: _____ by: _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

INSTALLATION FINAL WRITTEN APPROVAL
Date: 8/24/83 By: Jerrold C. Wood

FORM 20102-0477 PRELIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application) City Ordinance No. 9150 ☒ County Resolution No. 2832 ☐	LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT Division of Environmental Health 2200 St. Marys Avenue Lincoln, Nebraska 68502 Phone: 471-7800 **C**
Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.	FILE NO._____

Indicate on sketch if residence and well are exisiting or proposed.



REVIEWING ACTION

Remarks :_____

Date: April 20, 1983

Minimum Design Requirement
1. Capacity of Septic Tank 1000 gals.
2. Total Length of Laterals 168 ft.
3. With a Trench Width of 48 in.
4. Total Area of Lateral needed 641 sq.ft.

Jerrold C. Hood
Signature of Reviewing Official

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

D

DATE: _____

FILE NO. _____


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material PVC; Diameter 4" in.
2. Distance above basement floor _____ in., or below basement floor 38 in.
3. Distance between dwelling and septic tank 50 ft.
4. Number of clean-outs —.
5. Distances to:
Well or Suction Line _____ ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

B. SEPTIC TANK:
1. Material Pre Cast; No. of compartments _____.
2. Capacity 1000 gals.;
3. Factory Built: Yes ☒ No ☐
(Company _____)
4. Manholes: Over Inlet; diam. _____ in.
Over Outlet; diam. _____ in.
Riser Above ☐ Below ☐ Grade ___ in.
5. Inlet: Baffle ☐ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☐
7. Depth of top of tank below finished grade 12" in.
8. Distances to:
Well or Suction Line _____ ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

C. DISTRIBUTION BOX:
1. Material Pre Cast; Number - available outlets _____.
2. Factory Built: Yes ☒ No ☐
(Company _____)
3. Distance from Septic Tank 7' ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☐ Perforated Pipe ☒
Diameter of Half Round _____ or Perforated Pipe 4" .
Material: fiberglass ☐ ; plastic ☑ ; concrete ☐ ; other _____.
2. Lateral Lines:
Number 3 ; Length of each line 100, 100, 15, _____, _____ ft.;
Total length of laterals 215 ft.;
Distance between lateral lines 6'-10" ft.
3. Trench dimensions: Width 36" ft.;
Slope 3 in/100 ft.; Average Depth 30" in.
4. Filter Material: Road Gravel
Depth of Material 18" in.
5. Distances to:
Well or Suction Line 100' ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St. Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 8-25-89

☒ Evaluation of the Sewage Disposal System ☐ Enclosed is $75.00

Legal Description of Property: TWP. 9N; RANGE 7E; SECTION 28; BLOCK 3

LOT 5; ADDITION YANKEE RIDGE ESTATES; Street Address 9141 So. 63rd

Directions to Property go south on 56th - 3miles from Hgw 2 - to Rebel Drive (½ mile south of Yankee Hill Rd) go east on Rebel Drive to 63rd - turn south 1st house on West side

Location of Well southeast corner of house Tap Location: Inside ☐ Outside ☒

Location of Sewage System West of back of house Year Installed 1983

	NAME	ADDRESS	PHONE
Present Owner:	Manuel + Jeri Herrera	9141 S. 63rd	421-2026
Tenant/Buyer:	" "	" "	work 488-2388
Return to:	" "	" "	" "

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Jeri Herrera Address 9141 S. 63rd Lincoln 68502

==========

HEALTH DEPARTMENT USE ONLY

Date Received 8-25-89 Received $75.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE 8-28-89

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☒	☐	Approved:	☒	Date 8-28-89 by [illegible]
Bacteria	☒	☐	Provisional:	☐	Date _____ by ____
Nitrate	☒	☐	Disapproved:	☐	Date _____ by ____

Comments: Owner has said they have pumped septic tank. Recommend pumping tank about every 2-3 years.

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☒	Approved: ☒	Provisional Approval: ☐

APPROVED BY Donald E. Nagel, R.S. DATE AUGUST 31, 1989

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832