FILE #2238

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

FEBRUARY 16, 1986 — THIS LICENSE OR PERMIT EXPIRES

LYLE THOMPSON — LICENSEE OR PERMITTEE

5138 LOCUST, LINCOLN, NE 68516 — ADDRESS

T9N; R7E; Sec 28; Bk 5; Lot 1; Yankee Ridge Estates; So. 63rd — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NON TRANSFERABLE NEW CONSTRUCTION

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 60.00	018606	$ 60.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. Date and Amount

APPLICATION

HEALTH

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

A

FILING FEE: $ 60 00

FILE NO. 2238

DATE: 6-25-85

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section 28 ;
   Block 5 : Lot 1 : Addition Yankee Digger Estates
   Street Address 9200 S 63rd

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: over ft.

Lyle Thompson & Paulsen-Gillam
Signature of Applicant (Owner or Lessee)

5138 Locust
Address

68516

(Do not write below this double line)

1. Health Department: Date Rec'd. Aug-16-85 . Date Frwd. Aug-16-85 . ACTION: Approved ☒ Disapproved ☐ Signature: Ron Margrave

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 8/19/85 . Date Frwd. 8/19/85 . ACTION: Approved ☐ Disapproved ☐ Signature:

3. City or County Engineer: Date Rec'd. 8-19-85 . Date Frwd. 8-19-85 . ACTION: Approved ☒ Disapproved ☐ Signature: Ramin Pazdar

REMARKS OR REASONS FOR DISAPPROVAL

Site Visits:
Date: 10-10-85 by: (Lic + tank)
Date: 10-11-85 by: (rest + sewer)
Date: by:

INSTALLATION FINAL WRITTEN APPROVAL
Date: 10-18-85 By: Ron Margrave

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

B

FILE NO. 2238

PROPERTY WHERE SOIL TESTED:

Location: Township 9N ; Range 7E ; Section & ¼ Section 28 SW¼
Property Dimensions: _____ ft. x _____ ft. Area: 3 acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☒.
Dates of Tests: 6-24-85 to 6-25-85. Weather: Precip. 0 Temp. 96.

OWNER: Kyle Thompson
Address: 5138 Locust
489-7282
68516

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	36"	6-24	5:30 PM	6-25	1:30 PM	6-25	1:30 PM	16"	6:00 P.M.	14¼	60m	1¾	60m. 1¾
2	"	"	"	"	"	"	"	"	"	15	"	1	1
3	"	"	"	"	"	"	"	"	"	15	"	1	1
4	"	"	"	"	"	"	"	"	"	14⅞	"	1⅛	1⅛
5	"	"	"	"	"	"	"	"	"	14	"	2	2
6	"	"	"	"	"	"	"	"	"	15	"	1	1
7	"	"	"	"	"	"	"	"	"	14¼	"	1¾	1¾
8	"	"	"	"	"	"	"	"	"		"		

Paul van Gilderen Pager 790-9162
Signature of Person Conducting Test

Address 18100 N 1st Phone 785-7755

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

(Do not write below this line)

REVIEWING ACTION

Remarks: _____
Soil Type (SCS): Wymore Silty Clay Loam
Date: July 1, 1985

Approved Percolation Rate (a)
A. 51 min./inch
B. _____ min./inch
C. _____ min./inch

Jerrold C. Hood
Signature of Reviewing Official

For Lyle Thompson

10-8-85



Installer

Paul von Gillern

von Gillern Trenching

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

RECEIVED MAR 0 4 1992

2200 St Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 3-1-92

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 7E; SECTION 28; BLOCK 5

LOT 1; ADDITION Yankee Ridge; Street Address 9200 S. 163 Lincoln, NE

Directions to Property 2½ miles south of 56th & Hyw 2 turn on Rebel Dr. go east to 163rd st turn south. brown house east side

Location of Well North of house Tap Location: Inside ☒ Outside ☒

Location of Sewage System East of house Year Installed 1985

	NAME	ADDRESS	PHONE
Present Owner:	Lyle & Donna Thompson	9200 S 163	423-3702
Tenant/Buyer:	none		
Return to:	Lyle & Donna Thompson	9200 S. 163 Lincoln NE 68516	

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Donna J. Thompson Address 9200 S 163

==========

HEALTH DEPARTMENT USE ONLY

Date Received MARCH 4, 1992 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE 3-5-92

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☒	☐	Approved:	☒	Date 3-5-92 by PD
Bacteria	☒	☐	Provisional:	☐	Date ____ by ____
Nitrate	☒ 0.2ppm	☐	Disapproved:	☐	Date ____ by ____

Comments: Only one cleanup at surface level. Septic tank pumped out in past year – P.D.

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☒	Approved: ☒	Provisional Approval: ☐

APPROVED BY March 9, 1992 Paul B Thompson DATE 3-9-92

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

FILE #W-116

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL WATER WELL CONSTRUCTION — TYPE OF LICENSE OR PERMIT

FEBRUARY 20, 1986 — THIS LICENSE OR PERMIT EXPIRES

DONNA J. THOMPSON, 9300 SO. 63 STREET, MAIL: 5138 LOCUST, LINCOLN, NE 68516 — LICENSEE OR PERMITTEE / ADDRESS

T9N; R7E; Sec 28, Bk 5; Lot 1; Yankee Ridge Estates — NAME OF ESTABLISHMENT, IF ANY / ADDRESS

REMARKS: NON TRANSFERABLE NEW CONSTRUCTION

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 45.00	019851	$ 45.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. — Date and Amount

45

APPLICATION

HEALTH

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM: 20222-0483
REQUEST FOR SITE CLEARANCE AND PERMIT FOR INDIVIDUAL WATER WELL

LINCOLN LANCASTER COUNTY HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL HEALTH
2200 ST. MARYS AVENUE
LINCOLN, NEBRASKA 68502
PHONE: 471-7800

FILING FEE $45.00

FILE NO. W-116

DATE: 8-20-85

The undersigned hereby requests: Site Clearance and Permit to construct a new individual water well ☒ ; Permit existing well ☐ ; well repair or alteration involving opening of well ☐ ; in conformance with appropriate ordinance, as described herein:

1. Legal description of property: Twp. ~~T9N~~ T9N : Range R7E : Section 28
   Block 5 : Lot 1 : Addition Yankee Ridge Estates
2. Well use: Residential ☒ ; Commerical ☐ ; Other Use ☐
   Describe new house
3. Distance to Public Water Supply: ____ Ft.
4. Intended use of well Residential use

Donna J Thompson
Signature of Applicant (owner or lessee)

(9300 S. 63)
Address
mail to: 5138 Locust
Lincoln NE 68516

Sewage Permit Applied For Yes ☒ No ☐ Not Applicable ☐

1. Health Department: Date Rec'd 8/20/85. Date Frwd. 8/20/85. Action: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood
2. Supt. Bldg. Insp.: Date Rec'd 8/20/85. Date Frwd. 8/20/85. Action: Approved ☒ Disapproved ☐ Signature: Gary N. Shewak
3. City or County Engineers: Date Rec'd 8/20/85. Date Frwd. 8/20/85. Action: Approved ☒ Disapproved ☐ Signature: Jerome D. Obrist

REMARKS OR REASONS FOR DISAPPROVAL

Site Visits:
Date: 11/25/85 by L.C.H.
Date: ____ by ____
Date: ____ by ____

Nitrate Level <0.1 PPM
Bacteriological Analysis Satisfactory
Yes ☒ No ☐

INSTALLATION FINAL WRITTEN APPROVAL
Date: 11/26/85 By: L. C. Hood

Health Department copy: White
Engineers Copy: Light Green
Building Inspectors Copy: Light Blue

FORM 23-13

FORM: 20223-0483
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL WATER WELL
CITY ORDINANCE NO. 13558
FILE NO. W-116

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL HEALTH
2200 ST. MARYS AVENUE
LINCOLN NE 68502
Phone: 471-7800

DATA SHEET FOR WATER WELLS

Legal Description: Sec. 28 T. 9N R. 7E Block 5 Lot 1 Addition Yankee Ridge

Owner Lyle Thompson Address

LOG OF WELL	
	Description
Depth Ft. to	top Soil
1 - 94	yellow to grey
94-110	blue clay
110-165	sod, yellow, grey layers
165-	layers of Sandstone
225	in clays
225-235	white clay & Sandstone
235-250	90% Sandstone
250-255	Hard layer clay
255-267	Gravel
267-277	lime shale, Sandstone
	Grey & white clays
Stop Casing at 266	

WELL COMPLETION RECORD

Drilling Method: Rotary

Depth (from ground level), Ft. 266'
Date Completed 10-31-85

Casing: Length, Ft. 266; Dia.In. 4"
Wall Thickness, Inc. 160; type PVC

Screen: Length, Ft. 30 Dia.In. 4
Type PVC, slot Size .032

Drop Pipe: Length, Ft 220 Dia.In. 1¼

Water Level, Surface to top of water, Ft.:
Static 149, Pumping 190

Yield: 25 ggm, Measured ☒, Est. ☐
Chlorination Completed Yes ☒ No ☐

The above information including "Log of Well" is a true record of the job performed by me.

Driller Keith Meacham
(Signed)

REMARKS NITRATE NITROGEN < 0.1 ppm
BACTERIOLOGICAL O.K.

Address 7331 Vine St

Date 10-31-85

DO NOT WRITE BELOW THIS DOUBLE LINE

Health Department forwarded copy of record to Nebraska Conservation and Survey Department for Scientific Record ☒

FORM 23-4

AS BUILT DRAWING OF INSTALLATION IN RELATION TO BUILDINGS, PROPERTY LINES, OTHER WELLS, AND SOURCES OF CONTAMINATION. INDICATE NORTH.



