FILE #2504

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

NOVEMBER 19, 1987 — THIS LICENSE OR PERMIT EXPIRES

TERRY ZIMMERMAN — LICENSEE OR PERMITTEE

3300 SERENITY CIR., APT #10 LINCOLN, NE 68516 — ADDRESS

T9N; R7E; Sec 28; Bk 6; Lot 2; Yankee Ridge Estl; 9150 So. 66 Street — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NON TRANSFERABLE NEW CONSTRUCTION

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 60.00	018754	$ 60.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. Date and Amount

APPLICATION

HEALTH

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

A

FILING FEE: $ 60.00

FILE NO. 2504

DATE: 5-19-87

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section 28 ;
   Block 6 : Lot 2 : Addition Yankee Ridge Estates
   Street Address 9150 South 66th Street

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe

3. Type of Individual Sewage Disposal System: Septic Tank ☒ * ; Other ☐

4. Distance to public sewer: — ft. (note not needed)

* Owner will use the "Experimental Sewage Disposal System"

Terry J. Zimmerman
Signature of Applicant (Owner or Lessee)

3300 Serenity Circle Apt #10
Address
Lincoln Nebraska 68516

(Do not write below this double line)

1. Health Department: Date Rec'd. 5/19/87. Date Frwd. 5/19/87. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 5/20/87. Date Frwd. 5/20/87. ACTION: Approved ☒ Disapproved ☐ Signature: Gary N. Shenwood

3. City or County Engineer : Date Rec'd. 5/20/87. Date Frwd. 5/20/87. ACTION: Approved ☒ Disapproved ☐ Signature: Dennis D Bartels

REMARKS OR REASONS FOR DISAPPROVAL PRE-EXISTING WELL

Site Visits:
Date: 9/1/87 by: J. C. Hood
Date: by:
Date: by:

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

INSTALLATION FINAL WRITTEN APPROVAL
Date: 11/2/87 By: Jerrold C. Hood

FORM 23-43

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800 JUN 1 1 1987

B

FILE NO. _____

PROPERTY WHERE SOIL TESTED: Yankee Ridge Estates

Location: Township T9N ; Range R7E ; Section & ¼ Section 28 .
Property Dimensions: _____ ft. x _____ ft. Area: _____ acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☒ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ . Sharpsburg
Dates of Tests: 6 - 6 to 6-7-87 . Weather: Precip. -0- Temp. 80's.

OWNER: Terry Zimmerman 423-7963
Address: 4821 Huddersfield Ct. Lincoln, Ne 68516

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	36	6/6	7:00	6/7	6:00	6/7	6:30	16 5/8	7:00	18 3/8	30	1 3/4	
2			AM		AM			22 1/4		23 1/8		7/8	
3								26 1/4		27		3/4	
4								22 7/8		23 1/2		5/8	
5								19		19 7/8		7/8	
6								26 1/2		27 3/8		7/8	
7								26 3/8		18 1/8		1 1/4	
											7	6 3/8	
												.91	

Brad Southwick
Signature of Person Conducting Test

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

Address 701 E 4 Hudson Phone 792-2462

(Do not write below this line)

REVIEWING ACTION

Remarks: _____
Soil Type (SCS): Sharpsburg silty Clay Loam
Date: June 11, 1987

Approved Percolation Rate (a)
A. 30 min./inch
B. _____ min./inch
C. _____ min./inch

Gerald C. Hoos
Signature of Reviewing Official

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

D

DATE: 9-1-87

FILE NO. _____

Terry Zimmerman 9250 S. 66
Yanke Ridge Estates


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material PVC ; Diameter 4 in.
2. Distance above basement floor ____ in., or below basement floor 9 in.
3. Distance between dwelling and septic tank 117 ft.
4. Number of clean-outs 2 .
5. Distances to:
Well or Suction Line NA ft.; Stream NA ft.; Pressure Line NA ft.; Property Line NA ft.

B. SEPTIC TANK:
1. Material Fiberglass; No. of compartments 1 .
2. Capacity 1000 gals.;
3. Factory Built: Yes ☒ No ☐
(Company Corr A Glas)
4. Manholes: Over Inlet; diam. 10 in.
Over Outlet; diam. 10 in.
Riser Above ☐ Below ☐ Grade ____ in.
5. Inlet: Baffle ☒ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☒
7. Depth of top of tank below finished grade 24-14 in.
8. Distances to:
Well or Suction Line NA ft.; Stream NA ft.; Pressure Line NA ft.; Property Line 60 ft.

C. DISTRIBUTION BOX:
1. Material Plastic ; Number - available outlets 7 .
2. Factory Built: Yes ☒ No ☐
(Company _____)
3. Distance from Septic Tank 8 ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☒ Perforated Pipe ☐
Diameter of Half Round 12" or
Perforated Pipe _____.
Material: fiberglass ☒ ; plastic ☐ ; concrete ☐ ; other _____.
2. Lateral Lines:
Number 2 ; Length of each line 100 , 96 , ____ , ____ , ____ ft.;
Total length of laterals 196 ft.;
Distance between lateral lines 10 ft.
3. Trench dimensions: Width 4 ft.;
Slope 4 in/100 ft.; Average Depth 38 in.
4. Filter Material: Road Gravel
Depth of Material 18 in.
5. Distances to:
Well or Suction Line NA ft.; Stream NA ft.; Pressure Line NA ft.; Property Line 60 ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

OC

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 4-30-92

☒ Evaluation of the Sewage Disposal System ☑ Enclosed is $~~75.00~~ $150.00

Legal Description of Property: TWP. 9 ; RANGE 7 ; SECTION 28 ; BLOCK 6

LOT 2 ; ADDITION ~~Yankee Ridge~~ Estates ; Street Address 9150 S. 66th St.

Directions to Property Call borrower (owner)

Location of Well _____ Tap Location: Inside ☐ Outside ☐

Location of Sewage System _____ Year Installed _____

	NAME	ADDRESS	PHONE
Present Owner:	Terrence & Karen Zimmerman	9150 S. 66th St	423-7963 Home
Tenant/Buyer:			489-8858 Work Terry
Return to:			

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Rhonda S Dowd SECURITY FEDERAL Address 1330 N St.

==========

HEALTH DEPARTMENT USE ONLY $150.00

Date Received 5-6-92 Received $~~75.00~~ Check ☑ Cash ☐

PRELIMINARY STATUS--DATE 5-4-92

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☒	☐	Approved:	☒	Date 5-4-92 by P.D
Bacteria	☒ 5-7-92 P.D.	☐	Provisional:	☐	Date _____ by _____
Nitrate	<0.1 ppm ☒ PD	☐	Disapproved:	☐	Date _____ by _____

Comments: Septic tank should be pumped out if not done in the past two years.

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☒	Approved: ☒	Provisional Approval: ☐

APPROVED BY Paul Prasmann DATE 5-8-92

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

AS BUILT DRAWING OF SYSTEM

DATE 9-2-87 INSTALLER Southwick Sewer & Drain

