FILE NO. 363

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

May 1, 1974 — THIS LICENSE OR PERMIT EXPIRES

Colonial Company — LICENSEE OR PERMITTEE

7140 South 7[illegible] Street — ADDRESS

T9N; R7E; Sec. 29; Bl. 1; Lot 1; Tower Acr[illegible] Add. — NAME OF ESTABLISHMENT, IF ANY

LEGAL DESCRIPTION — ADDRESS

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
624-1535 110.15	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-30(67) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 363

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described herein:

1. Legal description of property: Twp. 9N; Range 7E; Section 29;
Block 1; Lot 1; Addition TOWER ACRES
Street Address _____.

2. Property Use: Residential _____ ☒; Commercial _____ ☐
No. of Bedrooms 3. Describe: _____
Other Use _____ ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Distance to public sewer: _____ ft.

Roger Bailey For
Signature of Applicant (owner or lessee)
Colonial Co
7140 S 75
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 10/31/73. ACTION: Approved ☒ Disapproved ☐
Date Frwd. 10/31/73. Signature: Jerrold C. Head

2. Supt. Bldg. Insp.: Date Rec'd. 10-31-73. ACTION: Approved ☒ Disapproved ☐
Date Frwd. 10-31-73. Signature: Charles Boy By Bill Brooks

3. Dep. City Engineer: Date Rec'd. 10-31-73. ACTION: Approved ☒ Disapproved ☐
Date Frwd. " . Signature: J. L. Blessing

REMARKS OR REASONS FOR DISAPPROVAL _____

FINAL ACTION ON SITE CLEARANCE: Approved ☐ Disapproved ☐

Date Applicant Notified: _____ Signature _____

FORM HD-32(67) APPLICATION FOR PERMIT
TO CONSTRUCT INDIVIDUAL SEWAGE
DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. _____

DATE: _____

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 9N; Range 7E; Section 29;
Block 1; Lot 1; Addition TOWER ACRES
Street Address _____.

2. Property Use: Residential _____ [X]; Commercial _____ [ ]
No. of Bed Rooms 3 Describe: _____

Other Use _____ [ ]
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-32a(67) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT, attached hereto.)

Roger Bailey For
Colonial Co
Signature of Applicant (owner or lessee)

7140 S 75
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Date Site Clearance _____

3. Site Visits:
Date: 11/2/73 by: J.C.H.
Date: _____ by: _____
Date: _____ by: _____

4. Date: Approved [X]; Disapproved [ ]: 10/31/73
by: Jerrold C. Hood R.S.

5. BUREAU OF LICENSES & PERMITS
Date Notified: _____
Date Issued: _____ Serial _____

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 11/2/73 by: Jerrold C. Hood

FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. _____

PROPERTY WHERE SOIL TESTED:
Location: Township 9N 7E
Section & ¼ Sect. 29
Property Dimensions: ____ft. x ____ ft.
Area: _____acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☐; Sandy Clay ☐

Owner: Colonial Co.
Address 7140 S 75

Dates of Tests: _____ to _____. Weather: Precip. ____ Temp. ____ F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	38	10/24/73	8:00	10/24/73	8:40	10/24/73	8:40	10	8:30		1 hr	1	
2												2	
3												1½	
4												1¾	
5												2	
6												2	

Sum of Percolation Rates _____
Average of Rates: _____
Mean of Rates: _____

Ryan Bailey
Signature of Person Conducting Test

Address 4131 Cliff Ford Dr
Phone: 489 8208

(Do not write below this line)

REVIEWING ACTION

REMARKS: _____

Approved Percolation Rate(s)
A. 37 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: October 31, 1973

Jerrold C. Hood
Signature of Reviewing Official

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. _____

SPECIFICATIONS

DATE: OCT 29


A. BUILDING SEWER:
1. Material PLASTIC; Diameter 4 in.
2. Distance above basement floor ___ in.; or below basement floor ___ in.
3. Distance between dwelling and septic tank 1238" ft.
4. Number of clean-outs 2.
5. Distances To:
Well or Suction Line 50 ft.;
Stream — ft.; Pressure Line — ft.;
Property Line — ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material FIBERGLASS; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth 48 in.
3. Factory Built: Yes ☒ (Company CORRUGATED FIBERGLASS) No ☐
4. Manholes: Over Inlet; diam. ___ in.
Over Outlet; diam. ___ in.
Below Grade 24 in.
5. Inlet: Baffle ☒; or Tee ☐
6. Outlet: Baffle ☒; or Tee ☐
Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade ___ in.
8. Distances To:
Well or Suction Line 200 ft.;
Stream — ft.; Pressure Line — ft.;
Property Line ___ ft.

C. DISTRIBUTION BOX
1. Material CON; No. available outlets 5.
2. Factory Built: Yes ☒, (Company PRE-CAST STEP) No ☐
3. Dimension: Length ___ in.; Width ___ in. Depth ___ in.
4. Distance from Septic Tank 5'11" ft.
5. Serial Distribution: Yes ☐, No ☒ (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: HALF Round
2. Lateral Lines: Depth below grade ___ in.
Number 3; Length of each line 100 ft 99'10"
Total length of Laterals 208 ft.;
Slope 6 in/100 ft. Diameter of pipe 16 in.; Shape —
Material: concrete ☐; fiber asbestos ☐; clay ☐; other ___
Distance between lateral lines 7 ft.
3. Trench Dimensions: Depth ___ in.; Width 48 in.
4. Filter Material: Gravel.
Depth of material from trench bottom ___ in.
5. Distances To:
Well or Suction Line 200+ ft.;
Stream — ft.; Pressure Line — ft.
Property Line — ft.
6. Percolation Rate: _____ minutes/inch

TYPICAL SKETCHES



SEPTIC TANK

Rick Bailey
Signature of Applicant

WELL
26'
GARAGE
HOUSE
2'
103'10"
C. CLEANOUT
19'10"
5'11"
7'
99'
100'
10'
W
S
N
E