FILE NO. 346

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

February 3, 1974 — THIS LICENSE OR PERMIT EXPIRES

Robert Fuller — LICENSEE OR PERMITTEE

3245 South 44th — ADDRESS

T9N; R7E; Section 29; Block 3; Lot 1; Tower Acres — NAME OF ESTABLISHMENT, IF ANY

LEGAL DESCRIPTION — ADDRESS

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
110.15 624-1535	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-30(67) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 346

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described herein:

1. Legal description of property: Twp. 9N; Range 7E; Section 29;
Block 3; Lot 1; Addition _____;
Street Address TOWER ACRES

2. Property Use: Residential ☒; Commercial ☐
No. of Bedrooms 2. Describe: _____
Other Use ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Distance to public sewer: _____ ft.

Robert Fuller
Signature of Applicant (owner or lessee)

3245 SOHH
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 8/3/73. Date Frwd. 8/3/73.
ACTION: Approved ☒ Disapproved ☐
Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 8/3/73. Date Frwd. _____.
ACTION: Approved ☒ Disapproved ☐
Signature: Chas Seale By R.S.

3. City Engineer: Date Rec'd. 8/3/73. Date Frwd. _____.
ACTION: Approved ☒ Disapproved ☐
Signature: [illegible]

REMARKS OR REASONS FOR DISAPPROVAL _____

FINAL ACTION ON SITE CLEARANCE: Approved ☒ Disapproved ☐

Date Applicant Notified: 9-7-73 Signature James Wenda

FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 346

PROPERTY WHERE SOIL TESTED:
Location: Township 9N
Section & ¼ Sect. 29-7E
Property Dimensions: 360 ft. x 631.6 ft.
Area: 5 acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☐; Sandy Clay ☐

Owner: Robert Fuller
Address 3245 So. 44

Dates of Tests: 7-28-73 to 7-29-73. Weather: Precip. None Temp. 80's F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
Hole No.	Hole Depth (in.)	Pre-Saturation Period Start Date (Mo. Day)	Start Time (Hr. Min.)	End Date (Mo. Day)	End Time (Hr. Min.)	Percolation Readings Start Date (Mo. Day)	Start Time (Hr. Min.)	Start Water Level (in.)	End Time (Hr. Min.)	End Water Level (in.)	Results Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	36"	7-28	10:30	7-29	11:00	7-29	11:00	6"	3:00	5 ¼	30	¾"	40
2	36"	7-28	10:30	7-29	11:00	7-29	11:00	6"	3:00	5	30	1	30
3	36"	7-28	10:30	7-29	11:00	7-29	11:00	6"	3:00	5	30	1	30
4	36"	7-28	10:30	7-29	11:00	7-29	11:00	6"	3:00	5 ½	30	½	60
5	36"	7-28	10:30	7-29	11:00	7-29	11:00	6"	3:00	5	30	1	30
6	36"	7-28	10:30	7-29	11:00	7-29	11:00	6"	3:00	5 ¼	30	¾	40

Sum of Percolation Rates 230
Average of Rates: 38.3
Mean of Rates: 30

Robert Fuller
Signature of Person Conducting Test

Address 3245 So. 44th
Phone: 488-7565

(Do not write below this line)

REVIEWING ACTION

REMARKS:

Approved Percolation Rate(s)
A. 37 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: August 3, 1973

Jerrold C. Hood
Signature of Reviewing Official

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 346

SPECIFICATIONS

DATE: 7-31-73


A. BUILDING SEWER:
1. Material Tile; Diameter 4 in.
2. Distance above basement floor ___ in.; or below basement floor 12 in.
3. Distance between dwelling and septic tank 40 ft.
4. Number of clean-outs 1.
5. Distances To:
Well or Suction Line 150 ft.;
Stream ___ ft.; Pressure Line ___ ft.;
Property Line 170 ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material CONCRETE No. of compartments 1.
2. Capacity 1,000 gals.; Liquid depth ___ in.
3. Factory Built: Yes ☒ (Company PRECAST) No ☐
4. Manholes: Over Inlet; diam. 0 in.
Over Outlet; diam. 0 in.
Below Grade 24 in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☒
Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade 24 in.
8. Distances To:
Well or Suction Line 170 ft.;
Stream ___ ft.; Pressure Line ___ ft.;
Property Line 170 ft.


C. DISTRIBUTION BOX
1. Material CONCRETE No. available outlets 4.
2. Factory Built: Yes ☒, (Company PRECAST) No ☐
3. Dimension: Length ___ in.; Width ___ in. Depth ___ in.
4. Distance from Septic Tank 10 ft.
5. Serial Distribution: Yes ☐, No ☐ (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: CONCRETE 1/2 Tile
2. Lateral Lines: Depth below grade 24 in. Number ___; Length of each line ___ ft Total length of Laterals 139 ft.; Slope ~~104~~ in/100 ft. Diameter of pipe 12 in.; Shape ___
Material: concrete ☒; fiber asbestos ☐; clay ☐; other ___
Distance between lateral lines ___ ft.
3. Trench Dimensions: Depth 42 in.; Width 48 in.
4. Filter Material: GRAVEL.
Depth of material from trench bottom 20 in.
5. Distances To:
Well or Suction Line 185 ft.;
Stream ___ ft.; Pressure Line ___ ft.
Property Line 170 ft.
6. Percolation Rate: 38.3 minutes/inch

TYPICAL SKETCHES



Robert Fuller
Signature of Applicant



James Wevaka

9-7-73