LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 645-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF PERMIT

December 18, 1975
THIS PERMIT EXPIRES

Richard Doetker
ISSUED TO

Route #1, Roca, Nebraska
ADDRESS

T9N; R7E; Sec. 31;
LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
624-1535	110.16	148.14	6-2
RECEIPTED BY	DATE	AMOUNT	

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 645-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: _____

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section 31
   Block _____; Lot _____; Addition _____
   Street Address _____

2. Property Use: Residential _____ ☒ ; Commercial _____ ☐
   No. of Bedrooms 3 . Describe: _____
   Other Use _____ ☐
   Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft.

Richard Doetker
Signature of Applicant (Owner or Lessee)

RR 1 Roca, Nebraska
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 6/18/75 . Date Frwd. 6/18/75 . ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. _____ . Date Frwd. _____ . ACTION: Approved ☐ Disapproved ☐ Signature: Dave O'Dell

3. City or County Engineer : Date Rec'd. 6-19-75 . Date Frwd. 6-19-75 . ACTION: Approved ☑ Disapproved ☐ Signature: Henry Graff Deputy

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 645-C

DATE: _____

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 9N ; Range 7E ; Section 31 ; Block _____ ; Lot _____ ; Addition _____.
Street Address _____.

2. Property Use: Residential _____ ☒; Commercial _____ ☐
No. of Bedrooms 3
Describe: _____
Other Use _____
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Richard Dalton
Signature of Applicant (owner or lessee)

RR 1 Roca, Nebr.
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd; _____
Filing Fee: $ 30.00

2. Site Visits:
Date: 12-3-75 by: jw
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒; Disapproved ☐ 6/18/75
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 12-3-75 by: James Weverka

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 645-C

SPECIFICATIONS

DATE: _____


A. BUILDING SEWER:
1. Material CAST IRON & TILE; Diameter 4 in.
2. Distance above basement floor ___in.; or below basement floor ___in.
3. Distance between dwelling and septic tank ___ft.
4. Number of clean-outs _____.
5. Distances To:
Well or Suction Line ___ft.;
Stream ___ft.; Pressure Line ___ft.;
Property Line ___ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material CONCRETE; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth ___in.
3. Factory Built: Yes ☒ (Company PRE-CAST
No ☐
4. Manholes: Over Inlet; diam. 6 in.
Over Outlet; diam. 6 in.
Below Grade _____in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☒; or Tee ☐
Depth of outlet below inlet ___in.
7. Depth of top of tank below finished grade ___in.
8. Distances To:
Well or Suction Line ___ft.;
Stream ___ft.; Pressure Line ___ft.;
Property Line ___ft.

C. DISTRIBUTION BOX
1. Material CON; No. available outlets 5.
2. Factory Built: Yes ☒, (Company PRE-CAST STEP No ☐
3. Dimension: Length ___in.; Width ___in. Depth ___in.
4. Distance from Septic Tank ___ft.
5. Serial Distribution: Yes ☐, No ☒ (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: HALF MOON
2. Lateral Lines: Depth below grade ___in. Number 2; Length of each line ___ft Total length of Laterals 136 ft.; Slope 4 in/100 ft. Diameter of pipe 24 in.; Shape C
Material: concrete ☒; fiber asbestos ☐; clay ☐; other _____
Distance between lateral lines ___ft.
3. Trench Dimensions: Depth ___in.; Width 48 in.
4. Filter Material: GRAVEL.
Depth of material from trench bottom ___in.
5. Distances To:
Well or Suction Line ___ft.;
Stream ___ft.; Pressure Line ___ft.
Property Line ___ft.
6. Percolation Rate: _____minutes/inch

TYPICAL SKETCHES



Signature of Applicant


EXHIBIT "A"

Legal Description of Property:

A tract of land in the SW 1/4 of Section 31, T9N, R7E of the 6th P.M., more particularly described as follows:

Beginning at the northwest corner of the southwest quarter of Section 31, T9N, R7E; thence easterly along the north line of the SW 1/4 of said Section 31, a distance of 794.0 feet; thence southerly, parallel with and 794.0 feet easterly from the west line of the SW 1/4 of said Section 31, a distance of 466.0 feet; thence westerly parallel with and 466.0 feet southerly from the north line of the SW 1/4 of said Section 31, a distance of 232.0 feet; thence northerly, parallel with the west line of the SW 1/4 of said Section 31, a distance of 436.0 feet to a point 30.0 feet southerly from the north line of the SW 1/4 of said Section 31; thence westerly parallel with and 30.0 feet southerly from the north line of the SW 1/4 of said Section 31, a distance of 392.0 feet; thence southwesterly along a straight line to a point 150.0 feet southerly from the north line of the SW 1/4 of said Section 31 and 50.0 feet easterly from the west line of the SW 1/4 of said Section 31; thence westerly, parallel with and 150.0 feet southerly from the north line of the SW 1/4 of said Section 31, a distance of 50.0 feet to a point on the west line of the SW 1/4 of said Section 31; thence northerly along the west line of the SW 1/4 of said Section 31 a distance of 150.0 feet to the point of beginning excepting the west 50.0 feet thereof. Containing 3.0 acres, more or less.

f
f.



4' wide

3½ - 4' deep

Large half moon, concrete

jw 12-3-75

9204130004

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St. Marys Avenue Phone (402) 471-7800

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

REAL ESTATE TRANSFER / LO

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 3-30-92

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 7E; SECTION 31 East of the 6th P.M.; BLOCK ____

LOT ____; ADDITION _____; Street Address 10700 So 27

Directions to Property ½ mile North on 27th From Saltillo RD East Side

Location of Well East Side of Home Tap Location: Inside ☒ Outside ☒

Location of Sewage System 50' South & 10' West of Southwest Corner of the house Year Installed 1975

	NAME	ADDRESS	PHONE
Present Owner:	Richard/Brenda Doetker	R.R. #1 Box 170A Roca, Ne	423-3328
Tenant/Buyer:			
Return to:			

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Richard Doetker Address R.R. #1 Box 170A Roca, Ne 68430

==========

HEALTH DEPARTMENT USE ONLY

Date Received MARCH 31, 1992 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE 4/1/92

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☒	☐	Approved:	☒	Date 4/1/92 by J.C.H.
Bacteria	☒	☐	Provisional:	☐	Date _____ by ____
Nitrate <0.1ppm	☒	☐	Disapproved:	☐	Date _____ by ____

Comments: IF THE SEPTIC TANK HAS NOT BEEN PUMPED RECENTLY IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED. IT WOULD HAVE BEEN BETTER TO SITUATE THE TANK SO IT WOULDN'T HAVE BEEN DRIVEN OVER OR THAT THE GRADE HAD NOT BEEN RAISED OVER PART OF THE LATERAL, NO EVIDENCE OF MALFUNCTION HOWEVER. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☒	Approved: ☒	Provisional Approval: ☐

APPROVED BY Jerrold C. Hood R.E.H.S. DATE APRIL 7, 1992

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832