FILE #2272

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF LICENSE OR PERMIT

MAY 5, 1986
THIS LICENSE OR PERMIT EXPIRES

FRED ELSWICK — RFD #8 — LINCOLN, NE. 68506
LICENSEE OR PERMITTEE — ADDRESS

T9N; R7E; Sec 31 W½, NE¼, SE¼, NE¼
NAME OF ESTABLISHMENT, IF ANY — ADDRESS

REMARKS: NON TRANSFERABLE ALTER, EXTEND OR REPAIR

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 30.00	018754	$ 30.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. — Date and Amount

APPLICATION

HEALTH
ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO. 2272

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 11-5-85

The undersigned hereby applies for a permit to ALTER [X], EXTEND [ ], or REPAIR [ ] an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 19N; Range 8E; Section 31 W½, NE¼, SE¼, NE¼;
Block _____; Lot _____; Addition _____
Street Address _____

2. Property Use: Residential _____ [X]; Commercial _____ [ ]
No. Bedrooms 2
Describe _____
Other Use [ ]
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Description of proposed alteration, extension or repair: ABANDON SEPTIC SYSTEM & INSTALL LAGOON

5. Work to be done by: Owner [ ]; or Contractor [X], SOUTHWICK SEWER & DRAIN
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$	1300 00

Fred ELSWICK
Signature of Applicant (owner or lessee)

RFD 8 LINCOLN 68506
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Site Visits:
Date: 11/5/85 by: L.C.H. need fence pad etc
Date: 2/12/86 by: L.C.H.
Date: _____ by: _____

3. Date: Approved [X]; Disapproved [ ]
by: Jerold C. Hoos

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 2/12/86 by: L.C. Hoos

005

Lincoln-Lancaster County Health Department

2200 St. Mary's Avenue, Lincoln, Nebrask

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

REAL ESTATE TRANSFER/LOAN

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☒ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☒ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 3501 Rokeby Rd

Twp 9N Range 7E Section 31 1/4 ___ 1/4 ___ Block ___ Lot ___ Addition ___

Directions to Property Approx 35th + Rokeby Rd - South on lane - gray house at end of lane

Location of Well South of house Tap Location: Inside ☐ Outside ☒

Location of Sewage System Lagoon North of house Year Installed 1986

	NAME	ADDRESS	PHONE
Present Owner:	Debbra L Hoy	Box 167A Roca, Ne	473-3220 (D) 423-4266 (H)
Tenant/Buyer:			
Return to:	above		

Signature of Applicant Debbra L Hoy Address above Date 11 / 18 / 92

HEALTH DEPARTMENT USE ONLY

Date Received 11 / 18 / 92 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By Gerald Hood **DATE:** 11 / 19 / 92

WATER SYSTEM:	Approved	Disapproved
Construction	☒	☐
Bacteria	☒ ____/ml	☐ ____/ml
Nitrate	☒ <0.1 ppm	☐ ____ppm

SEWAGE SYSTEM
Approved ☐
Provisional ☐
Disapproved ☒

Additional Site Visits
Date 11 / 24 / 92 by L.C.H.
Date ___ / ___ / ___ by ___
Date ___ / ___ / ___ by ___

Comments: LAGOON NEEDS WARNING SIGNS. NEEDS WEEDS, CATTAILS AND SAPLINGS CLEARED OUT OF AND AROUND LAGOON. Corrected 11/24/92 L.C.H. Good job-!


See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☒ Provisional Approval: ☐

Approved by Gerald C. Hood R.E.H.S. Date 11 / 24 / 92

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.


PROPERTY LINES
LANE
43'
43'
60'
75'
75'
30'