014

# LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-780

**ORIGINAL LOAN APPROVAL FILE**
**PREVIOUS HISTORY UNKNOWN**

REAL ESTATE TRANSFER / LO

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☑ Evaluation of the Individual Water System Date: 5-11-93

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 7E; SECTION 32; BLOCK ~~10~~

LOT 10; ADDITION _____; Street Address 10445 Dawn ave

Directions to Property 3/4 mi So of Hwy 2 on 56th to Liberty Lane West 2 blks to Dawn ave, No to Road end.

Location of Well East of driveway Tap Location: Inside ☐ Outside ☒

Location of Sewage System No of House Year Installed _____

| | NAME | ADDRESS | PHONE |
|---|---|---|---|
| Present Owner: | Madlyn Schwartz | 10445 Dawn ave | 423 7001 |
| Tenant/Buyer: | | | |
| Return to: | Madlyn Schwartz | 10445 Dawn ave | 68506 |

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Madlyn Schwartz Address RT 8 Lincoln Ne

==========

*HEALTH DEPARTMENT USE ONLY*

Date Received MAY 11, 1993 Received $150.00 Check ☒ Cash ☐

---

PRELIMINARY STATUS--DATE 5/13/93

| WATER SYSTEM: | Approved | Disapproved | SEWAGE SYSTEM: | | SITE VISIT: |
|---|---|---|---|---|---|
| Construction | ☒ | ☐ | Approved: | ☐ | Date 5/13/93 by J.C.H. |
| Bacteria | ☒ | ☐ | Provisional: | ☒ | Date _____ by ____ |
| Nitrate <0.1ppm | ☒ | ☐ | Disapproved: | ☐ | Date _____ by ____ |

Comments: SEPTIC SYSTEM PREDATES REGULATIONS. NO RECORD OF SEPTIC SYSTEM HENCE APPROVAL IS PROVISIONAL. NO EVIDENCE OF MALFUNCTION. See Attached Letter ☐

---

FINAL STATUS

| | WATER SYSTEM: | SEWAGE DISPOSAL SYSTEM: | |
|---|---|---|---|
| | Approved: ☒ | Approved: ☐ | Provisional Approval: ☒ |

APPROVED BY Gerald C. Hood R.E.H.S. DATE MAY 17, 1993

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832

104