LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 ST. MARYS
LINCOLN, NEBRASKA 68502

FILE NO. 2469-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

SEPTEMBER 31, 1987 — THIS PERMIT EXPIRES

RICHARD WAGNER — ISSUED TO

P.O. BOX 165 ROCA, NE 68430 — ADDRESS

T9N: R7E: Sec 32: Lot 32 I.T.
LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE METER, EXTEND OR REPAIR

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY: MC — DATE: 4-1-87 — AMOUNT:

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH
ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO. _____

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: _____

The undersigned hereby applies for a permit to ALTER [X], EXTEND [ ], or REPAIR [ ] an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: ~~T32 R6W 32-9-7~~ Twp. 9N ; Range 7E ; Section 32 ;
Block _____ ; Lot 32 I.T. ; Addition _____
Street Address _____

2. Property Use: Residential _____ [X] ; Commercial _____ [ ]
No. Bedrooms 2 Describe _____
Other Use [ ]
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank [ ] ; Other [—]

4. Description of proposed alteration, extension or repair: CONVERT TO LAGOON WITH LIFT STATION.

5. Work to be done by: Owner [ ] ; or Contractor [—] , Strahman Oil Co Inc
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$	2500 00

Richard Wagner
Signature of Applicant (owner or lessee)

Box 165 Roca, Ne 68430
Address

(Do not write below this line)


REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Site Visits:
Date: 4-6-87 by: _____
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved [X] ; Disapproved [ ]
by: Gerrold E. Wood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 4-6-87 by: _____



4-45°x4"
2- wyes x 4"
2- 2"x45°
1- 2"x4" connector
1- ~~Fernco~~ connector 4" plastic to cast
2- 4" caps
1- 2" check valve
1- 282 pump

Dick Wagner

N

002

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 9-29-92

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N; RANGE 7E; SECTION 32 SW¼; BLOCK ____

LOT 32; ADDITION _____; Street Address 4500 Saltillo Rd.

Directions to Property go South on 56th Street to Saltillo Road, turn right & go to red mailbox with address 4500 Saltillo on it

Location of Well W of house ? Tap Location: Inside ☐ Outside ☒

Location of Sewage System _____ Year Installed 1987

	NAME	ADDRESS	PHONE
Present Owner:	Larry + Jane Semler	4500 Saltillo Road	421-7379
Tenant/Buyer:	Stan + Tami Rudder	Rt. 1, Wymore, NE	486-6355
Return to:	Nebraska Title To Mary Lancaster, 633 South 9th, Suite 100, Lincoln 68508		

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Tamara J. Rudder Address Rt. 1, Wymore, NE

==========

HEALTH DEPARTMENT USE ONLY

Date Received SEPTEMBER 30, 1992 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE SEPTEMBER 30, 1992 10/7/92 by J.C.H.

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☒	☐	Approved:	☐	Date 9/30/92 by J.C.H.
Bacteria	☒	☐	Provisional:	☐	Date 10/5/92 by J.C.H.
Nitrate 2.4ppm	☒	☐	Disapproved:	☒	Date 10/6/92 by J.C.H.

Comments: NO FENCE ON EAST SIDE OF LAGOON, NO WARNING SIGNS, NO LOCKED GATE. Corrected 10/7/92 J.C.H.

_____ See Attached Letter ☐

FINAL STATUS

	WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
	Approved: ☒	Approved: ☒	Provisional Approval: ☐

APPROVED BY Jerrold C. Hood R.E.H.S. DATE October 7, 1992

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832