LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-

ORIGINAL LOAN APPROVAL FILE
PREVIOUS HISTORY UNKNOWN

REAL ESTATE TRANSFER /

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

[X] Evaluation of the Individual Water System Date: 7/19/91

[X] Evaluation of the Sewage Disposal System [XX] Enclosed is $150.00

Legal Description of Property: TWP. 9N ; RANGE 7E ; SECTION SE 1/4 32 ; BLOCK ____

LOT 34 ; ADDITION _____ ; Street Address Route 1, Box 164A, Roca, NE 68430

Directions to Property 50th & Saltillo Road, blue house on north side of street

Location of Well SW corner of house 6' from drive Tap Location: Inside [X] Outside [ ]

Location of Sewage System 25' east of center of chimney Year Installed 1969

	NAME	ADDRESS	PHONE
Present Owner:	Ben & Holly Parpart	Route 1, Box 164A, Roca, Ne. 68430	423-5392
Tenant/Buyer:	Gary & Michelle Boyer	7100 S. 40th, Rte. 16, Lincoln Ne. 68516	423-6895
Return to:	Martell State Bank/Doug Gappa	Box 95, Martell, Ne. 68404	794-5375

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant R. Holly Address Box 95, Martell, Ne. 68404

==========

HEALTH DEPARTMENT USE ONLY

Date Received JULY 19, 1991 Received $150.00 Check [X] Cash [ ]

PRELIMINARY STATUS--DATE JULY 19, 1991

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	[X]	[ ]	Approved:	[ ]	Date 7/19/91 by J.C.H
Bacteria	[X]	[ ]	Provisional:	[X]	Date _____ by ____
Nitrate	[X]	[ ]	Disapproved:	[ ]	Date _____ by ____

Comments: IF THE SEPTIC TANK HAS NOT BEEN PUMPED RECENTLY IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED. SEPTIC SYSTEM APPARENTLY PREDATES REGULATIONS HENCE APPROVAL IS PROVISIONAL. NO EVIDENCE OF MALFUNCTION. See Attached Letter [ ]

FINAL STATUS

	WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
	Approved: [X]	Approved: [ ]	Provisional Approval: [X]

APPROVED BY Gerrold E. Hood R.S. DATE JULY 24, 1991

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832