LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 ST. MARYS
LINCOLN, NEBRASKA 68502

FILE NO. 2625-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

AUGUST 9, 1988 — THIS PERMIT EXPIRES

GARY M. TEMPLE — ISSUED TO

5020 BANCROFT LINCOLN, NE 68506 — ADDRESS

T9N; R7E; Sec 32; Lot 54 I.T. — LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE NEW CONSTRUCTION

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 60.00	$	$	$ 60.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY	DATE	AMOUNT
MC	2-16-88	

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH
ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

A

FILING FEE: $ 60.00

FILE NO. 2625-C

DATE: _____

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section 32 ;
   Block _____ : Lot 54 IT : Addition _____
   Street Address _____

2. Property Use: Residential ☑ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 4 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: MILES ft. ~~TO BE DETERMINED BY SOIL PERCOLATION TEST~~

Gary M Semple
Signature of Applicant (Owner or Lessee)

5020 Bancroft St., Lincoln 68506
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 2/9/88 . Date Frwd. 2/9/88 . ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 2/10/88 . Date Frwd. 2/10/88 . ACTION: Approved ☐ Disapproved ☐ Signature: _____

3. City or County Engineer : Date Rec'd. 2/9/88 . Date Frwd. _____ . ACTION: Approved ☒ Disapproved ☐ Signature: _____

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 8-29-88 by: _____
Date: _____ by: _____
Date: _____ by: _____

INSTALLATION FINAL WRITTEN APPROVAL
Date: 8-30-88 By: _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM 23-43

FORM CONTROL NUMBER 23098

LANCASTER COUNTY
CASH RECEIPT

PAGE 1 OF 1

TRANSACTION CODE	C	R	CASH RECEIPT NUMBER	DATE OF DEPOSIT	ACCOUNTING PERIOD	BUDGET FY
			28789	M M D D Y Y: 02 19 88	M M Y Y	Y Y: 88

ACTION: [X] ORIGINAL ENTRY (E) [ ] ADJUSTMENT (M)

BANK ACCOUNT: 11

OFFSET CASH ACCOUNT:

COMMENTS: L & L County Health

REFERENCE INVOICE NUMBER	REFERENCE INVOICE LINE NO.	FUND	AGENCY	ORGANIZATION	SUB ORG	ACTIVITY	REVENUE SOURCE	SUB REV SRCE	JOB NUMBER	REPT. CATEG	BAL SHEET ACCT.	OBJECT	SUB-OBJ	VENDOR/ PROVIDER	AMOUNT	INC./ DEC IND	P/F IND
		011	999				2559								60 00		
DESCRIPTION									Sewer Permit 2625-C								
DESCRIPTION																	
DESCRIPTION																	
DESCRIPTION																	
DESCRIPTION																	
DESCRIPTION																	
DESCRIPTION																	

TOTAL 60 00

PREPARED BY:
NAME _____ TITLE _____ DATE _____

APPROVED BY:
NAME _____ TITLE _____ DATE _____

APPROVED BY:
NAME MG TITLE _____ DATE 2-10-88

ORIGINAL

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

B

FILE NO. 2625-C

PROPERTY WHERE SOIL TESTED:

Location: Township 7N ; Range 7E ; Section & ¼ Section 32 . LOT 54 I.T.
Property Dimensions: _____ ft. x _____ ft. Area: _____ acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 3/27 to 3/28 . Weather: Precip. No Temp. 45° .

641' x 620.5' x 701' x 560.7 x 84.85

OWNER: GARY M. TEMPLE

Address: 5020 BANCROFT ST. LINCOLN NE 68506

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1		3/27	9 AM	3/28	8:00	3/28	8:10	6"	8:40	3/8	30	3/8	30/3/8
2		3/27	9:30AM	3/28	8:00	3/28	8:15	6"	8:45	6/8	30	6/8	30/6/8
3		3/27	9:40 AM	3/28	8:00	3/28	8:20	6"	8:50	5/8	30	5/8	30/5/8
4		3/27	10 AM	3/28	8:00	3/28	8:25	6"	8:55	11/8	30	11/8	30/11/8
5		3/27	10:20 AM	3/28	8:00	3/28	8:30	6"	9:00	3/8	30	3/8	30/3/8
6		3/27	10:40 AM	3/28	8:00	3/28	8:35	6"	9:05	4/8	30	4/8	30/4/8

Sum of Percolation Rates: 30/4 in
Average of Rates: 5.33/8
Mean of Rates: _____

Gary M. Temple
Signature of Person Conducting Test

Address 5020 BANCROFT ST LINCOLN, NE Phone 488-9274

(Do not write below this line)

REVIEWING ACTION

Remarks: _____
Soil Type (SCS): WYMORE SILTY CLAY LOAM
Date: MARCH 30, 1988

Approved Percolation Rate (a)
A. 48 min./inch
B. _____ min./inch
C. _____ min./inch

Derrold C. Hood
Signature of Reviewing Official

FORM 20102-0477
PRELIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒


LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

C

Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.

FILE NO._____

Indicate on sketch if residence and well are exisiting or proposed.



REVIEWING ACTION

Remarks :_____

Date: MARCH 30, 1988

Minimum Design Requirement
1. Capacity of Septic Tank 1250 gals.
2. Total Length of Laterals _____ ft.
3. With a Trench Width of _____ in.
4. Total Area of Lateral needed ~~1232~~ sq.ft.

Gerrold C. Hood
Signature of Reviewing Official

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

D

DATE: _____

FILE NO. _____


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material PVC; Diameter 4 in.
2. Distance above basement floor _____ in., or below basement floor 14 in.
3. Distance between dwelling and septic tank 175 ft.
4. Number of clean-outs 3.
5. Distances to: Well or Suction Line _____ ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

B. SEPTIC TANK:
1. Material Pre Cast; No. of compartments _____.
2. Capacity 1500 gals.;
3. Factory Built: Yes ☒ No ☐ (Company _____)
4. Manholes: Over Inlet; diam. _____ in. Over Outlet; diam. _____ in. Riser Above ☐ Below ☐ Grade ____ in.
5. Inlet: Baffle ☐ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☐
7. Depth of top of tank below finished grade 8" in.
8. Distances to: Well or Suction Line _____ ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.


C. DISTRIBUTION BOX:
1. Material Pre Cast; Number - available outlets _____.
2. Factory Built: Yes ☒ No ☐ (Company _____)
3. Distance from Septic Tank 13 ft.


D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☐ Perforated Pipe ☒ Diameter of Half Round _____ or Perforated Pipe _____. Material: fiberglass ☐ ; plastic ☐ ; concrete ☐ ; other _____.
2. Lateral Lines: Number 5 ; Length of each line 100, 100, 100, 100, 10 ft.; Total length of laterals 410 ft.; Distance between lateral lines ____ ft.
3. Trench dimensions: Width 3 ft.; Slope 6 in/100 ft.; Average Depth 32 in.
4. Filter Material: Road Gravel Depth of Material 16 in.
5. Distances to: Well or Suction Line — ft.; Stream — ft.; Pressure Line — ft.; Property Line — ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

APPROX. DIST. BETWEEN HOLES





8-29-88

Larry Schwarck

