CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

FILE NO. 332

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

December 18, 1973 — THIS LICENSE OR PERMIT EXPIRES

Bouwens Plumbing Co. — LICENSEE OR PERMITTEE

2300 South 62nd Street — ADDRESS

T9N; R7E; Sec. 33; Bl. 2; Lot 5; Nealrene Acres 1st Add.

NAME OF ESTABLISHMENT, IF ANY — LEGAL DESCRIPTION — ADDRESS

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
110.15	110.16	148.14	6-2

624-1535

SERIAL NO. | DATE | AMOUNT

APPLICATION

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-32(67) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 332

DATE: _____

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 9; Range 7; Section 33;
Block 2; Lot 5; Addition Meadowlane Acres 1st Addition
Street Address _____

2. Property Use: Residential _____ [✓]; Commercial _____ [ ]
No. of Bed Rooms _____ Describe: _____

Other Use _____ [ ]
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [✓]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-32a(67) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT, attached hereto.)

Chuck Lehanover
Signature of Applicant (owner or lessee)

_____
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Date Site Clearance 11-14-73

3. Site Visits:
Date: 11-14-73 by: jw
Date: _____ by: _____
Date: _____ by: _____

4. Date: Approved [X]; Disapproved [ ]: 6/18/73
by: Jerrold E. Rood R.S.

5. BUREAU OF LICENSES & PERMITS
Date Notified: _____
Date Issued: _____ Serial _____

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 11-14-73 by: jw

FORM HD-30(67) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 332

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described herein:

1. Legal description of property: Twp. 9 ; Range 7 ; Section 33 ;
Block 2 ; Lot 5 ; Addition ~~First Addition~~ Meadrene acres
Street Address _____

2. Property Use: Residential ☑; Commercial ☐
No. of Bedrooms 3. Describe: _____
Other Use ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☑; Other ☐

4. Distance to public sewer: _____ ft.

Chuck Schanou
Signature of Applicant (owner or lessee)

Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 6/18/73. ACTION: Approved ☒ Disapproved ☐
Date Frwd. 6/18/73. Signature: Jerrold C. Hood R.S.

2. Supt. Bldg. Insp.: Date Rec'd. 6-19-73. ACTION: Approved ☒ Disapproved ☐
Date Frwd. 6-19-73. Signature: Chas Seals By B.S.

3. Dpty City Engineer: Date Rec'd. 6-19-73. ACTION: Approved ☒ Disapproved ☐
Date Frwd. " . Signature: J L Blessing

REMARKS OR REASONS FOR DISAPPROVAL _____

FINAL ACTION ON SITE CLEARANCE: Approved ☒ Disapproved ☐

Date Applicant Notified: 11-14-73 Signature gw

FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 332

PROPERTY WHERE SOIL TESTED:
Location: Township 9 North Range 7 East of the 6th PM
North West Section & ¼ Sect. ~~9 North Range 7 East of the 6th PM~~
Property Dimensions: ___ft. x 33 ft.
Area: _____acres. (Attach sketch of property showing hole location).
Owner: Chuck Schramow
Address _____

Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☐; Sandy Clay ☐ ?

Dates of Tests: 5/20 to 5/21. Weather: Precip. Wet Temp. 75 F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
Hole No.	Hole Depth (in.)	Pre-Saturation Period Start Date (Mo. Day)	Pre-Saturation Period Start Time (Hr. Min.)	Pre-Saturation Period End Date (Mo. Day)	Pre-Saturation Period End Time (Hr. Min.)	Percolation Readings Start Date (Mo. Day)	Percolation Readings Start Time (Hr. Min.)	Percolation Readings Start Water Level (in.)	Percolation Readings End Time (Hr. Min.)	Percolation Readings End Water Level (in.)	Results Elapsed Time (Min.)	Results Water Level Drop (in.)	Results Percolation Rates (Min./inch)
1	48	5/20	3:10	5/21	5:25	5/21	5:30	6	6:00	5¼	30	3/4	
2	48	"	3:15	"	5:28	"	5:33	6	6:03	5½	30	½	
3	48	"	3:18	"	5:30	"	5:35	6	6:05	5½	30	½	
4	48	"	3:20	"	5:35	"	5:40	6	6:10	5½	30	½	
5	48	"	3:25	"	5:40	"	5:45	6	6:15	5¾	30	¼	
6	48	"	3:30	"	5:43	"	5:50	6	6:20	5½	30	½	

Sum of Percolation Rates ½" 30'
Average of Rates:
Mean of Rates:

Wesley W Bowers
Signature of Person Conducting Test

Address 3900 No 27th Bowers Plumbing
Phone: 466 1644

(Do not write below this line)

REVIEWING ACTION

REMARKS: Rate right at maximum

DATE: June 18, 1973

Approved Percolation Rate(s)
A. 60 min./inch
B. _____ min./inch
C. _____ min./inch

Gerrold C. Hood
Signature of Reviewing Official

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 332

SPECIFICATIONS

DATE: _____


A. BUILDING SEWER:
1. Material _____; Diameter ____ in.
2. Distance above basement floor ____in.; or below basement floor ____in.
3. Distance between dwelling and septic tank ____ft.
4. Number of clean-outs _____.
5. Distances To:
Well or Suction Line ____ft.;
Stream ____ft.; Pressure Line ____ft.;
Property Line ____ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Concrete No. of compartments _____.
2. Capacity 1000 gals.; Liquid depth ____in.
3. Factory Built: Yes ☑ (Company Tanner Pre Cast)
No ☐
4. Manholes: Over Inlet; diam. ____in.
Over Outlet; diam. ___in.
Below Grade _____in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☐
Depth of outlet below inlet ___in.
7. Depth of top of tank below finished grade ____in.
8. Distances To:
Well or Suction Line ____ft.;
Stream ____ft.; Pressure Line ____ft.;
Property Line ____ft.


C. DISTRIBUTION BOX
1. Material Concrete; No. available outlets 6.
2. Factory Built: Yes ☑, (Company Tanner Pre Cast)
No ☐
3. Dimension: Length ____in.; Width ___in.
Depth ____in.
4. Distance from Septic Tank ____ft.
5. Serial Distribution: Yes ☐, No ☐
(If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: Concrete
2. Lateral Lines: Depth below grade 18 in.
Number 3; Length of each line ___ft
Total length of Laterals 247 ft.;
Slope ____in/100 ft. Diameter of pipe ____ in.; Shape _____
Material: concrete ☐; fiber asbestos ☐; clay ☐; other _____
Distance between lateral lines ____ft.
3. Trench Dimensions: Depth 36 in.;
Width 48 in.
4. Filter Material: Gravel.
Depth of material from trench bottom _____in.
5. Distances To:
Well or Suction Line ____ft.;
Stream _____ft.; Pressure Line ____ft.
Property Line ____ft.
6. Percolation Rate: _____minutes/inch

TYPICAL SKETCHES



Chuck Schanou
Signature of Applicant



Fiberglass tank
" small half moons

It appears that there is no area left for additions to systems

soil was black

jw

11-14-73

N