FILE #2080

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

OCTOBER 30, 1984 — THIS LICENSE OR PERMIT EXPIRES

LARRY SCHWARCK — LICENSEE OR PERMITTEE

8200 OLD CHENEY RD. — ADDRESS

LINCOLN, NE 68516

T9N; R7E; Sec 33; Bk 3; Lot 5; Nealrene Acres — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NON TRANSFERABLE ALTER, EXTEND OR REPAIR

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 30.00	018754	$ 30.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. — Date and Amount

APPLICATION

HEALTH

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒

County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 2080

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: April 19, 1984

The undersigned hereby applies for a permit to ALTER ☐, EXTEND ✓, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 19N ; Range 7E ; Section 33 ;
Block 3 ; Lot 5 ; Addition Neal Rean Acres FIRST ADDITION
Street Address _____

2. Property Use: Residential _____ ✓; Commercial _____ ☐
No. Bedrooms 3 Describe _____
Other Use ☐
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank ✓; Other ☐

4. Description of proposed alteration, extension or repair:
Add 80' Lateral

5. Work to be done by: Owner ☐ ; or Contractor ☒ , Larry Schwarck
Contractor's Name

6. Estimated cost of project:

a. Materials	$	472.00
b. Labor	$	
c. Other	$	
TOTAL	$	472.00

Larry Schwarck
Signature of Applicant (owner or lessee)

8200 Old Cheney Rd Lincoln, Ne
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Site Visits:
Date: April-84 by: nnn *
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒ ; Disapproved ☐
by: Jerrold E. Hood
PROVISIONAL ONLY


4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 12-2-97 by: Ron Hagemeister

* Note that south laterals was capped off at distribution box because apparently ground water was seeping up through laterals.

Neal Rene Acres.

Larry Schwarck

4-19-84



80' perf pipe in 3' Trench

Average 36" Deep.

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St. Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER

This form must be completed and returned to request a real estate transfer inspection.
MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☐ Evaluation of the Individual Water System Date: 9/16/83

☑ Evaluation of the Sewage Disposal System ☑ Enclosed is $45.00

Legal description of property: TWP. 9N ; RANGE 7E ; SECTION 33

BLOCK 3 ; LOT 5 ; ADDITION NEALBERNE ACRES FIRST ADDITION

Street Address RT. 8

Directions to Property S. ON 56TH ST TO ROKEBY RD., E. TO NEALBERNE ACRES, PROPERTY LOCATED IN S.E. CORNER OF ADD.

Location of Well _____ Tap Location: Inside ☐ Outside ☐

Location of Sewage System _____ Year Installed _____

	NAME	ADDRESS	PHONE
Present Owner:	ZETTERMAN	RT. 8, NEALBERNE ACRES	423-0510
Tenant/Buyer:	PETERSON	1924 N. 58TH	464-5880
Return To:	BOB HINRICHS FIRST FEDERAL	C/O AUSTIN REALTY 3910 SOUTH ST BOX 5204	68505 ATTN: VIVIAN

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant _____ Address 3910 SOUTH ST

HEALTH DEPARTMENT USE ONLY

Date Received SEPTEMBER 20, 1982 Received $45.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE 9/21/83

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:	SITE VISIT:
Construction	☐	☐	Approved: ☐	Date 9/21/83 by L.C.H
Bacteria	☐	☐	Provisional: ☐	Date 10/11/83 by L.C.H
Nitrate	☐	☐	Disapproved: ☒	Date 4/84 by R.M.

Comments: SEWAGE VIOLATION EFFLUENT ON GROUND SURFACE. IF OLD WELL IS NOT GOING TO BE USED THEN WELL MUST BE PROPERLY ABANDONED ACCORDING TO SECTION 8.54.080 OF THE LINCOLN MUNICIPAL CODE. See Attached Letter ☐

Contingent upon correction of sewage violation - see attached letter

FINAL STATUS

WATER SYSTEM: Approved: ☐ RURAL WATER DISTRICT

SEWAGE DISPOSAL SYSTEM: Approved: ☐ Provisionsal Approval: ☒

APPROVED BY Ron Mayer DATE 9-29-83 (APRIL 1984)

20215-1079R WELL BEING KEPT MUST HAVE SOIL MOUNDED AROUND IT, NO DEPRESSION.