LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 ST. MARYS
LINCOLN, NEBRASKA 68502

FILE NO. 2005-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF PERMIT

DECEMBER 29, 1983
THIS PERMIT EXPIRES

BILL BARCLAY — 1940 DEVOE DRIVE — LINCOLN, NE 68506
ISSUED TO — ADDRESS

T9N; R7E; Sec. 33; Bk 4; Lot 4; Deerhaven Acres
LEGAL DESCRIPTION

REMARKS: NONTRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 60.00	$	$	$ 60.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY: EB
DATE: 6/24/85
AMOUNT:

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH
ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $ 60.00

FILE NO. 2005-C

DATE: 6-29-83

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section 33 ;
   Block 4 : Lot 4 : Addition DEERHAVEN ACRES
   Street Address _____

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒

4. Distance to public sewer: _____ ft.

Signature of Applicant (Owner or Lessee)

1940 DEWOE LINCOLN
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 6/29/83. Date Frwd. 6/29/83. ACTION: Approved ☒ Disapproved ☐ Signature: Errold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. _____. Date Frwd. _____. ACTION: Approved ☐ Disapproved ☐ Signature: _____

3. City or County Engineer: Date Rec'd. 6/29/83. Date Frwd. 11. ACTION: Approved ☐ Disapproved ☐ Signature: Don Thomas

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 11-14-83 by: mm - ~~not relevant~~ - need parcel
Date: 5-11-84 by: mm - need final drawing
Date: 3-8-85 by: mm

INSTALLATION FINAL WRITTEN APPROVAL
Date: 3-8-85 By: Ken Magnuson

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

B

FILE NO. 2005-C

PROPERTY WHERE SOIL TESTED:

Location: Township_____; Range_____; Section & ¼ Section_____.
Property Dimensions: _____ft. x _____ft. Area:_____acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ■ .
Dates of Tests: 4-8-83 to 4-9-83. Weather: Precip. .05 Temp. 35°.

#LOT 4 BLOCK 4 DEERHAVEN

OWNER: Bill Barcley
Address: 483-6463 or 473-7007

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	36"	4-8	4:30 pm	4-9	8:30 AM	4-9	8:30 AM						
2	"	"	"	"	"	"	"						
3	"	"	"	"	"	"	"						
4	"	"	"	"	"	"	"						
5	"	"	"	"	"	"	"						
6	"	"	"	"	"	"	"						

ALL Hole's Still Full From Pre. Test

William M. Hoagland
Signature of Person Conducting Test

Address 2701 N 27th Lot 22 Phone_____

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____


(Do not write below this line)

REVIEWING ACTION

Remarks:_____
Soil Type (SCS): Wymore Silty Clay Loam
Date: June 29, 1983

Approved Percolation Rate (a)
A._____min./inch
B._____min./inch
C._____min./inch

Jerrold C. Wood
Signature of Reviewing Official


No.
1
2
3
4
5
6
50'
100'
Deerhaven Road
50.56

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

FOR PROPERTY IN **LANCASTER COUNTY** ONLY

This form must be completed and returned with payment to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: "Lincoln-Lancaster County Health Department" or "LLCHD"

☑ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

Legal Description of Property: Street Address 10901 So 63

Twp 9N Range 7E Section 33 1/4 SW 1/4 Block 4 Lot 4 Addition Deerhaven Acres

Directions to Property go south on South 56th street to Deerhaven Road. Go east to house

Location of Well Rural water Tap Location: Inside ☐ Outside ☐

Location of Sewage System west of house Year Installed 1983

	NAME	ADDRESS	PHONE
Present Owner:	Duane Pavlish	10901 So 63 Lincoln NE 68516	421-8320
Tenant/Buyer:			
Return to:	Duane Pavlish	10901 So 63 Lincoln NE 68516	421-8320

Signature of Applicant Duane Pavlish Address 10901 So 63 Lincoln NE 68516 Date 3/12/96

HEALTH DEPARTMENT USE ONLY

RECEIVED
Date 3/13/96
Initials J.C.H.
Amount $150.00
Check No. 3617

DATA ENTRY
Date ____/____/____
Case No. ____
Initials ____

PRELIMINARY STATUS--By Jerrold C. Hood **DATE:** 3/13/96

RURAL WATER DISTRICT

WATER SYSTEM:	Approved	Disapproved
Construction	☐	☐
Bacteria	☐ ____/ml	☐ ____/ml
Nitrate	☐ ____ppm	☐ ____ppm

SEWAGE SYSTEM
Approved ☒
Provisional ☐
Disapproved ☐

Additional Site Visits
Date____/____/____by____
Date____/____/____by____
Date____/____/____by____

Comments: LAGOON COULD USE A LITTLE MORE WATER IN.

See Attached Letter ☐

FINAL STATUS RURAL WATER DISTRICT

WATER SYSTEM: Approved ☐ **SEWAGE DISPOSAL SYSTEM:** Approved ☒ Provisional Approval ☐

Approved by Jerrold C. Hood R.E.H.S. Date 3/13/96

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

White - Applicant after approval Yellow - Environmental Health Pink - Business Office

Revised/Reprint: 10-95

001

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

FOR PROPERTY IN **LANCASTER COUNTY** ONLY

This form must be completed and returned with payment to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: "Lincoln-Lancaster County Health Department" or "LLCHD"

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

3305

Legal Description of Property: Street Address 10901 So. 63rd.

Twp 9N Range 7E Section 33 1/4 ___ 1/4 ___ Block ___ Lot ___ Addition DEER HAVEN ACRES

Directions to Property South on 56th to Deerhaven to So 63rd. just No of Seattle

Location of Well No Well Tap Location: Inside ☐ Outside ☒

Location of Sewage System Back of Home Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	Pavelish		
Tenant/Buyer:	Fisbeck	5801 Deerwood Dr.	421-8787
Return to:	Attn. Shon L. Fisbeck	Community Mortgage 4645 Normal Blvd	441-3200

Signature of Applicant Shon L. Fisbeck Address 5801 Deerwood Dr. Date 4/21/97

HEALTH DEPARTMENT USE ONLY

RECEIVED

Date 04/21/97
Initials MS
Amount 150.00
Check No. 4720

DATA ENTRY

Date ___/___/___
Case No. ___
Initials ___

PRELIMINARY STATUS--By P. DROTZMANN **DATE:** 4/23/97

WATER SYSTEM:	Approved	Disapproved
Construction	☐	☐
Bacteria	☐ ___/ml	☐ ___/ml
Nitrate	☐ ___ppm	☐ ___ppm

SEWAGE SYSTEM

Approved ☐
Provisional ☐
Disapproved ☒

Additional Site Visits

Date 4/25/97 by PD
Date ___/___/___ by ___
Date ___/___/___ by ___

Comments: ON RURAL WATER SYSTEM. LAGOON GATE NOT SECURED WITH LOCK. CEDAR TREES ALONG EAST SIDE OF DIKE. SHOULD LAGOON FAIL TO OPERATE CORRECTLY, ALL TREES WITHIN 100 FEET OF LAGOON WILL NEED TO BE REMOVED. See Attached Letter ☐

4-28-97 GATE LOCKED

FINAL STATUS

WATER SYSTEM: Approved ☒ **SEWAGE DISPOSAL SYSTEM:** Approved ☒ Provisional Approval ☐

Approved by Paul Drotzmann Date 4/28/97

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

White - Applicant after approval Yellow - Environmental Health Pink - Business Office

Revised/Reprint: 10-95

BK 4 Lot 4 Deerhaven

IAA Verbeek
10901 So 63
Lincoln. Ne 68516

