LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

2200 St. Marys Ave Lincoln, NE 68502-3785 (402) 441-8000

NON TRANSFERABLE

PERMIT

Permit
SEWAGE INSTALLATION

No. 94380118701

Issued 06/22/94
Expires 12/22/94
Revenue Code 18754

Establishment
DAN KUBR
T9N R7E SEC 35
LOT 17

FEES: $150.00

TOTAL $150.00

Permittee
DAN KUBR
RR0001
BOX 00138
ROCA NE 68430

Issued By M. Jane Ford
Health Director

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW
"POST IN A PROMINENT PLACE"

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

A

FILING FEE: $ 150.00

FILE NO. _____

DATE: 6/23/94

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 9N ; Range 7E ; Section 35 ;
   Block _____ : Lot 17II : Addition _____
   Street Address 1/8 MILE NORTH OF 98 + SALTILLO RD WEST SIDE

2. Property Use: Residential ☑ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☑ ; Other ☐

4. Distance to public sewer: 0 ft.

Dan Kuhl Const
Signature of Applicant (Owner or Lessee)

RT 1 Box 138 ROCA NE 68430
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 6/23/94 . Date Frwd. 6/24/94 . ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk: Date Rec'd. 6/24/94 . Date Frwd. 6/24/94 . ACTION: Approved ☒ Disapproved ☐ Signature: Gary Lyon

3. City or County Engineer: Date Rec'd. 6/24/94 . Date Frwd. _____ . ACTION: Approved ☒ Disapproved ☐ Signature: Thomas

REMARKS OR REASONS FOR DISAPPROVAL Build System @ Above 100 Yr Flood Plain of Unnamed Creek

Site Visits:
Date: 10/20/94 by: D.C.H. Sewer, tank + 2 laterals
Date: 10/21/94 by: D.C.H.
Date: _____ by: _____

INSTALLATION FINAL WRITTEN APPROVAL
Date: 11/30/94 By: Jerrold Hood

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM 23-43

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

B

FILE NO. _____

PROPERTY WHERE SOIL TESTED:

Location: Township 9N ; Range 7E ; Section & ¼ Section 35 SE/4
Property Dimensions: _____ ft. x _____ ft. Area: _____ acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☒ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 6-28 to 6-29 94. Weather: Precip. 0 Temp. 80s.

OWNER: Rod Lancomer

Address: Lincoln, Ne 68510

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Water Level (in.)	Time (Hr./Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	38	6/28	7:30	6/29	7:00	6/29	11:10	28	11:40	28½	30	½	
2	↓		AM		AM		AM	29¾	AM	30⅜		⅝	
3								27⅛		27⅝		½	
4								28½		28⅞		⅜	
5								27		27⅝		⅝	
6								26⅞		27⅜		½	

Brad Southwell
Signature of Person Conducting Test

Address 17201 So. 72 Hickman Phone 475-2462

Sum of Percolation Rates: 3.125
Average of Rates: .52
Mean of Rates: _____

(Do not write below this line)

REVIEWING ACTION

Remarks: _____

Soil Type (SCS): _____

Date: _____

Approved Percolation Rate (a)
A. _____ min./inch
B. _____ min./inch
C. _____ min./inch

_____
Signature of Reviewing Official

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

D

DATE: 10-22-94

FILE NO. _____


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material PVC ; Diameter 4" in.
2. Distance above basement floor ____ in., or below basement floor 14 in.
3. Distance between dwelling and septic tank 59 ft.
4. Number of clean-outs 1 .
5. Distances to: Well or Suction Line NA ft.; Stream ____ ft.; Pressure Line ____ ft.; Property Line ____ ft.

B. SEPTIC TANK:
1. Material C-Crete ; No. of compartments 1 .
2. Capacity 1,000 gals.;
3. Factory Built: Yes ☒ No ☐ (Company PreCast)
4. Manholes: Over Inlet; diam. 9 in. Over Outlet; diam. 15 in. Riser Above ☐ Below ☐ Grade ____ in.
5. Inlet: Baffle ☒ ; or Tee ☐
6. Outlet: Baffle ☒ ; or Tee ☐
7. Depth of top of tank below finished grade 14 in.
8. Distances to: Well or Suction Line NA ft.; Stream ____ ft.; Pressure Line ____ ft.; Property Line 20+ ft.

C. DISTRIBUTION BOX:
1. Material PVC ; Number - available outlets 5 .
2. Factory Built: Yes ☒ No ☐ (Company ____)
3. Distance from Septic Tank 14 ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☐ Perforated Pipe ☒ Diameter of Half Round ____ or Perforated Pipe 4" . Material: fiberglass ☐ ; plastic ☒ ; concrete ☐ ; other ____ .
2. Lateral Lines: Number 3 ; Length of each line 100 , 100 , 100 , ____ , ____ ft.; Total length of laterals 300 ft.; Distance between lateral lines 20+ ft.
3. Trench dimensions: Width 38" ~~ft.~~; Slope 6 in/100 ft.; Average Depth ____ in.
4. Filter Material: Road Gravel Depth of Material 12 in.
5. Distances to: Well or Suction Line NA ft.; Stream ____ ft.; Pressure Line ____ ft.; Property Line 20+ ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

Pere For Lavcomer
To Jerry Hs

