LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

2200 St. Marys Ave Lincoln, NE 68502-3785 (402) 471-8000

NON TRANSFERABLE

PERMIT

Permit
SEWAGE SYSTEM REPAIR

No. 92390030401

Issued 10/16/92
Expires 04/16/93
Revenue Code 18754

Establishment
ARNOLD HOUDEK
T12N R8E SEC 33
LOT 7

FEES: $50.00

TOTAL $50.00

Permittee
ARNOLD HOUDEK
RR0002
MILFORD NE 68405

Issued By M. Jane Ford
Health Director

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW
"POST IN A PROMINENT PLACE"

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO. _____

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 10/14/92

The undersigned hereby applies for a permit to ALTER ☒, EXTEND ☐, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 12N; Range 8E; Section 33;
Block ____; Lot T.L.; Addition _____
Street Address _____

2. Property Use: Residential _____ ☒; Commercial _____ ☐
No. Bedrooms 3
Describe _____
Other Use ☐
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair:
new lagoon system

5. Work to be done by: Owner ☐; or Contractor ☒, Orville Hurst
Contractor's Name

6. Estimated cost of project:

a. Materials	$
b. Labor	$
c. Other	$
TOTAL	$ 1500 00

Arnold F. Hondek
Signature of Applicant (owner or lessee)

Milford, Neb RT 2
Address

(Do not write below this line) (761-2004)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 50.00

2. Site Visits:
Date: 10-16-92 by: P.D
Date: 10-19-92 by: ran tile loss could to well
Date: 7-15-96 by: ran recharge
11-20-97 ran dike not tobulit

3. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Hoof

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: _____ by: _____

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☐ Evaluation of the Individual Water System ☐ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 15700 N. 141st St. Waverly NE 68462

Twp 8N Range 8 Section 33 1/4 NE 1/4 Block ___ Lot 12 Addition ___

Directions to Property 3½ mi NORTH OF HWY 6 ON 141st 2 STORY WHITE HOUSE EAST SIDE OF RD

Location of Well 20 FT EAST OF HOUSE Tap Location: Inside ☐ Outside ☐

Location of Sewage System 50 YDS EAST OF HOUSE Year Installed 90'

	NAME	ADDRESS	PHONE
Present Owner:	Arnold Houdek	Route 2 Milford NE 68405	1-402-761-2004
Tenant/Buyer:	Dustin Crist	15700 N. 141st St. Waverly NE 68462	786-3358
Return to:	Dustin Crist	same	same

Signature of Applicant Dustin L Crist Address SAME Date 12/18/94

HEALTH DEPARTMENT USE ONLY

Date Received 12/19/94 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By Ron Marquart **DATE:** 12/20/94

WATER SYSTEM:	Approved	Disapproved	**SEWAGE SYSTEM**	**Additional Site Visits**
Construction	☒	☒ corrected	Approved ☐	Date 1/12/95 by RM
Bacteria	☒ 0 /ml	☐ ___ /ml	Provisional ☐	Date 1/17/95 by RM
Nitrate	☒ 1.3 ppm (treated)	☒ 15.8 ppm (raw)	Disapproved ☒	Date ___/___/___ by ___

Comments: the southeast half of the waste stabilization lagoon dikes must be reconstructed before approval can be given.

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ * **SEWAGE DISPOSAL SYSTEM** Approved: ☐ Provisional Approval: ☐

Approved by Ron Marquart, RS Date 1/20/95

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

* Approval applies to treated water for nitrate removal, not the raw water.