LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 1253-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

JUNE 28, 1978 — THIS PERMIT EXPIRES

MARY L. NEAL, RFD, BENNET, NE 68317 — ISSUED TO / ADDRESS

T9N, R8E, Section 29 (ALTER) — LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 15.00	$	$	$ 15.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH — ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1253-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 12/27/77

The undersigned hereby applies for a permit to ALTER ☒, EXTEND ☐, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 9N; Range 8E; Section 29;
Block _____; Lot _____; Addition _____
Street Address 9600 So 120TH St.

2. Property Use: Residential _____ ☒; Commercial _____ ☐
No. Bedrooms 3 Describe _____
Other Use ☐
Describe LAGOON

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☒

4. Description of proposed alteration, extension or repair: _____

5. Work to be done by: Owner ☐ ; or Contractor ☒, Tom Felton
Contractor's Name

6. Estimated cost of project:

a. Materials	$
b. Labor	$
c. Other	$
TOTAL	$

[signature] (Mrs)
Signature of Applicant (owner or lessee)
Mary L. Neal
RFD 1 Bennet Ne. 68317
Address

(Do not write below this line)


REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 15.00

2. Site Visits:
Date: 12/30/77 by: L.C.H.
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 12/30/77 by: L.C.H.


Mary Neal
120 Street
9600
HOUSE
clearouts
57
80
30
22
25
50
N
E

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☐ Evaluation of the Individual Water System Date: 10-3-90

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 9N ; RANGE 8E ; SECTION 29 ; BLOCK ____

LOT 127; ADDITION _____; Street Address 9500 S. 120th

Directions to Property approx. ½ mile N of Hwy 2 east side

Location of Well _____ Tap Location: Inside ☐ Outside ☐

Location of Sewage System _____ Year Installed ____

	NAME	ADDRESS	PHONE
Present Owner:	Mary Neal Schutz	9500 S. 120th	wk 472-3611
Tenant/Buyer:	Margaret Parker	9003 Pioneers	489-6674
Return to:	President Federal Savings	440 So. 13th	474-5559

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Kelly Peterson Address 400 S. 13th 68508

==========

HEALTH DEPARTMENT USE ONLY

Date Received October 3, 1990 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE 10-4-90

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☐	☐	Approved:	☒ (Corrections made.)	Date 10-4-90 by mm
Bacteria	☐	☐	Provisional:	☐	Date 10-15-90 by mm
Nitrate	☐	☐	Disapproved:	☒	Date _____ by ____

Comments: small trees & one large tree on dike of lagoon must be removed. Water level in lagoon must be between the 2-3 ft level. May have to seal lagoon so that it holds water. Recommend not dumping waste oil on the ground. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☐	Approved: ☒	Provisional Approval: ☐

APPROVED BY Ron Maynard DATE 10-17-90

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832