LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 1346-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — December 26, 1978

TYPE OF PERMIT — THIS PERMIT EXPIRES

Woodcraft Homes — 3545 North 48 Street, Lincoln, NE

ISSUED TO — ADDRESS

T12N, R6E, Section 32, Block 3, Lot 2, Add. Willard Estates

LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH

ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $ 30.00

FILE NO. 1346-C

DATE: May 26, 1978

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 12N ; Range 6E ; Section 32 ; Block 3 : Lot 2 : Addition Willard Estates
   Street Address _____

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒

4. Distance to public sewer: _____ ft.

X Woodcraft Homes Corp. Willard Woosley
Signature of Applicant (Owner or Lessee)

3545 No 48 Lincoln
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 6/26/78. Date Frwd. 6/26/78. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

X 2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 6-21-78. Date Frwd. 6-21-78. ACTION: Approved ☒ Disapproved ☐ Signature: Shirley Grant, Clerk

3. City or County Engineer: Date Rec'd. 6-26-78. Date Frwd. 6-26-78. ACTION: Approved ☒ Disapproved ☐ Signature: Henry Graff

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 7-14-78 by: gw
Date: 8-23-78 by: gw
Date: _____ by: _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

INSTALLATION FINAL WRITTEN APPROVAL
Date: 8-24-78 By: James Wevecka

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

B

FILE NO. 1346-C

PROPERTY WHERE SOIL TESTED:

Location: Township 12N ; Range 6E ; Section & ¼ Section 32 SE/4
Property Dimensions: _____ ft. x _____ ft. Area: _____ acres. (Attach Sheet C with sketch of property).

Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .

Dates of Tests: 5-14-78 to 5-15-78 . Weather: Precip. _____ Temp. _____ .

OWNER: WOODCRAFT HOMES

Address: LINCOLN, NE

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End		Elapsed	Water	Percolation
Hold No.	Hole Depth (in.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Water Level (in.)	Time (Hr./Day)	Water Level (in.)	Time (Min.)	Level Drop (in.)	Rates (Min./in.)
1	30	5/14	12:00	5/15	12:00	5/15	3:30	14¼	4:00	14⅜	30	⅛	240
2								13½		14⅛		⅝	48
3								16¼		16¾		½	60
4								17½		18⅛		⅝	48
5								17¼		17¾		½	60
6								17½		18		½	60

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

Brad Southwick
Signature of Person Conducting Test

Address Hickman, Ne Phone 792-2462

(Do not write below this line)

REVIEWING ACTION

Remarks: _____

Soil Type (SCS): _____

Date: _____

Approved Percolation Rate (a)
A. _____ min./inch
B. _____ min./inch
C. _____ min./inch

_____
Signature of Reviewing Official

FORM 20102-0477
PRELIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐


LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

C

Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.

FILE NO. 1346-E

Indicate on sketch if residence and well are exisiting or proposed.



REVIEWING ACTION

Remarks: _____

_____

Date: _____

Minimum Design Requirement
1. Capacity of Septic Tank _____ gals.
2. Total Length of Laterals _____ ft.
3. With a Trench Width of _____ in.
4. Total Area of Lateral needed ____ sq.ft.

_____
Signature of Reviewing Official

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

D

DATE: _____

FILE NO. _____


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material_____; Diameter_____in.
2. Distance above basement floor_____ in., or below basement floor_____in.
3. Distance between dwelling and septic tank_____ft.
4. Number of clean-outs_____.
5. Distances to:
Well or Suction Line_____ft.;
Stream_____ft.; Pressure Line _____ft.; Property Line_____ft.

B. SEPTIC TANK:
1. Material_____; No. of compartments_____.
2 Capacity_____gals.;
3. Factory Built: Yes ☐ No ☐
(Company_____)
4. Manholes: Over Inlet; diam._____in.
Over Outlet; diam._____in.
Riser Above ☐ Below ☐ Grade____in.
5. Inlet: Baffle ☐ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☐
7. Depth of top of tank below finished grade_____in.
8. Distances to:
Well or Suction Line_____ft.;
Stream_____ft.; Pressure Line _____ft.; Property Line_____ft.

C. DISTRIBUTION BOX:
1. Material_____; Number - available outlets_____.
2. Factory Built: Yes ☐ No ☐
(Company_____)
3. Distance from Septic Tank_____ft.


D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☐ Perforated Pipe ☐
Diameter of Half Round_____ or
Perforated Pipe_____.
Material: fiberglass ☐ ;plastic ☐ ;
concrete ☐ ; other_____.
2. Lateral Lines:
Number___;Length of each line_____,
_____,_____,_____,_____ft.;
Total length of laterals_____ft.;
Distance between lateral lines____ft.
3. Trench dimensions: Width_____ft.;
Slope_____in/100 ft.; Average Depth_____in.
4. Filter Material:_____
Depth of Material_____in.
5. Distances to:
Well or Suction Line_____ft.;
Stream_____ft.; Pressure Line _____ft.; Property Line_____ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

AS BUILT DRAWING OF SYSTEM

DATE JULY 14 1978 INSTALLER NORM BERGHUIS



WILLARD ESTATES
LOT 2 BLK 4

N